CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM





LISTING No. 7165-1615:0119 Page 1 of 2

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: BOSCH SECURITY SYSTEMS130 Perinton Parkway, Fairport, NY 14450

Contact: Jon Wolski (585) 678-3323 Fax (585) 678-3263

Email: jon.wolski@us.bosch.com

DESIGN: Models D7212B, D7412G, D7412GV2, D9112B, D9412, D9412G and D9412GV2 fire alarm

control units. Inherently power-limited; remote station, central station and local service. Refer to listee's data sheet for detailed product description and operational considerations.

System components:

D122; Dual Battery Hardness

D125B; Powered Loop Interface Module D126; 12V, 7Ah Rechargeable Battery

D127/D136; Relay

D928; Dual Phone Line Switcher Module

D129; Initiating Circuit Module

D130/D8130; Relay Module/Release Module

D161/162; Phone Cord

D192C/192D/D192G; Circuit Supervision Modules D268/269/279; Independent Zone Control Modules

D720/1255/1256/1257; Command Centers

D720R/1255R/D720W/D1255W/D1260; Command Centers

*D1255RB/*1256RB/*1257RB; Command Centers

D8132; Battery Charger Module D1218; Battery - 12V 18 Ah

D8121A/8122; Subscriber Terminal Unit D8125/D8125MUX; POPEX Module

D9127T/D9127U; POPIT

D8128/8128A/8128C/D8128D; OctoPOPIT Module

D8129; OctoRelay Module D9131; Parallel Printer Interface D1640; Class 2 Transformer

D8004/8103/8109/8108A; Enclosures D8109G/D8109H/D8109L; Enclosures

D9133TTL-E, DX4020; Network Interface Module

DS7432; Mutiplex Expander Module

DS7457iF/DS7461i; Single Zone Multiplex Input Module

DS7460i; 2-Zone Expander

DS7465i; Input/Output Multiplex Module ICP-SDI-9114; SDI Splitter/Isolator Module

*Rev. 06-19-09 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: July 01, 2012 Listing Expires June 30, 2013

Authorized By: JASON DEWITT, Deputy State Fire Marshal

Fire Engineering Division

Listing No. 7165-1615:0119

Page 2 of 2

INSTALLATION: In accordance with the listee's printed installation instructions, applicable codes and

ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as fire alarm control units suitable for high rise application for use with separately

listed compatible Applied American Technologies' Model EVAC-2101 voice

evacuation/communication system (CSFM Listing No. 6911-1393:103), two way firefighter telephone system, initiating and indicating signal devices. Models D9127T and D9127U POPIT modules shall be used with four-wire smoke detectors only. Model EVAC-2101 and the FACP must be installed in the same room, not more than 20' apart. Wiring between the

FACP and the EVAC-2101 must be in conduit.

These control units can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition. Refer to manufacturers

installation instruction manual for details. Authority having jurisdicti

NOTE: 1. For Fire Alarm Verification Feature (delay of alarm signaling), the maximum

Retard/Reset/Restart period shall not exceed 30 seconds.

2 Burglary and other non-fire functions were not examined.

3. Combined with 7170-1615:145

*Rev. 06-19-09 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: July 01, 2012 Listing Expires June 30, 2013

Authorized By: JASON DEWITT, Deputy State Fire Marshal

Fire Engineering Division