

消防處
牌照及審批總區

香港九龍
尖沙咀東部康莊道1號5樓
消防總部大廈



FIRE SERVICES DEPARTMENT
LICENSING AND CERTIFICATION COMMAND

Fire Services Headquarters Building,
No. 1 Hong Chong Road, 5/F.,
Tsim Sha Tsui East, Kowloon,
Hong Kong

本處檔號 Our Ref.: (18) in FP 206/1207
來函檔號 Your Ref. J-002/C/096
圖文傳真 Fax: 2367 3631
電話 Tel. No.: 2733 7557
電子郵件 E-mail: lcpolic2@hkfsd.gov.hk

27 February 2006

Bosch Security Systems Ltd
12/F, Metropole Square,
2 On Yiu Street, Shatin,
N.T.

Dear Sirs,

Acceptance of Detectors

I refer to my interim reply of 25.1 .2005 on the captioned subject.

Please be informed that the following detectors, which have been certified by Underwriters Laboratories Inc., are acceptable to this Department:-

Manufacturer : Bosch Security Systems

Type : Smoke Detector, 4-wire conventional, photoelectric

Testing Standards : ANSI/UL 268 and CAN/ULC-S529-02

Models : FCP-500,
FCP-500-P,
FCP-500-C, and } (employed a supplementary CO sensor)
FCP-500-C-P }

Supporting Document : Test report file S3019 Project 04CA21919 issued by Underwriters Laboratories Inc. on 5 May 2005.

/P.2

Please note that the above acceptance is valid subject to:-

- i. all conditions as stipulated in the above-mentioned test report being complied with;
- ii. the installation conforming to FSD Circular Letter No. 1/2002 Rules for Fire Detection and Alarm Systems for Buildings; and
- iii. the components used in the installation being compatible.

Yours faithfully,



(CHAN Chor-kam)
for Director of Fire Services

CCK/TLC/lkc