

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7167-1615:0239

Page 1 of 2

**CATEGORY:** 7167 -- CONTROL UNIT (HOUSEHOLD)

**LISTEE:** BOSCH SECURITY SYSTEMS 130 Perinton Parkway, Fairport, NY 14450  
Contact: Jon Wolski (585) 678-3323 Fax (585) 678-3263  
Email: jon.wolski@us.bosch.com

**DESIGN:** Model D7212GV3, D7412GV3 and D9412GV3 residential fire alarm control units.  
Refer to listee's data sheet for additional detailed product description and operational considerations. System components:  
D720/1255/1256/1257/1260; Command Centers (may be followed by W or R)  
D122/122L; Dual Battery Harness  
D125B; Powered Loop Interface Module  
D126; 12V, 7Ah Battery  
D127; Relay  
D129; Initiating Circuit Module  
D130/D133; Relay Module  
D161/D162; Phone Cord  
D5300; Remote Account Manager II  
D8121A; Subscriber Terminal Unit  
D8125; POPEX Module  
D9127T, 9127U; POPIT Module  
D8128D; OctoPOPIT Module  
D1640; Transformer  
D8004/8103/8109/8108A; Enclosures  
D8129; OctoRelay Module  
D8130; Release Module  
D8132; Battery Charger Module  
D9131/D9131A; Printer Interface  
DX4020; Network Interface Module  
ITS-DX4020-G; GPRS/GSM IP Communicator  
ICP-SDI-9114; Splitter/Isolator  
DS7432; Multiplex Expander Module  
DS7457iF/DS7461i; Single Zone Multiplex Input Module  
DS7460i; 2-Zone Expander  
DS7465i; Input/Output Multiplex Module

6-1-10 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2013**

Listing Expires **June 30, 2014**

Authorized By: **JAMES PARSEGIAN, Program Coordinator**  
*Fire Engineering Division*

- INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
- MARKING:** Listee's name, model number, electrical rating, and UL label.
- APPROVAL:** Listed as household fire alarm control units for use with separately listed compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual for details.  
For fire alarm use, the secondary (standby) power supply shall supply energy during power loss to operate a protected premises, central station, or proprietary system for 24 hours or an auxilliary or remote station system for 60 hours in the normal condition followed by not less than 5 minutes of alarm as required by code.  
These control units can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition.
- NOTE:**
- 1) For household system, Fire Alarm Verification Feature (delay of fire alarm signal) is NOT approved for use in California. This feature shall not be programmed into the unit.
  - 2) Burglary and other non-fire functions were not examined.

6-1-10 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2013**

Listing Expires **June 30, 2014**

Authorized By: **JAMES PARSESIAN, Program Coordinator**  
*Fire Engineering Division*