

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7167-1615:0223 Page 1 of 1

CATEGORY: 7167 -- CONTROL UNIT (HOUSEHOLD)

LISTEE: BOSCH SECURITY SYSTEMS 130 Perinton Parkway, Fairport, NY 14450
Contact: Frank Mioduszewski (585) 678-3368 Fax (585) 678-3263
Email: frank.ski@us.bosch.com

DESIGN: Models ICP-EZM1-NA and *ICP-EZM2-NA residential fire alarm control unit. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

IUI-EZ1; Control Center/Keypad
ICP-EXVM-ENF, -ENM; Voice Module
ICP-EZTS; Tamper Switch
AE1/D8108A; Enclosures
*DX2010; Expansion Module
*D132A; Smoke Detector Reversing Relay Module
*C900V2; Dialer Capture Module

RATING: 120 V, 60 Hz, 30 VA

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as residential fire alarm control unit for use with separately listed compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual for details.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition.

- NOTE:**
1. For fire alarm use, the secondary (standby) power supply shall supply energy during power loss to operate a protected premises, central station, or proprietary system for 24 hours or an auxiliary or remote station system for 60 hours in the normal condition followed by not less than 5 minutes of alarm as required by code.
 2. For household system, **Fire Alarm Verification Feature** (delay of fire alarm signal) is NOT approved for use in California. This feature shall not be programmed into the unit.
 3. Burglary and other non-fire functions were not examined.

*Rev. 12--2006 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division