

CERTIFICATE OF COMPLIANCE

Certificate Number S7365
Report Reference S7365-20200528
Issue Date 2020-JUNE-05

Issued to: Bosch Security Systems, Inc
130 Perinton Pkwy
Fairport NY 14450-9107

This certificate confirms that representative samples of HEAT-AUTOMATIC FIRE DETECTORS
See next page

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: ANSI/UL 521- Heat Detectors for Fire Protective Signaling Systems

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>




CERTIFICATE OF COMPLIANCE

Certificate Number S7365
Report Reference S7365-20200528
Issue Date 2020-JUNE-05

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Models

Single Station Heat Alarm, 3V Battery Operated, 135°F Fixed Threshold with 15°F Rate of Rise, Model RFHT-A



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

