



# **CONETTIX B6800 Central Station Software Receiver**

B6800-SR

**en**

Protocol Reference



## Contents

<b>1.0</b>	<b>Introduction .....</b>	<b>5</b>
1.1	CONETTIX B6800 Central Station Software Receiver .....	5
<b>2.0</b>	<b>Recommended programming .....</b>	<b>5</b>
2.1	Receiver connection to automation .....	5
<b>3.0</b>	<b>Communication Protocols.....</b>	<b>6</b>
3.1	D6500 Mode Messages.....	6
3.1.1	Acron Super Fast (Message Type 9) .....	6
3.1.2	Ademco 4-1 Express (Message Type b) .....	7
3.1.3	Ademco 4-2 Express (Message Type c).....	8
3.1.4	Ademco Contact-ID (Message Type a) .....	9
3.1.5	Ademco 10-Digit Contact-ID (Message Type a).....	10
3.1.6	Ademco High Speed, 4-8-1 (Message Type f) .....	11
3.1.7	ADT SIA (Message Type S) .....	12
3.1.8	Caller ID (Message Type e) .....	13
3.1.9	CFSK (Message Type i).....	13
3.1.10	Common Formats (Message Type 1) .....	14
3.1.11	DNIS/ANI (Message Type N) .....	15
3.1.12	DSC 4-3 (Message Type d) .....	16
3.1.13	FBI Super Fast (Message Type F) .....	17
3.1.14	ITI (Message Type l) .....	18
3.1.15	Link Test (Message Type 1) .....	19
3.1.16	Robofon (Message Type j) .....	20
3.1.17	Sescoa Super Speed (Message Type 7).....	21
3.1.18	Scancom 4-16-1, 5-16-1, 6-16-1 - Available Upon Request (Message Type g) .....	22
3.1.19	Scancom 4-24-1, 5-24-1, 6-24-1 - Available Upon Request (Message Type h) .....	23
3.1.20	Seriee FSK (Message Type k) .....	24
3.1.21	Seriee DTMF (Message Type l) .....	25
3.1.22	SIA (Message Type S) .....	26
3.1.23	Silent Knight FSK0 (Message Type 1).....	27
3.1.24	Silent Knight FSK1 (Message Type m) .....	30
3.1.25	Silent Knight FSK2 (Message Type m).....	33
3.1.26	Silent Knight FSK80 D6500 mode (Message Type 1).....	34
3.1.27	Telim (Message Type n) .....	35
3.1.28	Text Message (Message Type 3) .....	36
3.1.29	Varitech FSK 4-1 (Message Type 1) .....	37
3.1.30	Varitech FSK 4-2 (Message Type 1) .....	38
3.1.31	VONK (Message Type V) .....	39
3.1.32	X-SIA Text (Message Type S) .....	40
3.1.33	SafeCom (Message Type p) .....	41
3.2	SIA Mode Messages.....	42
3.2.1	Acron Super Fast (Message Type 9) .....	42
3.2.2	Ademco Contact-ID (Message Type a) .....	43
3.2.3	Ademco 10-Digit (Message Type b) .....	43
3.2.4	Ademco 4-1 Express (Message Type b) .....	44
3.2.5	Ademco 4-2 Express (Message Type c).....	46
3.2.6	Ademco High Speed 4-8-1, SCANCOM 4-8-1 (Message Type f) .....	47

3.2.7 Caller ID (Message Type <TAB>) .....	49
3.2.8 CFSK (Message Type i).....	50
3.2.9 Common Formats (Message Type <TAB>) .....	51
3.2.10 DNIS/ANI (Message Type N) .....	53
3.2.11 FBI Super Fast (Message Type F) .....	56
3.2.12 ITI (Message Type I) .....	58
3.2.13 Link Test (Message Type <TAB>) .....	59
3.2.14 RB2000 (Message Type R) Description .....	60
3.2.15 Robofon (Message Type j) .....	61
3.2.16 Scancom 4-16-1, 5-16-1, 6-16-1 - Available Upon Request (Message Type g) .....	62
3.2.17 Scancom 4-24-1, 5-24-1, 6-24-1 - Available Upon Request (Message Type h) .....	63
3.2.18 Seriee DTMF (Message Type l) .....	64
3.2.19 Seriee FSK (Message Type k) .....	65
3.2.20 Sescoa Super Speed (Message Type 7).....	66
3.2.21 Silent Knight FSK() (Message Type <TAB>) .....	67
3.2.22 Silent Knight FSK1 (Message Type m).....	68
3.2.23 Silent Knight FSK2 (Message Type m).....	70
3.2.24 Silent Knight FSK80 (Message Type <TAB>) .....	71
3.2.25 Telim (Message Type n) .....	72
3.2.26 Varitech FSK 4-1 (Message Type <TAB>) .....	73
3.2.27 Varitech FSK 4-2 (Message Type <TAB>) .....	74
3.2.28 VONK (Message Type V) .....	75
3.2.29 X-SIA text (Message Type <TAB>) .....	76
3.2.30 SafeCom (Message Type p) .....	77
3.3 Input Command Processing.....	78
Appendix A: Contact ID Event Code Classifications.....	79
Appendix B: Internal Messages.....	89
Appendix C: Modem4/ModemIII <sup>a</sup> Messages .....	93
Appendix D: Network Messages .....	141
Appendix E: Pulse Output .....	145
Appendix F: Format ID (by Message Type) .....	151
Appendix G: ADT SIA Report Codes.....	155
Appendix H: RB2000 Messages .....	161
Appendix I: SafeCom Messages.....	169
Appendix J: Acknowledgement from Automation Software.....	179
Appendix K: Cyclic Redundancy Check (CRC) Calculation.....	181
Appendix L: Network Automation .....	185

# 1.0 Introduction

## 1.1 CONETTIX B6800 Central Station Software Receiver

The CONETTIX B6800 Central Station Software Receiver (CONETTIX B6800-SR) is a software-based IP receiving platform. The system runs on commercial off the shelf (COTS) Windows. The CONETTIX B6800-SR replaces the Bosch D6600 and D6100IPV6 hardware receiver products for IP applications but retains the product functionality. The CONETTIX B6800 Central Station Software Receiver does not support PSTN.

This manual is intended for use as a reference for the protocols used by the Bosch D6100ipv6 and the D6600 hardware receiver products. The content is from the legacy manual named *CONETTIX D6600/D6100/Pv6/D6100i Recevier/Gateway Computer Interface Manual*.

# 2.0 Recommended programming

## 2.1 Receiver connection to automation

Below are the recommended selections for programming when connecting the receivers to an automation system.

Table 1: Recommended Programming Selections	
Receiver Gateway Number	Selects a number (01 to 99) that is included in every message to the computer in both D6500 and SIA modes
Output Format	Enable output messages in the selected format: SIA computer interface standard format, recommended (expanded reporting capabilities) D6500 21-character format output
Link Test	Tests if a supervision signal can be sent and received from the central station by the receiver

## 3.0 Communication Protocols

### 3.1 D6500 Mode Messages

In D6500 Mode, the line number/group number sent to the computer is only one digit. Refer to Table 2.

**Table 2: Line Number/Group Number Conversion Table**

Line# /Group #	Converted to	Line# /Group #	Converted to	Line # /Group #	Converted to	Line # /Group #	Converted to
L01/G01	1	L09/G09	9	L17/G17	H	L25/G25	P
L02/G02	2	L10/G10	A	L18/G18	I	L26/G26	Q
L03/G03	3	L11/G11	B	L19/G19	J	L27/G27	R
L04/G04	4	L12/G12	C	L20/G20	K	L28/G28	S
L05/G05	5	L13/G13	D	L21/G21	L	L29/G29	T
L06/G06	6	L14/G14	E	L22/G22	M	L30/G30	U
L07/G07	7	L15/G15	F	L23/G23	N	L31/G31	V
L08/G08	8	L16/G16	G	L24/G24	O	L32/G32	W

 In D6500 mode, any group that equals 33 is converted to an "X." Any group greater than or equal to 34 is converted to a "Y." For lines that are grouped, Gxx appears instead of Lxx. For networked accounts, Nxx appears instead of Lxx and the line number is identified.

#### 3.1.1 Acron Super Fast (Message Type 9)

Acron Super Fast Example	D6500 Byte Description																					
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
	h	9	r	r	l	s	s	s	s	a	a	a	a	C	C	C	C	C	C	C	C	t

**Table 3: Message Type 9 (Acron Super Fast) Byte Description**

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	9
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6-9	Spaces	Six spaces.
10-13	Account Number	Account number, four digits.
14-21	Channels	Channels 1 to 8
22	Trailer Character	Typically, this is HEX 14.

### 3.1.2 Ademco 4-1 Express (Message Type b)

4-1 Express  
Example

D6500 Byte Description	
	1    2    3    4    5    6    7    8    9    10    11    12    13    14    15    16    17    18    19    20    21    22
	h    b    r    r    l    s    s    s    s    s    a    a    a    a    s    E    s    s    s    X    t

Table 4: Message Type b (Ademco 4-1 Express) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	b
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6-11	Spaces	Six spaces.
12-15	Account Number	Account number, four digits.
16	Space	One space.
17	E	Event Code, "A" as the default.
18-20	Spaces	Three spaces.
21	X	Zone number.
22	Trailer Character	Typically, this is HEX 14.

### 3.1.3 Ademco 4-2 Express (Message Type c)

4-2 Express  
Example

D6500 Byte Description	
	1    2    3    4    5    6    7    8    9    10    11    12    13    14    15    16    17    18    19    20    21    22
	h    c    r    r    l    s    s    s    s    s    a    a    a    a    s    E    s    s    X    Y    t

Table 5: Message Type c (Ademco 4-2 Express) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	c
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6-11	Spaces	Six spaces.
12-15	Account Number	Account number, four digits.
16	Space	One space.
17	E	Event Code, "A" as the default.
18-19	Spaces	Two spaces.
20-21	XY	Event code and zone number.
22	Trailer Character	Typically, this is HEX 14.

### 3.1.4 Ademco Contact-ID (Message Type a)

Contact ID Example	D6500 Byte Description																					
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
	h	a	r	r	l	s	a	a	a	a	1	8	Q	X	Y	Z	G	G	C	C	C	t

Table 6: Message Type a (Ademco Contact ID) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	a
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6	Space	One space.
7-10	Account Number	Account number, four digits.
11-12	18	Ademco Contact-ID format number
13	Qualifier	Qualifier, 1=New event or opening, 3=New restore or closing, 6=Previous event.
14-16	XYZ	Class code and event code (see Appendix A: Contact ID Event Code Classifications).
17-18	GG	Group number.
19-21	CCC	Zone codes or user ID.
22	Trailer Character	Typically, this is HEX 14.

### 3.1.5 Ademco 10-Digit Contact-ID (Message Type a)

Contact ID Example	D6500 Byte Description													
	1	2	3	4	5	6	7	8	9	10	11	12	13	14
	h	a	r	r	l	s	a	a	a	a	a	a	a	a
	15	16	17	18	19	20	21	22	23	24	25	26	27	28
	a	a	5	8	Q	X	Y	Z	G	G	C	C	C	t

Table 7: Message Type a (Ademco 10-Digit) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	ASCII a. Message Type a for Ademco Contact-ID format.
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line Card Number	Line number in the receiver gateway that sent the message.
6	Space	One space.
7-16	Account Number	Account number, 10 digits.
17-18	58	Ademco Contact-ID format number for 10 digits account.
19	Qualifier	Qualifier, 1=New event or opening, 3=New restore or closing, 6=Previous event.
20-22	XYZ	Class code and event code (see Appendix A: Contact ID Event Code Classifications).
23-24	GG	Group number.
25-27	CCC	Zone codes or user ID.
28	Trailer Character	Typically, this is HEX 14.

### 3.1.6 Ademco High Speed, 4-8-1 (Message Type f)

	SCANCOM 4-8-1, 5-8-1, 6-8-1 - Available Upon Request
-----------------------------------------------------------------------------------	------------------------------------------------------

High Speed Example	D6500 Byte Description																																															
	<table> <tr> <td>1</td><td>2</td><td>3</td><td>4</td><td>5</td><td>6</td><td>7</td><td>8</td><td>9</td><td>10</td><td>11</td><td>12</td><td>13</td><td>14</td><td>15</td><td>16</td><td>17</td><td>18</td><td>19</td><td>20</td><td>21</td><td>22</td><td>23</td><td>24</td> </tr> <tr> <td>h</td><td>f</td><td>r</td><td>r</td><td>l</td><td>a</td><td>a</td><td>a</td><td>a</td><td>a</td><td>a</td><td>s</td><td>C</td><td>C</td><td>C</td><td>C</td><td>s</td><td>C</td><td>C</td><td>C</td><td>C</td><td>s</td><td>C</td><td>t</td> </tr> </table>	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	h	f	r	r	l	a	a	a	a	a	a	s	C	C	C	C	s	C	C	C	C	s	C
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24																									
h	f	r	r	l	a	a	a	a	a	a	s	C	C	C	C	s	C	C	C	C	s	C	t																									

**Table 8: Message Type f (Ademco High Speed, 4-8-1) Byte Description**

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	f
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6-11	Account Number	Account number, up to six digits. Account number less than six characters is right aligned with leading ASCII spaces.
12	Space	One space.
13-16	CCCC	Channels 1 to 4.
17	Space	One space.
18-21	CCCC	Channels 5 to 8.
22	Space	One space.
23	C	Supervisory channel.
24	Trailer Character	Typically, this is HEX 14.

### 3.1.7 ADT SIA (Message Type S)

ADT SIA Example	D6500 Byte Description																				
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21
	h	S	r	r	l	[	#	a	a	a	a		d	a	m	m	-	d	d	-	y
	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42
	y	t	l	h	h	:	m	m	:	s	s	E	M	M	Z	Z	Z	/	***	t	

Table 9: ADT SIA (Message Type S) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	S
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6	space	One space.
7	#	#
8-11	Account Number	Up to sixteen digits in the account number.
12		Separator. Indicates more data positions after account number.
13-32	Date and Time	Date and time.
33	E	SIA block code.
34-35	Event Code	SIA event code (refer to Appendix G: ADT SIA Report Codes).
36-39	Zone	Zone number.
40	/	Separator.
41	***	Next block of data.
42	Trailer Character	Typically, this is HEX 14.

### 3.1.8 Caller ID (Message Type e)

Caller ID Example	D6500 Byte Description																					
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
	h	e	r	r	1	T	T	T	T	T	T	T	T	T	T	T	T	T	T	T	T	t

Table 10: Caller ID (Message Type e) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	e
3-4	Receiver Number	Receiver gateway Number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6-21	Caller ID	Up to sixteen digits, Caller ID with less than sixteen characters is right aligned with leading ASCII spaces.
22	Trailer Character	Typically, this is HEX 14.

### 3.1.9 CFSK (Message Type i)

CFSK Example	D6500 Byte Description																					
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
	h	i	r	r	l	s	s	s	s	a	a	a	a	a	a	T	T	E	E	s	s	t

Table 11: CFSK (Message Type i) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	i
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6-9	Spaces	Four spaces.
10-15	Account Number	Six digit account number.
16-17	TT	Event Code.
18-19	EE	Zone/User ID.
20-21	Spaces	Two spaces.
22	Trailer Character	Typically, this is HEX 14.

### 3.1.10 Common Formats (Message Type 1)

Type 1 Example	D6500 Byte Description																					
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
	h	l	r	r	l	a	a	a	a	a	a	a	a	a	E	E	y	y	y	y	t	

**Table 12: Common Formats (Message Type 1) Byte Description**

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	1
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line Number	Line number in the receiver gateway that sent the message.
6-15	Account Number	Account number, up to ten digits. Account numbers less than ten characters are right aligned with leading ASCII spaces.
16-17	Event Code	Event codes define the type of signal received and interpreted by the D6500 receiver gateway.
18-21	Zone Number	Zone or ID number sent by the communicator. Zone numbers less than four digits are right aligned with leading ASCII spaces.
22	Trailer Character	Typically, this is HEX 14.

The receiver gateway sends the 3-1, 4-1, 4-2, single round, double round, extended pulse formats, BFSK, Modem II or Modem IId messages in either D6500 Mode or SIA Mode, depending on the programmable option selected. The receiver gateway also sends internal and ModemIIIa<sup>2</sup> messages in either D6500 mode or SIA mode, depending on the option selected. Refer to Appendix B: Internal Messages and Appendix C: Modem4/ModemIIIa<sup>2</sup> for a list of the messages and their descriptions.

### 3.1.11 DNIS/ANI (Message Type N)

DNIS/ANI  
Example

D6500 Byte Description															
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
H	N	r	r	l	s	D	d	d	d	d	d	d	d	d	d
17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
d	d	&	a	a	a	a	a	a	a	a	a	a	a	a	t

Table 13: DNIS/ANI (Message Type N) Byte Description

#	Title	Description
1	Header Character (H)	Optional. Check with the computer automation software for compatibility.
2	Message Type	N (Capital n).
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6	Space	One space.
7	DNIS Identifier	DNIS identifier.
8-18	DNIS Number	DNIS number, up to 11 digits.
19	ANI Identifier (&)	ANI identifier.
20-30	ANI Number	ANI number, up to 11 digits.
31	Trailer Character	Typically, this is HEX 14.

### 3.1.12 DSC 4-3 (Message Type d)

DSC 4-3  
Example

D6500 Byte Description																						
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
	h	d	r	r	l	s	s	s	s	s	a	a	a	a	s	E	s	X	Y	Y	t	

Table 14: DSC-4-3 (Message Type d) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	d
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6-11	Spaces	Six spaces.
12-15	Account Number	Account number, four digits.
16	Space	One space.
17	E	Event Code, "A" as the default.
18	Space	One space.
19	X	Event code number.
20-21	YY	Zone number.
22	Trailer Character	Typically, this is HEX 14.

### 3.1.13 FBI Super Fast (Message Type F)

FBI Super  
Fast Example

D6500 Byte Description	
	1    2    3    4    5    6    7    8    9    10    11    12    13    14    15    16    17    18    19    20    21    22
	h    F    r    r    l    s    s    s    s    s    a    a    a    a    T    Z    Z    E    s    s    t

Table 15: FBI Super Fast (Message Type F) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	F (Capital f).
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6-11	Spaces	Six spaces.
12-15	Account Number	Account number, four digits.
16	T	Zone type.
17-18	ZZ	Zone number.
19	E	Event type.
20-21	Spaces	Two spaces.
22	Trailer Character	Typically, this is HEX 14.

### 3.1.14 ITI (Message Type I)

ITI Example

D6500 Byte Description																						
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
	h	I	r	r	l	s	s	s	a	T	a	a	a	a	G	I	Z	Z	E	W	N	t

Table 16: ITI (Message Type I) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	I (Capital i).
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6-8	Spaces	Three spaces.
9	Account Number	First digit account number.
10	Panel Type	Control panel Type.
11-14	Account Number	Next four digit account number.
15	G	Group number.
16	I	Open/close (O/C) User ID.
17-18	ZZ	Zone number.
19	E	Condition code.
20	W	Protection level was.
21	N	Protection level is.
22	Trailer Character	Typically, this is HEX 14.

### 3.1.15 Link Test (Message Type 1)

Link Test  
Example

D6500 Byte Description																						
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
	h	1	r	r	0	s	s	s	s	s	s	s	s	s	s	@	s	s	s	s	t	

Table 17: Link Test (Message Type 1) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	1
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line Number	Line number as zero for link test.
6-15	Spaces	Eleven spaces.
16-17	Event Code	Event code is @ for link test.
18-21	Spaces	Four spaces.
22	Trailer Character	Typically, this is HEX 14.

### 3.1.16 Robofon (Message Type j)

Robofon  
Example

D6500 Byte Description																						
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
	h	j	r	r	l	s	s	s	s	a	a	a	a	a	E	E	s	s	s	s	t	

Table 18: Robofon (Message Type j) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	j
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6-9	Spaces	Four spaces.
10-15	Account Number	Six digit account number.
16-17	EE	Event code.
18-21	Spaces	Four spaces.
22	Trailer Character	Typically, this is HEX 14.

### 3.1.17 Sescoa Super Speed (Message Type 7)

Sescoa Super Speed Example	D6500 Byte Description																																											
	<table> <tr> <td>1</td><td>2</td><td>3</td><td>4</td><td>5</td><td>6</td><td>7</td><td>8</td><td>9</td><td>10</td><td>11</td><td>12</td><td>13</td><td>14</td><td>15</td><td>16</td><td>17</td><td>18</td><td>19</td><td>20</td><td>21</td><td>22</td></tr> <tr> <td>h</td><td>7</td><td>r</td><td>r</td><td>l</td><td>s</td><td>s</td><td>s</td><td>s</td><td>s</td><td>a</td><td>a</td><td>a</td><td>a</td><td>s</td><td>l</td><td>A</td><td>A</td><td>C</td><td>s</td><td>t</td></tr> </table>	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	h	7	r	r	l	s	s	s	s	s	a	a	a	a	s	l	A	A	C	s	t
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22																							
h	7	r	r	l	s	s	s	s	s	a	a	a	a	s	l	A	A	C	s	t																								

Table 19: Sescoa Super Speed (Message Type 7) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	7
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6-11	Spaces	Six spaces.
12-15	Account Number	Account number, four digits.
16	Space	One space.
17	I	Event code.
18-19	AA	Two digit zone code or the first two digits user code.
20	C	Space if zone report, or the last digit user code.
21	s	One space.
22	Trailer Character	Typically, this is HEX 14.

### 3.1.18 Scancom 4-16-1, 5-16-1, 6-16-1 - Available Upon Request (Message Type g)

Scancom 4-  
16-1, 5-16-1,  
6-16-1  
Example

D6500 Byte Description																
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
h	g	r	r	l	a	a	a	a	a	a	s	C	C	C	C	s
18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34
C	C	C	C	s	C	C	C	C	C	C	C	C	s	C	t	

Table 20: Scancom 4-16-1, 5-16-1, 6-16-1 - Available Upon Request (Message Type g) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	g
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6-11	Account Number	Account number up to six digits. Account numbers less than six characters are right aligned with leading ASCII spaces.
12	Space	One space.
13-16	CCCC	Channels 1 to 4.
17	Space	One space.
18-21	CCCC	Channels 5 to 8.
22	Space	One space.
23-26	CCCC	Channels 9 to 12.
27	Space	One space.
28-31	CCCC	Channels 13 to 16.
32	Space	One space.
33	C	Supervisory channel.
34	Trailer Character	Typically, this is HEX 14.

### 3.1.19 Scancom 4-24-1, 5-24-1, 6-24-1 - Available Upon Request (Message Type h)

Scancom  
4-24-1  
Example

D6500 Byte Description																					
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
h	h	r	r	l	a	a	a	a	a	a	s	C	C	C	C	s	C	C	C	C	s
23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
C	C	C	C	s	C	C	C	s	C	C	C	C	s	C	C	C	C	s	C	t	

Table 21: Scancom 4-24-1, 5-24-1, 6-24-1 - Available Upon Request (Message Type h) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	h
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6-11	Account Number	Account number up to six digits. Account numbers less than six characters are right aligned with leading ASCII spaces.
12	Space	One space.
13-16	CCCC	Channels 1 to 4.
17	Space	One space.
18-21	CCCC	Channels 5 to 8.
22	Space	One space.
23-26	CCCC	Channels 9 to 12.
27	Space	One space.
28-31	CCCC	Channels 13 to 16.
32	Space	One space.
33-36	CCCC	Channels 17 to 20.
37	Space	One space.
38-41	CCCC	Channels 21 to 24.
42	Space	One space.
43	C	Supervisory channel.
44	Trailer Character	Typically, this is HEX 14.

### 3.1.20 Seriee FSK (Message Type k)

Seriee FSK  
Example

D6500 Byte Description																						
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
	h	k	r	r	l	s	s	s	s	s	a	a	a	a	a	s	E	s	Z	Z	t	

Table 22: Seriee FSK (Message Type k) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	k
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6-11	Spaces	Six spaces.
12-16	Account Number	Five digit account number.
17	Space	One space.
18	E	Event code.
19	Space	One space.
20 -21	ZZ	Zone number.
22	Trailer Character	Typically, HEX 14.

### 3.1.21 Seriee DTMF (Message Type l)

Seriee DTMF Example	D6500 Byte Description																					
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
	h	l	r	r	l	L	L	*	a	a	a	a	a	a	*	...					t	

Table 23: Seriee DTMF (Message Type l) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	1 (lowercase L).
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6-7	LL	Data length.
8	*	Data separator.
9-14	Account number	Four, five or six account numbers.
15	*	Data separator.
16-21	***	DTMF Seriee Data.
22	Trailer Character	Typically, HEX 14.

### 3.1.22 SIA (Message Type S)

SIA Example	D6500 Byte Description																					
Defined Messages	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
	h	S	r	r	l	[	#	a	a	a	a		E	M	M	Z	Z	Z	/	***]	t	

Table 24: SIA (Message Type S) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	S
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6	[	Open bracket.
7	#	#
8-11	Account Number	Up to sixteen digits may be used in the account number.
12		Separator, indicates more data positions after account number.
13	E	SIA block code.
14-15	Event Code	SIA Event code.
16-19	Zone	Zone number.
20	/	Separator.
21	***]	Next block of data.
22	Trailer Character	Typically, HEX 14.

#### Undefined Messages

When an SIA message contains unprintable characters (unprintable characters are out of ASCII range 0x32-0x7E) or without an account block:

SIA Example	D6500 Byte Description																					
	1	2	3	4	5	6	7	.	.	N-1	N											
	h	S	r	r	L	[	data		]		t											

**Table 25: SIA (Message Type S) Byte Description**

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	S
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6	[	Open bracket.
7-(N-2)	data	The received SIA message contains hex characters either with or without account portion.
N	Trailer Character	Typically, HEX 14.

**3.1.23 Silent Knight FSK0 (Message Type 1)**

Silent Knight FSK0 Example	D6500 Byte Description																					
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
	h	1	r	r	l	s	s	s	s	s	s	a	a	a	a	s	E	s	s	s	Z	t

**Table 26: Silent Knight FSK1 (Message Type m) Byte Description**

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	1
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6-11	Spaces	Six spaces.
12-15	Account Number	Four digit account number.
16	Spaces	One space.
17	E	Event code.
18-20	Space	Three spaces.
21	Zone number	Zone number.
22	Trailer Character	Typically, HEX 14.

**Optional Silent Knight SK1 (Message Type m):**

If the receiver is equal to 1, the following output is used.

Silent Knight  
FSK1  
Example

D6500 Byte Description																					
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
h	m	r	r	l	s	a	a	a	a	a	a	a	a	"	Z	Z	"	...	t		

**Table 27: Optional Silent Knight SK1 (Message Type m) Byte Description**

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	m
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6	Spaces	One space.
7-14	Account Number	Maximum eight-digit account code. If the account code is less than eight digits, enter the actual number of digits without a leading space.
15	"	Separator.
16-17	ZZ	First zone number, up to eight reports, one report has two digits.
18	"	Separator.
19	***	More data.
21	Trailer Character	Typically, HEX 14.

<b>Table 28: Silent Knight Automation Format</b>				
Report Code	Description	To Automation		Note
		2 5 16=0(EEZZ)	2 5 16=1(ZZ)	
00:	Alarm Panic	PAss	00	
01 to 08:	Alarm 01 to 08	sA0x	01 to 08	x=1 to 8
09:	Holdup	Hass	09	
10 to 19:	Alarm 10 to 19	sA1x	10 to 19	x=0 to 9
20 to 29:	Alarm Restore 10 to 19	sH1x	20 to 29	x=0 to 9
30:	Test Code	sXss	30	
31:	Trouble Line 1	LT01	31	
32:	Trouble Line 2	LT02	32	
33:	Expand Trouble	ETss	33	
34:	Forced Access	DFss	34	
35:	Restore Line 1	LR01	35	
36:	Restore Line 2	LR02	36	
37:	Expand Restore	ERss	37	
38:	Cancel Code	OCss	38	
39:	Data Lost	RTss	39	
40:	Closing	CL00	40	
41 to 49:	Closing 01 to 09	CL0x	41 to 49	x=1 to 9
50 to 59:	Bypass 10 to 19	sB1x	50 to 59	x=0 to 9
60:	Trouble AC	ATss	60	
61 to 68:	Trouble 01 to 08	sT0x	61 to 68	x=1 to 8
69:	Trouble BAT	YTss	69	
70:	Restore AC	ARss	70	
71 to 78:	Restore 01 to 08	sRss	71 to 78	
79:	Restore BAT	YRss	79	
80:	Access	DS00	80	
81 to 89:	Access 01 to 09	DG0x	80 to 89	x=1 to 9
90:	Opening	OP00	90	
91 to 99:	Opening 01 to 09	OP0x	91 to 99	

### 3.1.24 Silent Knight FSK1 (Message Type m)

Silent Knight FSK1 Example	D6500 Byte Description																																										
	<table> <tr> <td>1</td><td>2</td><td>3</td><td>4</td><td>5</td><td>6</td><td>7</td><td>8</td><td>9</td><td>10</td><td>11</td><td>12</td><td>13</td><td>14</td><td>15</td><td>16</td><td>17</td><td>18</td><td>19</td><td>21- 28</td><td>29</td></tr> <tr> <td>h</td><td>m</td><td>r</td><td>r</td><td>l</td><td>s</td><td>a</td><td>a</td><td>a</td><td>a</td><td>a</td><td>a</td><td>a</td><td>a</td><td>"</td><td>E</td><td>E</td><td>Z</td><td>Z</td><td>...</td><td>t</td></tr> </table>	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	21- 28	29	h	m	r	r	l	s	a	a	a	a	a	a	a	a	"	E	E	Z	Z	...	t
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	21- 28	29																							
h	m	r	r	l	s	a	a	a	a	a	a	a	a	"	E	E	Z	Z	...	t																							

Table 29: Silent Knight FSK1 (Message Type m) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	m
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6	Spaces	One space.
7-14	Account Number	Maximum 8-digit account code. If the account code is less than 8 digits, enter the actual number of digits without a leading space.
15	"	Separator.
16-19	EEZZ	First event and zone number. If this is the only event, it will be ended with the terminator. Up to 8 reports. One report has 4 digits: 1-digit event code, 1-digit condition code, 2-digit zone code.
20	"	Separator.
21 - 28	***	Next data.
28	Trailer Character	Typically, HEX 14.

**Optional Silent Knight SK1 (Message Type m):**

	If the receiver is equal to 1, the following output is used.
-----------------------------------------------------------------------------------	--------------------------------------------------------------

Silent Knight FSK1 Example	D6500 Byte Description	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	21
		h	m	r	r	l	s	a	a	a	a	a	a	a	a	"	Z	Z	"	...	t

**Table 30: Optional Silent Knight SK1 (Message Type m) Byte Description**

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	m
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6	Spaces	One space.
7-14	Account Number	Maximum eight-digit account code. If the account code is less than eight digits, enter the actual number of digits without a leading space.
15	"	Separator.
16-17	ZZ	First zone number, up to eight reports, one report has two digits.
18	"	Separator.
19	***	More data.
21	Trailer Character	Typically, HEX 14.

**Table 31: Silent Knight Automation Format**

Report Code	Description	To Automation		Note
		2 5 16=0(EEZZ)	2 5 16=1(ZZ)	
00:	Alarm Panic	PAss	00	
01 to 08:	Alarm 01 to 08	sA0x	01 to 08	x=1 to 8
09:	Holdup	Hass	09	
10 to 19:	Alarm 10 to 19	sA1x	10 to 19	x=0 to 9
20 to 29:	Alarm Restore 10 to 19	sH1x	20 to 29	x=0 to 9
30:	Test Code	sXss	30	
31:	Trouble Line 1	LT01	31	
32:	Trouble Line 2	LT02	32	
33:	Expand Trouble	ETss	33	
34:	Forced Access	DFss	34	
35:	Restore Line 1	LR01	35	
36:	Restore Line 2	LR02	36	
37:	Expand Restore	ERss	37	
38:	Cancel Code	OCss	38	
39:	Data Lost	RTss	39	
40:	Closing	CL00	40	
41 to 49:	Closing 01 to 09	CL0x	41 to 49	x=1 to 9
50 to 59:	Bypass 10 to 19	sB1x	50 to 59	x=0 to 9
60:	Trouble AC	ATss	60	
61 to 68:	Trouble 01 to 08	sT0x	61 to 68	x=1 to 8
69:	Trouble BAT	YTss	69	
70:	Restore AC	ARss	70	
71 to 78:	Restore 01 to 08	sRss	71 to 78	
79:	Restore BAT	YRss	79	
80:	Access	DS00	80	
81 to 89:	Access 01 to 09	DG0x	80 to 89	x=1 to 9
90:	Opening	OP00	90	
91 to 99:	Opening 01 to 09	OP0x	91 to 99	

### 3.1.25 Silent Knight FSK2 (Message Type m)

Silent Knight FSK2 Example	D6500 Byte Description																																												
	<table> <tr> <td>1</td><td>2</td><td>3</td><td>4</td><td>5</td><td>6</td><td>7</td><td>8</td><td>9</td><td>10</td><td>11</td><td>12</td><td>13</td><td>14</td><td>15</td><td>16</td><td>17</td><td>18</td><td>19</td><td>20</td><td>21</td><td>22</td></tr> <tr> <td>h</td><td>m</td><td>r</td><td>r</td><td>l</td><td>s</td><td>a</td><td>a</td><td>a</td><td>a</td><td>a</td><td>a</td><td>a</td><td>a</td><td>"</td><td>E</td><td>E</td><td>Z</td><td>Z</td><td>"</td><td>***</td><td>t</td></tr> </table>	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	h	m	r	r	l	s	a	a	a	a	a	a	a	a	"	E	E	Z	Z	"	***	t
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22																								
h	m	r	r	l	s	a	a	a	a	a	a	a	a	"	E	E	Z	Z	"	***	t																								

Table 32: Silent Knight FSK2 (Message Type m) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	m
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6	Spaces	One space.
7-14	Account Number	Maximum eight-digit account code. If the account code is less than eight digits, enter the actual number of digits without a leading space.
15	"	Separator.
16-19	EEZZ	First event and zone number. If this is the only event, it will be ended with the terminator. Up to eight reports. One report has four digits: one-digit event code, one-digit condition code, two-digit zone code.
20	"	Separator.
21	***	Next data.
22	Trailer Character	Typically, HEX 14.

### 3.1.26 Silent Knight FSK80 D6500 mode (Message Type 1)

Silent Knight FSK80 Example	D6500 Byte Description																					
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
	h	1	r	r	l	s	s	s	s	s	s	A	A	A	A	s	A	s	s	X	Y	t

Table 33: Silent Knight FSK80 (Message Type 1) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	1
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6-11	Spaces	
12-15	Account Number	Four-digit account number.
16	Space	
17	Filler character A	Always char "A".
18-19	Spaces	
20-21	XY	Two-digit alarm zone code.
24	Trailer Character	Typically, HEX 14.

### 3.1.27 Telim (Message Type n)

Telim  
Example

D6500 Byte Description																
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
h	n	R	R	L	s	A	A	A	A	A	A	s	E	T	T	Z
18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	
Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	t	Z	

Table 34: Telim (Message Type n) Byte Description

#	Title	Description
1	Header Character (n)	Optional. Check with the computer automation software for compatibility.
2	Message Type	n
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6	Space	One space.
7-12	Account Number	Six digit account number.
13	Space	One space.
14	E	Event code.
15-32	TTZZZZZZZZZZ ZZ	Input line number.
33	Trailer Character	Typically, HEX 14.

### 3.1.28 Text Message (Message Type 3)

Type 3  
Example

D6500 Byte Description																						
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
	h	3	r	r	l	P	R	I	N	T	E	R			v	v	.	v	v	t		

Table 35: Text Message (Message Type 3) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	3
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line Number	Line number fixed at 1.
6-21	Message Text	Sixteen characters in length.
22	Trailer Character	Typically, HEX 14.

### 3.1.29 Varitech FSK 4-1 (Message Type 1)

Varitech FSK 4-1 Example	D6500 Byte Description																					
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
	h	1	r	r	l	s	s	s	s	s	s	a	a	a	a	s	E	s	s	s	X	t

Table 36: Varitech FSK 4-1 (Message Type 1) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	1
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6-11	Spaces	Six spaces.
12-15	Account Number	Four digit account number.
16	Space	One space.
17	E	Event code.
18-20	Spaces	Three spaces.
21	X	Zone number.
22	Trailer Character	Typically, HEX 14.

### 3.1.30 Varitech FSK 4-2 (Message Type 1)

Varitech FSK 4-2 Example	D6500 Byte Description																					
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
	h	1	r	r	l	s	s	s	s	s	s	a	a	a	a	s	E	s	s	X	Y	t

Table 37: Varitech FSK 4-2 (Message Type 1) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	1
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6-11	Spaces	Six spaces.
12-15	Account Number	Four digit account number.
16	Space	One space.
17	E	Event code.
18-19	Spaces	Two spaces.
20-21	XY	Zone number.
22	Trailer Character	Typically, HEX 14.

### 3.1.31 VONK (Message Type V)

VONK Example	D6500 Byte Description																																																
	<table border="1"> <tr> <td>1</td><td>2</td><td>3</td><td>4</td><td>5</td><td>6</td><td>7</td><td>8</td><td>9</td><td>10</td><td>11</td><td>12</td><td>13</td><td>14</td><td>15</td><td>16</td><td>17</td><td>18</td><td>19</td><td>20</td><td>21</td><td>22</td><td>23</td><td>24</td></tr> <tr> <td>h</td><td>V</td><td>r</td><td>r</td><td>l</td><td>A</td><td>A</td><td>1</td><td>2</td><td>3</td><td>4</td><td>5</td><td>6</td><td>7</td><td>8</td><td>9</td><td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td>G</td><td>t</td></tr> </table>	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	h	V	r	r	l	A	A	1	2	3	4	5	6	7	8	9	A	B	C	D	E	F	G	t
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24																										
h	V	r	r	l	A	A	1	2	3	4	5	6	7	8	9	A	B	C	D	E	F	G	t																										

Table 38: VONK (Message Type V) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	V
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6-7	Account Number	Two digit account number.
8-23	Zone status	Status of zones 1 to 16. If the zone is Closed, a “.”(period) is in this position. If the zone is Open, 1 to G appears in this position.
24	Trailer Character	Typically, HEX 14

### 3.1.32 X-SIA Text (Message Type S)

X-SIA  
Example

D6500 Byte Description																					
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
h	S	r	r	l	[	#	a	a	a	a		E	M	M	Z	Z	Z	*	'	T	
23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42		
T	T	T	T	T	T	T	T	T	T	T	T	'	N	M	/	*	*	*	t		

Table 39: X-SIA Text (Message Type S) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	S
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line/Group Number	Line number in the receiver gateway that sent the message.
6	[	Open bracket.
7	#	#
8-11	Account Number	Use up to sixteen digits in the account number.
12		Separator. Indicates more data positions after account number.
13	E	SIA block code.
14-15	MM	SIA event code.
16-19	ZZZZ	Zone number.
20	*	Text identifier.
21	'	Quotation mark (single).
22-34	TT...T	13 character text string.
35	'	Quotation mark (single).
36-37	NM	Unit field characters.
38	/	Separator.
39-41	***	Next block of data.
42	Trailer Character	Typically, HEX 14.

### 3.1.33 SafeCom (Message Type p)

SafeCom  
Example

D6500 Byte Description																
1	2	3	4	5	6	7	8	9	10	11	12	13	14	...	N1	N
h	p	r	r	l	A	A	A	A	E	E	E	E	...data...		t	

Table 40: SafeCom (Message Type p) Byte Description

#	Title	Description
1	Header Character (h)	Optional. Check with the computer automation software for compatibility.
2	Message Type	p
3-4	Receiver Number	Receiver gateway number from 01 to 99.
5	Line Card Number	Line number in the receiver gateway that sent the message.
6-9	Account Number	Four digits.
10-13	Event Code	Four digits.
14-(N-1)	Data	Parameter data for event code.
N	Trailer Character	Typically, HEX 14.

### 3.2 SIA Mode Messages

Use the SIA mode for central station monitoring.

#### 3.2.1 Acron Super Fast (Message Type 9)

Acron Super Fast Example	SIA Mode Description <LF><CRC><LEN><9><sequence#><receiver#><line#>[#aaaa CCCCCCCC]<CR>
-----------------------------	--------------------------------------------------------------------------------------------

**Table 41: Acron Super Fast (Message Type 9) Byte Description**

Title	Description
L	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
Message Type	9
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits are 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits are 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account#	The communicator's account number has four digits.

**Figure 1: Message sent to printer**

```
mm/ddshh:mmsLxxsACNsACCTsaaaa
+++sACCTsaaaasCCCsCCCC
```

 For lines that are grouped, Gxx appears instead of Lxx.

**Table 42: Acron Super Fast (Message Type 9) Printer Output**

Characters	Description
ACN	Acron Super Fast format.
Lxx	Line number.
Gxx	Grouped line numbers.

### 3.2.2 Ademco Contact-ID (Message Type a)

Contact-ID Example	SIA Mode Description
	<LF><CRC><LEN><a><sequence#><receiver#><line#>[#aaaa 18QXYZGGCCC]<CR>

Table 43: Ademco Contact-ID (Message Type a) Byte Description

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
Message Type	a
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits are 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits are 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account#	The communicator's account number has four digits.
18	Ademco Contact-ID format number.
Q	Qualifier, 1 = New event or opening, 3 = New restore or closing, 6 = Previous event.
XYZ	Class code and event code (refer to Appendix A: Contact ID Event Code Classifications).
GG	Group number.
CCC	Zone codes or User ID.

Figure 2: Message sent to printer

```
mm/ddshh:mmssLxxsCIDsACCTsaaaa
+++sACCTsaaaasNNNsEVENT=XYZsG=GGsC=CCC
```



For lines that are grouped, Gxx appears instead of Lxx.

Table 44: Ademco Contact-ID (Message Type a) Printer Output

Characters	Description
CID	Contact-ID format.
Gxx	Grouped Line numbers.
Lxx	Line number.
NNN	If Q = 1, print E/O for new event or opening If Q = 3, print R/C for restore or closing If Q = 6, print "OLD" for old messages and events.

### 3.2.3 Ademco 10-Digit (Message Type b)

10-Digit	SIA Mode Description
----------	----------------------

Example	<LF><CRC><LEN><a><sequence#><receiver#><line#>[#aaaaaaaa 58QXYZGGCCC]<CR>
---------	---------------------------------------------------------------------------

**Table 45: Ademco 10-Digit (Message Type b) Byte Description**

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
a	Message Type a Ademco Contact-ID.
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits are 01 to 99.
line#	The line number of the line in the Receiver/Gateway that sent the message. Valid digits are: 00- 99. Line#0 is used for receiver messages.
account#	The communicator's account number.
58	Ademco Contact-ID format number for 10 digits account.
Q	Qualifier, 1=New event or opening, 3=New restore or closing, 6=Previous event
XYZ	Class code and event code (refer to Appendix A: Contact ID Event Code Classifications)
GG	Group number
CCC	Zone codes or user ID

**Figure 3: Message sent to printer**

mm/ddhh:mmssLxxsCIDsACCTaaaaaaaa
+++sNNNsEVENT=XYZsG=GGsC=CCC

<input checked="" type="checkbox"/>	For lines that are grouped, Gxx appears instead of Lxx.
-------------------------------------	---------------------------------------------------------

**Table 46: Ademco Contact-ID (Message Type a) Printer Output**

Characters	Description
CID	Contact-ID format.
Gxx	Grouped Line numbers.
Lxx	Line number.
NNN	If Q = 1, print E/O for new event or opening If Q = 3, print R/C for restore or closing If Q = 6, print "OLD" for old messages and events.

### 3.2.4 Ademco 4-1 Express (Message Type b)

4-1 Express Example	SIA Mode Description
	<LF><CRC><LEN><b><sequence#><receiver#><line#>[#aaaa X]<CR>

**Table 47: Ademco 4-1 Express (Message Type b) Byte Description**

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
Message Type	b
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits are 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits are 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account#	The communicator's account number has four digits.
X	Zone number

**Figure 4: Message sent to printer**

```
mm/ddhh:mmssLxxsE41sACCTsaaaasEVENT=X
```



For lines that are grouped, Gxx appears instead of Lxx.

**Table 48: Ademco 4-1 Express (Message Type b) Printer Output**

Characters	Description
E41	Ademco 4-1 Express format.
Lxx:	Line number.
Gxx	Grouped line numbers.

### 3.2.5 Ademco 4-2 Express (Message Type c)

4-2 Express Example	SIA Mode Description <LF><CRC><LEN><c><sequence#><receiver#><line#>[#aaaa XY]<CR>
---------------------	--------------------------------------------------------------------------------------

Table 49: Ademco 4-2 Express (Message Type c) Byte Description

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
Message Type	c
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits are 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits are 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account#	The communicator's account number has four digits.
XY	Event code and Zone number.

Figure 5: Message sent to printer

mm/ddhh:mmssLxxsE42sACCTsaaaasEVENT=XY



For lines that are grouped, Gxx appears instead of Lxx.

Table 50: Ademco 4-2 Express (Message Type c) Printer Output

Characters	Description
E42	Ademco 4-2 Express format.
Lxx:	Line number.
Gxx	Grouped line numbers.

### 3.2.6 Ademco High Speed 4-8-1, SCANCOM 4-8-1 (Message Type f)

 SCANCOM 5-8-1, 6-8-1 - available upon request	
High Speed Example	SIA Mode Description <LF><CRC><LEN><f><sequence#><receiver#><line#>[#aaaaaa CCCCsCCCCsC]<CR>

Table 51: Ademco High Speed 4-8-1, SCANCOM 4-8-1 (Message Type F) Byte Description

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
Message Type	f
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits are 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits are 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account#	The communicator's account number has up to six digits.
CCCC	Channels 1 to 4.
s	One space.
CCCC	Channels 5 to 8.
s	One space.
C	Supervisory channel.

Figure 6: Message sent to printer

```
mm/ddshh:mmssLxxsGHGsACCTsaaaaaaaa
+++$ACCTsaaaaaaaaasCCCCsCCCCsC
```

 For lines that are grouped, Gxx appears instead of Lxx.
---------------------------------------------------------------------------------------------------------------------------------------------

Table 52: Ademco High Speed, 4-8-1 (Message Type f) Printer Output

Characters	Description
HGH	Ademco High Speed format.
Lxx:	Line number.
Gxx	Grouped line numbers.

## ADT SIA (Message Type S)

ADT SIA  
Example

SIA Mode Description	
<LF><CRC><LEN><S><sequence#><receiver#><line#>[#aaaa]<E><damm-dd-yytihh:mm:ss>data]<CR>	

**Table 53: ADT SIA (Message Type S) Byte Description**

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
Message Type	S (capital S)
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits are 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits are 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account#	The communicator's account number up to sixteen digits.
E	Event Code (refer to Appendix G: ADT SIA Report Codes).
damm-dd-yytihh:mm:ss	Date and time.
Data	This field contains message data codes such as event type, area number, point number, identification number.

### 3.2.7 Caller ID (Message Type <TAB>)

SIA Example

SIA Mode Description

&lt;LF&gt;&lt;CRC&gt;&lt;LEN&gt;&lt;TAB&gt;&lt;sequence#&gt;&lt;receiver#&gt;&lt;line#&gt;[#0000]&amp;TTTTTTTTTTTTTTT&lt;CR&gt;

**Table 54: Caller ID (Message Type <TAB>) Byte Description**

Title	Description
LF	Standard line feed character.
CRC	Cyclical Redundancy Check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted). For example, <LF>D9381C<TAB>12220100[#0001 Npt003YC009]<CR>. Counting from the <TAB> character through the last square bracket, there are 28 characters, 0x1C in hexadecimal.
Message Type	<TAB>
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits are 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits are 00 to 99. The receiver uses Line 0 (zero) for internal messages.
&	Origin ID Block.
T	Up to 16-digit Caller ID.

**Figure 7: Message sent to Printer**

30/04 17:00 L01 CLI 9563832510

### 3.2.8 CFSK (Message Type i)

CFSK Example

SIA Mode Description

&lt;LF&gt;&lt;CRC&gt;&lt;LEN&gt;&lt;i&gt;&lt;sequence#&gt;&lt;Receiver#&gt;&lt;line#&gt;[#aaaaaa|TTEE]&lt;CR&gt;

**Table 55: CFSK (Message Type i) Byte Description**

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
Message Type	i.
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits are 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits are 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account #	The communicator's account number, up to six digits.
TT	Event code.
EE	Zone/User ID.

### 3.2.9 Common Formats (Message Type <TAB>)

Defined Messages SIA Example	SIA Mode Description <LF><CRC><LEN><TAB><sequence#><receiver#><line#>[#aaaaaaaaaaaaaaa data]<CR>
------------------------------------	-----------------------------------------------------------------------------------------------------

**Table 56: Common Formats (Message Type <TAB>) Byte Description**

Title	Description
LF	Standard line feed character.
CRC	Cyclical Redundancy Check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted). For example, <LF>D9381C<TAB>12220100[#0001 Npt003YC009]<CR>. Counting from the <TAB> character through the last square bracket, there are 28 characters, 0x1C in hexadecimal.
Message Type	09 hex <TAB>
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits are 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits are 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account#	The communicator's account number up to sixteen digits.
Data	This field contains message data codes such as event type, area number, point number, identification number, and so on.

The receiver gateway sends the 3-1, 4-1, 4-2, single round, double round, extended pulse formats, BFSK, Modem II or Modem IId messages in either D6500 Mode or SIA Mode, depending on the program option selected. The receiver gateway also sends internal and ModemIIIa<sup>2</sup> messages in either D6500 mode or SIA mode, depending on the programmable option selected. Refer to Appendix B: Internal Messages and Appendix C: Modem4/ModemIIIa<sup>2</sup> for a list of the messages and their descriptions.

**Figure 8: Message sent to printer**

```
MM/DDsHH:MMsLxxSIA ACCT aaaa
+++ TEXT 1
+++ TEXT 2
```

## Undefined Messages

When a common format message contains unprintable hexadecimal characters (unprintable characters are out of ASCII range 0x32-0x7E) or without an account block:

SIA Example	SIA Mode Description
	<LF><CRC><LEN><TAB><sequence#><receiver#><line#>[data]<CR>

**Table 57: Common Formats (Message Type <TAB>) Byte Description**

Title	Description
LF	Standard line feed character.
CRC	Cyclical Redundancy Check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted). For example, <LF>D9381C<TAB>12220100[#001 Npt003YC009]<CR>. Counting from the <TAB> character through the last square bracket, there are 28 characters, 0x1C in hexadecimal.
Message Type	09 hex.
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits are 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits are 00 to 99. The receiver uses Line 0 (zero) for receiver gateway messages.
Data	The receiver message contains hex characters either with or without account portion.

**Figure 9: Message sent to printer**

```
MM/DDsHH:MMsLxx[SIA]
+++ TEXT 1
+++ TEXT 2
```

### 3.2.10 DNIS/ANI (Message Type N)

SIA Example	SIA Mode Description
	<LF><CRC><LEN><N><sequence#><receiver#><line#>[#0000 Dddddddddd&aaaaaaaa]<CR>

**Table 58: DNIS/ANI (Message Type N) Byte Description**

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
Message Type	N
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits are 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits are 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account#	Fixed at 0000.
D	DNIS identified.
DNIS number (d)	DNIS number, up to 11 digits.
ANI identifier (&)	ANI identifier.
ANI number (a)	ANI number, up to 11 digit.s

**Figure 10: Message sent to printer**

```
MM/DDsHH:MMsLxxsDNISssssssssss  
++sANIsaaaaaaaaaa
```

DSC 4-3 (Message Type d)

DSC4-3  
Example

## SIA Mode Description

&lt;LF&gt;&lt;CRC&gt;&lt;LEN&gt;&lt;d&gt;&lt;sequence#&gt;&lt;receiver#&gt;&lt;line#&gt;[#aaaa|XYY]&lt;CR&gt;

**Table 59: DSC 4-3 (Message Type d) Byte Description**

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
Message Type	d
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits are 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits are 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account#	The communicator's account number has four digits.
X	Event code number.
YY	Zone number.

**Figure 11: Message sent to printer**

```
mm/ddshh:mmsLxxsDSGsACCTaaaasEVENT=XYY
+++$ACC$aaaa$eeeeeee$ii$nnn
```



For lines that are grouped, Gxx appears instead of Lxx.

**Table 60: DSC 4-3 (Message Type d) Printer Output**

Characters	Description
DSG	DSC/Sur-Gard 4-3 format.
Lxx:	Line number.
Gxx	Grouped line numbers.

**Table 61: Printer Output Codes**

Character s	Description
ii	ZN=Zone number - ID=User ID
nnn	Zone/User number.
eeeeeeee	Up to eight-character event type, right justified – ALARM, RESTORE, TROUBLE, OPEN, OPENGRP, CLOSE, CLOSEGRP, BYPASS, UN BYPASS, CANCEL.

**Table 62: Event Code Table**

Code Number	Message	Event Characters
1	Alarm	A
2		A
3		A
4	Close	C
5	Open	O
6	Alarm	A
7		A
8		A
9	Restore	R
0	Trouble	T
B	CloseGrp	C
C	OpenGrp	O
D	Bypass	B
E	UnBypass	H
F	Cancel	O

### 3.2.11 FBI Super Fast (Message Type F)

FBI Super Fast Example	SIA Mode Description
	<LF><CRC><LEN><F><sequence#><receiver#><line#>[#aaaa TZZE]<CR>

Table 63: FBI Super Fast (Message Type F) Byte Description

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
Message Type	F
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits are 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits are 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account#	The communicator's account number has four digits.
T	Zone type.
ZZ	Zone number.
E	Event type.

Figure 12: Message sent to printer

```
mm/ddshh:mmsLxxsFBIsACCTsaaaasETsnnn
++sACCTsaaaasttttttseeeeeeesZNsnnn
```



For lines that are grouped, Gxx appears instead of Lxx.

**Table 64: FBI Super Fast (Message Type F) Printer Output**

Characters	Description
FBI	FBI Super Fast format.
Lxx:	Line number.
Gxx	Grouped line numbers.

**Table 65: Event Code Table**

Code	Zone/Event Type
1	Fire
2	Panic
3	Burglary
4	Medical
5	Auxiliary
6	Bypass
7	Inactive
8	Eight
9	Nine
0	Zero
B	Opening
C	Closing
D	Abort
E	Restore
F	Trouble

**Table 66: Printer Output Codes**

Characters	Description
ZN	ZN=Zone number - ID=User ID
nnn	Zone/User number.
tttttttt	Up to nine-character zone type, right justified FIRE, PANIC, BURGLARY, MEDICAL, AUXILIARY.
eeeeeeee	Up to eight-character event type, left justified ALARM, RESTORE, TROUBLE, OPEN, OPENGRP, CLOSE, CLOSEGRP, BYPASS, UN BYPASS, CANCEL.

### 3.2.12 ITI (Message Type I)

ITI Example	SIA Mode Description
	<LF><CRC><LEN><I><sequence#><receiver#><line#>[#aaaaa GIZZEWN]<CR>

Table 67: ITI (Message Type I) Byte Description

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
Message Type	I (Captial I).
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits are 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits are 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account#	The communicator's account number has up to six digits.
G	Group number.
I	O/C User ID.
ZZ	Zone number.
E	Condition code.
W	Protection level was.
N	Protection level now.

### 3.2.13 Link Test (Message Type <TAB>)

Link Test Example	SIA Mode Description
	<LF><CRC><LEN><TAB><sequence#><receiver#> []<CR>

The receiver automatically generates this message at the preprogrammed intervals.

**Table 68: Link Test (Message Type <TAB>) Description**

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted). For example, <LF>D9381C<TAB>12220100[#0001 Npt003YC009]<CR>. Counting from the <TAB> character through the last square bracket, there are 28 characters, 0x1C in hexadecimal.
Message Type	<TAB>
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits are 01 to 99.

### 3.2.14 RB2000 (Message Type R) Description

RB2000 Example	SIA Mode Description <LF><CRC><LEN><R><sequence#><receiver#><line#>[<VDS message>]<CR>
----------------	-------------------------------------------------------------------------------------------

**Table 69: RB2000 (Message Type R) Byte Description**

Title	Description
LF	Standard line feed character, hex 0A.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
R	ASCII R, Message Type R for RB2000 format.
sequence#	The message sequence number. The valid sequence number range: 0001 to 9999.
Receiver#	The receiver gateway that sent the message. Valid digits: 01 to 99.
line#	The line number of the line in the receiver gateway that sent the message. Valid digits: 00 to 99. The receiver uses Line 0 (zero) for internal messages.
<VDS message>	VDS message sent as a hex string, the receiver extracts the alarm type.
CR	Hex 0D

**Figure 13: Single message sent to Printer**

```
MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx
+++ RB2000_EVENT_RAW_DATA
```

**Figure 14: Multiple messages sent to printer**

```
MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx
+++ RB2000_EVENT_RAW_DATA 1
+++ RB2000_EVENT_RAW_DATA 2
...
+++ RB2000_EVENT_RAW_DATA n
```

**Table 70: RB2000 (Message Type R) Printer Output**

Characters	Description
MM/DDsHH:MM	Date and time.
RB2	RB2000 format.
Lxx	Line number.
ACCT xxxxxxxxxxxx	Subscriber number, up to 12 characters(hex).
RB2000_EVENT_R AW_DATA	The raw data of RB2000 event.
RB2000_EVENT_R AW_DATA1	The raw data of RB2000 event 1.
RB2000_EVENT_R AW_DATA 2	The raw data of RB2000 event 2.
RB2000_EVENT_R AW_DATA n	The raw data of RB2000 event n.

**3.2.15 Robofon (Message Type j)**

Robofon Example	SIA Mode Description
	<LF><CRC><LEN><j><sequence#><receiver#><line#>[#aaaaaa EE]<CR>

**Table 71: Robofon (Message Type j) Byte Description**

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
Message Type	j
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits are 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits are 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account #	The communicator's account number has up to six digits.
EE	Event code.

### 3.2.16 Scancom 4-16-1, 5-16-1, 6-16-1 - Available Upon Request (Message Type g)

4-16-1 Example	<b>SIA Mode Description</b> <pre>&lt;LF&gt;&lt;CRC&gt;&lt;LEN&gt;&lt;g&gt;&lt;sequence#&gt;&lt;receiver#&gt;&lt;line#&gt; [#aaaaaa CCCCsCCCCsCCCCsCCCCsC]&lt;CR&gt;</pre>
-------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Table 72: Scancom 4-16-1, 5-16-1, 6-16-1 - Available Upon Request (Message Type g) Byte Description**

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
Message Type	g
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits are 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits are 00 to 99. The receiver uses Line 0 (zero) for internal messages.
Account#	The communicator's account number has up to six digits.
CCCC	Channels 1 to 4.
s	One space.
CCCC	Channels 5 to 8.
s	One space.
CCCC	Channels 9 to 12.
s	One space.
CCCC	Channels 13 to 16.
s	One space.
C	Supervisory channel.

**Figure 15: Message sent to printer**

```
mm/ddshh:mmssLxxsSCNsACCTaaaaaaaa
+++sACCTaaaaaaaaasCCCCsCCCCsCCCCsCCCCsC
```



For lines that are grouped, Gxx appears instead of Lxx.

**Table 73: Scancom 4-16-1, 5-16-1, 6-16-1 - Available Upon Request (Message Type g) Printer Output**

Characters	Description
SCN	Scancom.
Lxx:	Line number.
Gxx	Grouped line numbers.

**3.2.17 Scancom 4-24-1, 5-24-1, 6-24-1 - Available Upon Request (Message Type h)**

4-24-1 Example	SIA Mode Description
	<LF><CRC><LEN><h><sequence#><receiver#><line#>[#aaaaaa CCCCsCCCCs CCCCs CCCCsCCCCsCCCCsC]<CR>

**Table 74: Scancom 4-24-1, 5-24-1, 6-24-1 - Available Upon Request (Message Type h) Byte Description**

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
Message Type	h
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits are 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits are 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account#	The communicator's account number, up to six digits.
CCCC	Channels 1 to 4.
s	One space.
CCCC	Channels 5 to 8.
s	One space.
CCCC	Channels 9 to 12.
s	One space.
CCCC	Channels 13 to 16.
s	One space.
CCCC	Channels 17 to 20.
s	One space.
CCCC	Channels 21 to 24.
s	One space.
C	Supervisory channel.

**Figure 16: Message sent to printer**

```
mm/ddhh:mmssLxxsSCNsACCTsaaaaaa
+++sACCTsaaaasCCCCsCCCCsCCCCsCCCC
+++++++=CCCCsCCCCsC
```



For lines that are grouped, Gxx appears instead of Lxx.

**Table 75: Scancom 4-24-1, 5-24-1, 6-24-1 - Available Upon Request (Message Type h) Printer Output**

Characters	Description
SCN	Scancom.
Lxx:	Line number.
Gxx	Grouped line numbers.

### 3.2.18 Seriee DTMF (Message Type l)

Seriee DTMF Example	SIA Mode Description
	<LF><CRC><LEN><l><sequence#><receiver#><line#>[#aaaa]*data]<CR>

**Table 76: Seriee DTMF (Message Type l) Byte Description**

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
Message Type	l (lowercase L).
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits are 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits are 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account #	The communicator's account number has four digits.
*	Data separator.
Data	DTMF Seriee Data.

### 3.2.19 Seriee FSK (Message Type k)

Seriee FSK Example	SIA Mode Description <LF><CRC><LEN><k><sequence#><receiver#><line#>[#aaaaa ZZ]<CR>
--------------------	---------------------------------------------------------------------------------------

Table 77: Seriee FSK (Message Type k) Byte Description

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
Message Type	k
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits are 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits are 00 to 99. The receiver uses Line 0 (zero) for internal messages.
Account #	The communicator's account number has up to six digits.
E	Event code.
ZZ	Zone number.

### 3.2.20 Sescoa Super Speed (Message Type 7)

Sescoa Super  
Speed  
Example

SIA Mode Description	
<LF><CRC><LEN><7><sequence#><receiver#><line#>[#aaaa  IAAC]<CR>	

**Table 78: Sescoa Super Speed (Message Type 7) Byte Description**

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
Message Type	7
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits are 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits are 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account#	The communicator's account number has four digits.
I	Event code.
AA	Two-digit zone code or the first two digits user code.
C	Space if zone report, or the last digit user code.

**Figure 17: Message sent to printer**

mm/ddhh:mmssLxxSESSsACCTaaaa +++sACCTaaaaasEEEeeeeeeeeeeee



For lines that are grouped, Gxx appears instead of Lxx.

**Table 79: Sescoa Super Speed (Message Type 7) Printer Output**

Characters	Description
SES	SESCOA Super Speed format.
Lxx	Line number.
Gxx	Grouped line numbers.
aaaa	Account code.
EEE	SESCOA Super Speed format event.
eeeeeeeeeeee ee	Up to 14-characters of event description.

### 3.2.21 Silent Knight FSK() (Message Type <TAB>)

Silent Knight FSK0 Example	SIA Mode Description <LF><CRC><LEN><TAB><sequence#><receiver#><line#>[#aaaa data]<CR>
-------------------------------	------------------------------------------------------------------------------------------

**Table 80: Silent Knight FSK0 (Message Type <TAB>) Byte Description**

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted). For example, <LF>D9381C<TAB>12220100[#0001 Npt003YC009]<CR>. Counting from the <TAB> character through the last square bracket, there are 28 characters, 0x1C in hexadecimal.
Message Type	<TAB>
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits: 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits: 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account #	The communicator's account number has four digits.
Data	Data.

### 3.2.22 Silent Knight FSK1 (Message Type m)

Silent Knight  
FSK1 Example

SIA Mode Description

```
<LF><CRC><LEN><m><sequence#><receiver#><line#>[#aaaa]  
EEZZ"ECZZ"EEZZ"EEZZ"EEZZ"EEZZ"EEZZ"EEZZ] <CR>
```

**Table 81:** Silent Knight FSK1 (Message Type m) Byte Description

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
Message Type	m
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits: 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits: 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account #	The communicator's account number has four digits.
EEZZ"EEZZ"EEZZ"EEZ Z"EEZZ"EEZZ"EEZZ"E ZZ	Up to eight reports. One report has four digits: one-digit event code, one-digit condition code, and two-digit zone code. The quote ("") is the separation character.

Optional Silent Knight FSK1 (Message Type m)



If the receiver is equal to 1, the following output is used.

Silent Knight  
FSK1 Example

SIA Mode Description

```
<LF><CRC><LEN><m><sequence#><receiver#><line#>[#aaaa]ZZ"ZZ"ZZ"ZZ"ZZ"ZZ"ZZ] <CR>
```

**Table 82:** Optional Silent Knight FSK1 (Message Type m) Byte Description

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
Message Type	m
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits: 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits: 00 to 99. The receiver uses Line 0 (zero) for internal messages.

account #	The communicator's account number has four digits.
ZZ"ZZ"ZZ"ZZ"ZZ"ZZ" ZZ"ZZ	Up to eight reports. One report has two digits. The quote ("") is the separate character.

**Table 83: Silent Knight FSK1 Optional Outputs**

Report Code	Description	To Automation		Note
		2 5 16 = 0(EEZZ)	2 5 16 = 1(ZZ)	
00	Alarm Panic	PAss	00	
01 to 08	Alarm 01 to 08	sA0x	01 to 08	x = 1 to 8
09	Holdup	Hass	09	
10 to 19	Alarm 10 to 19	sA1x	10 to 19	x = 0 to 9
20 to 29	Alarm Restore 10 to 19	sH1x	20 to 29	x = 0 to 9
30	Test Code	sXss	30	
31	Trouble Line 1	LT01	31	
32	Trouble Line 2	LT02	32	
33	Expand Trouble	ETss	33	
34	Forced Access	DFss	34	
35	Restore Line 1	LR01	35	
36	Restore Line 2	LR02	36	
37	Expand Restore	ERss	37	
38	Cancel Code	OCss	38	
39	Data Lost	RTss	39	
40	Closing	CL00	40	
41 to 49	Closing 01 to 09	CL0x	41 to 49	x = 1 to 9
50 to 59	Bypass 10 to 19	sB1x	50 to 59	x = 0 to 9
60	Trouble AC	ATss	60	
61 to 68	Trouble 01 to 08	sT0x	61 to 68	x = 1 to 8
69	Trouble BAT	YTss	69	
70	Restore AC	ARss	70	
71 to 78	Restore 01 to 08	sRss	71 to 78	
79	Restore BAT	YRss	79	
80	Access	DS00	80	
81 to 89	Access 01 to 09	DG0x	80 to 89	x = 1 to 9
90	Opening	OP00	90	
91 to 99	Opening 01 to 09	OP0x	91 to 99	

### 3.2.23 Silent Knight FSK2 (Message Type m)

Silent Knight  
FSK2 Example

SIA Mode Description

```
<LF><CRC><LEN><m><sequence#><receiver#><line#>[#aaaaaa]
EEZZ"ECZZ"EEZZ"EEZZ"EEZZ"EEZZ"EEZZ]<CR>
```

**Table 84: Silent Knight FSK2 (Message Type m) Byte Description**

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
Message Type	m
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits: 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits: 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account #	The communicator's account number has up to six digits.
EEZZ"EEZZ"EEZZ"EEZ Z"EEZZ"EEZZ"EEZZ"E ZZ	Up to eight reports. One report has four digits: one-digit event code, one-digit condition code, and two-digit zone code. The quote ("") is the separation character.

### 3.2.24 Silent Knight FSK80 (Message Type <TAB>)

Silent Knight  
FSK80  
Example

SIA Mode Description

<LF><CRC><LEN><TAB><sequence#><receiver#><line#>[#AAAA|NBAXY]<CR>

**Table 85: Silent Knight FSK80 (Message Type <TAB>) Byte Description**

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).  For example, <LF>D9381C<TAB>12220100[#0001 Npt003YC009]<CR>. Counting from the <TAB> character through the last square bracket, there are 28 characters, 0x1C in hexadecimal.
Message Type	<TAB>
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits: 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits: 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account #	The communicator's account number has four digits.
NBA	Alarm event

**Figure 18: Message sent to printer**

```
MM/DDsHH:MMsLxxsSFKsACCTsAAAA
+++ACCTsAAAAsALARM_ZNs1
+++ACCTsAAAAsALARM_ZNs2
+++ACCTsAAAAsALARM_ZNs3
+++ACCTsAAAAsALARM_ZNs4
+++ACCTsAAAAsALARM_ZNs5
+++ACCTsAAAAsALARM_ZNs7
+++ACCTsAAAAsALARM_ZNs8
+++ACCTsAAAAsALARM_ZNs9
```

**Table 86: Silent Knight FSK80 Printer/LCD output**

Characters	Description
MM/DDsHH:M	Date and time.
M	
SFK	SFSK80 format.
Lxx	Line number.
AAAA	The communicator's account number has four digits.
s	Space.

### 3.2.25 Telim (Message Type n)

Telim Example	SIA Mode Description
	<LF><CRC><LEN><n><sequence#><receiver#><line#>[#aaaaaa EETTZZZZZZZZZZZZZZ]<CR>

**Table 87: Telim (Message Type n) Byte Description**

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
Message Type	n
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits: 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits: 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account #	The communicator's account number has up to six digits.
EETTZZZZZZZZZZZZZZZZ	The event type and input line number.
ZZZ	

### 3.2.26 Varitech FSK 4-1 (Message Type <TAB>)

Varitech FSK 4-1 Example	SIA Mode Description <LF><CRC><LEN><TAB><sequence#><receiver#><line#>[#aaaa data]<CR>
-----------------------------	------------------------------------------------------------------------------------------

**Table 88: Varitech FSK 4-1 (Message Type <TAB>) Byte Description**

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted). For example, <LF>D9381C<TAB>12220100[#0001 Npt003YC009]<CR>. Counting from the <TAB> character through the last square bracket, there are 28 characters, 0x1C in hexadecimal.
Message Type	<TAB>
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits: 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits: 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account#	The communicator's account number has four digits.
data	The event type and 1-digit zone number.

### 3.2.27 Varitech FSK 4-2 (Message Type <TAB>)

Varitech FSK	SIA Mode Description
4-2 Example	<LF><CRC><LEN><TAB><sequence#><receiver#><line#>[#aaaa data]<CR>

**Table 89: Varitech FSK 4-2 (Message Type <TAB>) Byte Description**

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted). For example, <LF>D9381C<TAB>12220100[#0001 Npt003YC009]<CR>. Counting from the <TAB> character through the last square bracket, there are 28 characters, 0x1C in hexadecimal.
Message	<TAB>
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits: 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits: 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account #	The communicator's account number has four digits.
data	The event type and two-digit zone number.

### 3.2.28 VONK (Message Type V)

VONK Example	SIA Mode Description
	<LF><CRC><LEN><V><sequence#><receiver#><line#>[#aa 123456789ABCDEFG]<CR>

**Table 90: VONK (Message Type V) Byte Description**

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
Message Type	V
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits: 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits: 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account #	The communicator's account number has two digits.
Data	Status of zones 1 to 16. If the zone is closed, a “.” (Period) appears in this position. If the zone is open, any digit from 1 to G appears in this position.

### 3.2.29 X-SIA text (Message Type <TAB>)

X-SIA Example	SIA Mode Description
	<LF><CRC><LEN><TAB><sequence#><receiver#><line#>[#aaaa EMMZZZ*TTTTTTTTTTTT'NM/**]<CR>

**Table 91: X-SIA text (Message Type <TAB>) Byte Description**

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted). For example, <LF>D9381C<TAB>12220100[#0001 Npt003YC009]<CR>. Counting from the <TAB> character through the last square bracket, there are 28 characters, 0x1C in hexadecimal.
Message Type	<TAB>
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits: 01 to 99.
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits: 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account #	The communicator's account number has up to 16 digits.
E	SIA block code.
MM	SIA event code.
ZZZZ	Zone number.
*	Text identifier.
'	Single quote.
TT...TTT	13 character text string.
'	Single quote.
NM	Unit field characters.
/	Separator.
***	Next data.

**Figure 19: Message sent to printer**

```
MM/DDsHH:MMsLxxsSIAAsACCTsAAAA
+++sEMMZZZ*TTTTTTTTTTTT'NM
++sEMMZZZ*TTTTTTTTTTTT'NM
```

**Table 92: X-SIA Printer/LCD output**

Characters	Description
MM/DDsHH:MM	Date and time.
Lxx	Line number.
SIA	SIA format.
AAAA	Account code.
E	SIA block code.
MM	SIA event code.
ZZZZ	Zone number.
*	Text identifier.
'	Single quote.
TTT...T	13 character text string.
'	Single quote.
NM	Unit field characters.

### 3.2.30 SafeCom (Message Type p)

SafeCom Example	SIA Mode Description
	<LF><CRC><LEN><p><sequence#><receiver#><line#>[#aaaa EEEEdata]<CR>

**Table 93: SafeCom (Message Type p) Byte Description**

Title	Description
LF	Standard line feed character.
CRC	Cyclical redundancy check number.
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
Message	p
sequence#	The message sequence number. The valid sequence number range is 0001 to 9999.
receiver#	The receiver gateway that sent the message. Valid digits: 01 to 99.
line#	The line number of the line in the receiver gateway that sent the message. Valid digits: 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account #	The communicator's account number has four digits.
EEEE	Event code, four digits.
data	Event code parameter data.

### 3.3 Input Command Processing

Input devices, such as automation systems, send the commands described in Table 94 to the receiver. If the receiver does not recognize a command, it generates a REJECT COMMAND message, prints at connected printers, and sends an ASCII text message to the automation port.

	The CPU programming must be set to 1 to use input commands.
-----------------------------------------------------------------------------------	-------------------------------------------------------------

Table 94: ASCII Text Message to Automation Port

Set Time	<p>The automation system, or other device, sends the command shown below to set the time at the CONETTIX B6800-SR if the CONETTIX B6800-SR is programmed to synchronize the time and date with the automation system.</p> <p>D6650 !Thhmm&lt;CR&gt;  Mode:  SIA &lt;seq&gt;&lt;rec&gt;&lt;line&gt;[CSThhmm]&lt;CR&gt;  Mode: hh - hours (24 hour format)  mm - minutes.</p>
Set Date	<p>The automation system, or other device, sends the command shown below to set the time at the CONETTIX B6800-SR if the CONETTIX B6800-SR is programmed to synchronize the time and date with the automation system.</p> <p>D6650 !Dmmddy&lt;CR&gt;  Mode:  SIA &lt;seq&gt;&lt;rec&gt;&lt;line&gt;[CSDmmddy]&lt;CR&gt;  Mode: mm - month, dd - day, yy - year</p>
Stop Two Way Audio	<p>The automation system, or other device, sends the command shown below to stop a two way audio session on the line specified.</p> <p>D6650 !Kn&lt;CR&gt;  Mode:  SIA &lt;seq&gt;&lt;rec&gt;&lt;line&gt;[CLKnn]&lt;CR&gt;  Mode: nn - line card number, 01-32.</p>
Reject Command	<p>D6650 h3rrlsREJECTsCOMMANDsst  Mode:  SIA &lt;LF&gt;&lt;CRC&gt;&lt;TAB&gt;&lt;sequence#&gt;&lt;receiver#&gt;&lt;line#&gt;[REJECT COMMAND]&lt;CR&gt;  Mode:</p>


Table 95: Input Command Output Messages

	D6500 Mode	SIA Mode	Printer Output
Set Time	h1rrssssssssssXss2t	[NJT]	TIME SET
Set Date	h1rrssssssssssXss51t	[NJD]	DATE SET
Stop Two Way Audio	h1rrssssssssssXss52t	[CLK]	TWO WAY AUDIO STOP STOP

Table 95 shows the D6500 and SIA automation output formats for these input commands.

## Appendix A: Contact ID Event Code Classifications

Figure 20: Contact ID format



- 1 - Customer (Subscriber Account Number)
- 2 - Event Qualifier - E = New Event, R = Restore
- 3 - Event Code - refer to Section A1 Event Codes
- 4 - Group or Partition Number, 00 to FF (2 Hex digits 0-9, B-F, always 00 for non-partitioned panels)
- 5 - Zone ID number\* - reporting the alarm (001 to 999) or user number for open or close reports.

\* System status messages, such as AC Loss and Low Battery, are Zone ID 000.

**Table 96: Contact ID Event Code Classifications**

#	Event Type	Zone
<b>Medical:</b>		
100	Medical	Emerg-Personal Emergency-#
101	Pendant Transmitter	Emerg-Personal Emergency-#
102	Fail to report in	Emerg-Fail to check in-#
<b>Fire Alarms:</b>		
110	Fire	Fire-Fire Alarm-#
111	Smoke w/Verification	Fire-Fire Alarm-#
112	Combustion	Fire-Combustion-#
113	Waterflow	Fire-Water Flow-#
114	Heat	Fire-Heat Sensor-#
115	Pull Station	Fire-Pull Station-#
116	Duct	Fire-Duct Sensor-#
117	Flame	Fire-Flame Sensor-#
118	Near Alarm	Fire-Near Alarm-#
<b>Panic Alarms:</b>		
120	Panic Alarm	Panic-Panic-#
121	Duress	Panic-Duress-User #
122	Silent	Panic-Silent Panic-#
123	Audible	Panic-Audible Panic-#
124	Duress-Access Granted	Panic-Duress Access Grant-#
125	Duress-Egress Granted	Panic-Duress Egress Grant-#
<b>Burglar Alarms:</b>		
130	Burglary	Burg-Burglary-#
131	Perimeter	Burg-Perimeter-#
132	Interior	Burg-Interior-#
133	24 HR Burg (Aux)	Burg-24 Hour-#
134	Entry/Exit	Burg-Entry/Exit-#
135	Day/Night	Burg-Day/Night-#
136	Outdoor	Burg-Outdoor-#
137	Tamper	Burg-Tamper-#
138	Near Alarm	Burg-Near Alarm-#
139	Intrusion Verifier	Burg-Intrusion Verifier-#

**Table 96: Contact ID Event Code Classifications (continued)**

#	Event Type	Zone
<b>General Alarms:</b>		
140	General Alarm	Alarm-General Alarm-#
141	Polling Loop Open	Alarm-Polling Loop Open
142	Polling Loop Short (AL)	Alarm-Polling Loop Short
143	Expansion Mod Failure	Alarm-Exp. Module Tamper-#
144	Sensor Tamper	Alarm-Sensor Tamper-#
145	Expansion Module Tamper	Alarm-Exp. Module Tamper-#
146	Silent Burg	Alarm-Silent Burglary-#
<b>24 Hour Non-Burglary:</b>		
150	24 Hour (Auxiliary)	Alarm-24 Hr. Non-Burg-#
151	Gas Detected	Alarm-Gas Detected-#
152	Refrigeration	Alarm-Refrigeration-#
153	Loss of Heat	Alarm-Heating System-#
154	Water Leakage	Alarm-Water Leakage-#
155	Foil Break	Trouble-Foil Break-#
156	Day Trouble	Trouble-Day Zone-#
157	Low Bottled Gas Level	Alarm-Low Gas Level-#
158	High Temp	Alarm-High Temperature-#
159	Low Temp	Alarm-Low Temperature-#
161	Loss of Air Flow	Alarm-Air Flow-#
162	Carbon Monoxide Detected	Alarm-Carbon Monoxide-#
163	Tank Level	Trouble-Tank Level-#
<b>Fire Supervisory:</b>		
200	Fire Supervisory	Super.-Fire Supervisory-#
201	Low Water Pressure	Super.-Low Water Pressure-#
202	Low CO2	Super.-Low CO2-#
203	Gate Valve Sensor	Super.-Gate Valve-#
204	Low Water Level	Super.-Low Water Level-#
205	Pump Activated	Super.-Pump Activation-#
206	Pump Failure	Super.-Pump Failure-#

**Table 96: Contact ID Event Code Classifications (continued)**

#	Event Type	Zone
<b>System Troubles:</b>		
300	System Trouble	Trouble-System Trouble
301	AC Loss	Trouble-AC Power
302	Low System Batt	Trouble-Low Battery
303	RAM Checksum Bad	Trouble-Bad RAM Checksum (Restore not applicable)
304	ROM Checksum Bad	Trouble-Bad ROM Checksum (Restore not applicable)
305	System Reset	Trouble-System Reset (Restore not applicable)
306	Panel Prog Change	Trouble-Programming Changed (Restore not applicable)
307	Self-Test Failure	Trouble-Self Test Failure
308	System Shutdown	Trouble-System Shutdown
309	Battery Test Fail	Trouble-Battery Test Failure
310	Ground Fault	Trouble-Ground Fault-#
311	Battery Missing	Trouble-Battery Missing
312	Power Supply Overcurrent	Trouble-Pwr. Supp. Overcur.-#
313	Engineer Reset	Status-Engineer Reset-User # (Restore not applicable)
<b>Sounder/Relay Troubles:</b>		
320	Sounder/Relay	Trouble-Sounder/Relay-#
321	BELL 1	Trouble-Bell/Siren #1
322	BELL 2	Trouble-Bell/Siren #2
323	Alarm Relay	Trouble-Alarm Relay
324	Trouble Relay	Trouble-Trouble Relay
325	Reversing Relay	Trouble-Reversing Relay
326	Notification Appliance CKT. #3	Trouble-Notification Appl. Ckt#3
327	Notification Appliance CKT. #4	Trouble-Notification Appl. Ckt#4
<b>System Peripheral Troubles:</b>		
330	System Peripheral	Trouble-Sys. Peripheral-#
331	Polling Loop Open	Trouble-Polling Loop Open
332	Polling Loop Short	Trouble-Polling Loop Short
333	Exp. Module Failure	Trouble-Exp. Module Fail-#
334	Repeater Failure	Trouble-Repeater Failure-#
335	Local Printer Paper Out	Trouble-Printer Paper Out

**Table 96: Contact ID Event Code Classifications (continued)**

#	Event Type	Zone
336	Local Printer Failure	Trouble-Local Printer
337	Exp. Mod. DC Loss	Trouble-Exp. Mod. DC Loss-#
338	Exp. Mod. Low bat	Trouble-Exp. Mod. Low Batt-#
339	Exp. Mod. Reset	Trouble-Exp. Mod. Reset-#
341	Exp. Mod. Tamper	Trouble-Exp. Mod. Tamper-#
342	Exp. Module AC Loss	Trouble-Exp. Module AC Loss-#
343	Exp. Module Self Test Fail	Trouble-Exp. Self-Test Fail-#
344	RF Rcvr Jam Detect #	Trouble-RF Rcvr Jam Detect-#
<b>Communication Troubles:</b>		
350	Communication	Trouble-Communication Failure
351	Telco 1 Fault	Trouble-Phone line #1
352	Telco 2 Fault	Trouble-Phone line #2
353	LR Radio Xmitter Fault	Trouble-Radio Transmitter
354	Failure To Communicate	Trouble-Fail to Communicate
355	Loss of Radion Super.	Trouble-Radio Supervision
356	Loss of Central Polling	Trouble-Central Radion Polling
357	LRR XMTR. VSWR	Trouble-Radio Xmitter. VSWR-#
<b>Protection Loop:</b>		
370	Protection Loop	Trouble-Protection Loop-#
371	Protection Loop Open	Trouble-Prot. Loop Open-#
372	Protection Loop Short	Trouble-Prot. Loop Short-#
373	Fire Trouble	Trouble-Fire Loop-#
374	Exit Error (By User)	Alarm-Exit Error-#
375	Panic Zone Trouble	Trouble-PA Trouble-#
376	Hold-Up Zone Trouble	Trouble-Hold-Up Trouble-#

**Table 96: Contact ID Event Code Classifications (continued)**

#	Event Type	Zone
<b>Sensor:</b>		
380	Sensor TRBL-Global	Trouble-Sensor Trouble-#
381	Loss Of Supervision	Trouble-RF Sensor Super.-#
382	Loss Of Supervisn	Trouble-RPM Sensor Super.-#
383	Sensor Tamper	Trouble-Sensor Tamper-#
384	RF Low Battery	Trouble-RF Sensor Battery-#
385	Smoke Hi Sens.	Trouble-Smoke Hi Sens.-#
386	Smoke lo sens.	Trouble-Smoke Lo Sens.-#
387	Intrusion hi sens.	Trouble-Intrusion Hi Sens.-#
388	Intrusion lo sens.	Trouble-Intrusion Lo Sens.-#
389	Det. Self test fail	Trouble-Sensor Test Fail-#
391	Sensor Watch Failure	Trouble-Sensor Watch Fail-#
392	Drift Comp. Error	Trouble-Drift Comp. Error-#
393	Maintenance Alert	Trouble-Maintenance Alert-#
<b>Open/Close:</b>		
400	Open/Close	Opening/Closing
401	Open/Close By User	Opening-User #/Closing-User #
402	Group O/C	Closing-Group User #
403	Automatic Open/Close	Opening-Automatic/Closing-Automatic
404	Late to O/C	Opening-Late/Closing-Late
405	Deferred O/C	Event & Restore Not Applicable
406	Cancel (By User)	Opening-Cancel
407	Remote Arm/Disarm	Opening-Remote/Closing-Remote
408	Quick Arm	Event not applicable for opening/closing-Quick Arm
409	Keyswitch Open/Close	Opening-Keyswitch/Closing-Keyswitch
441	Armed Stay	Opening-Armed Stay/Closing-Armed Stay
442	Keyswitch Armed Stay	Opening-Keysw. Arm Stay/Opening-Keysw. Arm Stay
450	Exception O/C	Opening-Exception/Closing-Exception
451	Early O/C	Opening-Early/Closing-Early-Use r#
452	Late O/C	Opening-Late/Closing-Late-User #
453	Failed to Open	Trouble-Fail to open (Restore not applicable)

**Table 96: Contact ID Event Code Classifications (continued)**

#	Event Type	Zone
454	Failed to Close	Trouble-Fail to Close (Restore not applicable)
455	Auto-Arm Failed	Trouble-Auto Arm Failed (Restore not applicable)
456	Partial Arm	Closing-Partial arm-User #
457	Exit Error (User)	Closing-Exit Error-User #
458	User on Premises	Opening-User on Prem. -User #
459	Recent Close	Trouble-Recent Close-User # (Restore not applicable)
461	Wrong Code Entry	Access-Wrong Code entry (Restore not applicable)
462	Legal Code Entry	Access-Legal Code entry-user # (Restore not applicable)
463	Re-arm after Alarm	Status-Re Arm After Alarm-User # (restore not applicable)
464	Auto Arm Time Extended	Status-Auto Arm Time Ext.-User # (Restore not applicable)
465	Panic Alarm Reset	Status-PA Reset (Restore not applicable)
<b>Remote Access:</b>		
411	Callback Requested	Remote-Callback Requested (Restore not applicable)
412	Success-Download/access	Remote-Successful Access (Restore not applicable)
413	Unsuccessful Access	Remote-Unsuccessful Access (Restore not applicable)
414	System Shutdown	Remote-System Shutdown
415	Dialer Shutdown	Remote-Dialer Shutdown
416	Successful Upload	Remote-Successful Upload (Restore not applicable)
<b>Access Control:</b>		
421	Access Denied	Access-Access Denied-User # (Restore not applicable)
422	Access Report by User	Access-Access Gained-User # (Restore not applicable)
423	Forced Access	Panic-Forced Access-#
424	Egress Denied	Access-Egress Denied (Restore not applicable)
425	Egress Granted	Access-Egress Granted (Restore not applicable)
426	Access Door Proppped Open	Access-Door Proppped Open-#
427	Access Point DSM Trouble	Access-ACS Point DSM Trbl.-#
428	Access Point RTE Trouble	Access-ACS Point RTE Trbl.-#
429	Access Program Mode Entry	Access-ACS Prog. Entry-User # (Restore not applicable)

**Table 96: Contact ID Event Code Classifications (continued)**

#	Event Type	Zone
430	Access Program Mode Exit	Access-ACS Prog. Exit-User # (Restore not applicable)
431	Access Threat Level Change	Access-ACS Threat Level Chg.
432	Access Relay/Trigger Fail	Access-ACS Relay/Trig. Fail-#
433	Access RTE Shunt	Access-ACS RTE Shunt-#
434	Access DSM Shunt	Access-ACS DSM Shunt-#
<b>System Disables:</b>		
501	Access Reader Disable	Disable-Access Rdr. Disable-#
<b>Sounder/Relay Disables:</b>		
520	Sounder/Relay Disable	Disable-Sounder/Relay-#
521	Bell 1 Disable	Disable-Bell/Siren #1
522	Bell 2 Disable	Disable-Bell/Siren #2
523	Alarm Relay Disable	Disable-Alarm Relay
524	Trouble Relay Disable	Disable-Trouble Relay
525	Reversing Relay Disable	Disable-Reversing Relay
526	Notification Appliance Ckt #3	Disable-Notification Appl. Ckt #3
527	Notification Appliance Ckt #4	Disable-Notification Appl. Ckt #4
<b>System Peripheral Disables:</b>		
531	Module Added	Super.-Module Added (Restore not applicable)
532	Module Removed	Super.-Module Removed (Restore not applicable)
<b>Communication Disables:</b>		
551	Dialer Disabled	Disable-Dialer Disable
552	Radio Xmitter Disabled	Disable-Radio Disable
553	Remote Upload/Download	Disable-Rem. Up/Download Disable
<b>Bypasses:</b>		
570	Zone/Sensor Bypass	Bypass-Zone Bypass-#
571	Fire Bypass	Bypass-Fire Bypass-#

**Table 96: Contact ID Event Code Classifications (continued)**

#	Event Type	Zone
572	24 Hour Zone Bypass	Bypass-24 Hour Bypass-#
573	Burg. Bypass	Bypass-Burg. Bypass-#
574	Group Bypass	Bypass-Group Bypass-User #
575	Swinger Bypass	Bypass-Swinger Bypass-#
576	Access Zone Shunt	Access-ACS Zone Shunt-#
577	Access Point Bypass	Access-ACS Point Bypass-#
Test/Misc.:		
601	Manual Test	Test-Manually Triggered (Restore not applicable)
602	Periodic Test	Test-Periodic (Restore not applicable)
603	Periodic RF Xmission	Test-Periodic Radio (Restore not applicable)
604	Fire Test	Test-Fire Walk Test-User #
605	Status Report To Follow	Test-Fire Walk-User #
606	Listen-In To Follow	Listen-Listen-In Active (Restore not applicable)
607	Walk-Test Mode	Test-Walk Test Mode-User #
608	System Trouble Present	Test-System Trouble Present (Restore not applicable)
609	Video XMTR Active	Listen-Video Xmitter Active (Restore not applicable)
611	Point Tested OK	Test-Point Tested OK-# (Restore not applicable)
612	Point Not Tested	Test-Point Not Tested-# (Restore not applicable)
613	Intrusion Zone Walk Tested	Test-Intrn Zone Walk Test-# (Restore not applicable)
614	Fire Zone Walk Tested	Test-Fire Zone Walk Test-# (Restore not applicable)
615	Panic Zone Walk Tested	Test-PA Zone Walk Test (Restore not applicable)
616	Service Request	Trouble-Service Request
Event Log:		
621	Event Log Reset	Trouble-Event Log Reset (Restore not applicable)
622	Event Log 50% Full	Trouble-Event Log 50% Full (Restore not applicable)
623	Event Log 90% Full	Trouble-Event Log 90% Full (Restore not applicable)
624	Event Log Overflow	Trouble-Event Log Overflow (Restore not applicable)
625	Time/Date Reset	Trouble-Time/Date Reset-User # (Restore not applicable)
626	Time/Date Inaccurate	Trouble-Time/Date Invalid

<b>Table 96: Contact ID Event Code Classifications (continued)</b>		
#	Event Type	Zone
627	Program Mode Entry	Trouble-Program Mode Entry (Restore not applicable)
628	Program Mode Exit	Trouble-Program Mode Exit (Restore not applicable)
<b>Scheduling:</b>		
630	Schedule Change	Trouble-Schedule Changed (Restore not applicable)
631	Exception Sched. Change	Trouble-Esc. Sched. Changed (Restore not applicable)
632	Access Schedule Changes	Trouble-Access Sched. Changed (Restore not applicable)
<b>Personnel Monitoring:</b>		
641	Senior Watch Trouble	Trouble-Senior Watch Trouble
642	Latch-key Supervision	Status-Latch-key Super-User # (Restore not applicable)
<b>Special Codes:</b>		
750-789	These codes are used <b>only</b> by Protection and can be assigned any unique non-standard Event code that Pro 1 tracks.	

## Appendix B: Internal Messages

**Table 97: Internal Messages**

#	Internal Messages	D6500 Output <sup>2</sup>	SIA Output <sup>2</sup>	Printer Output
1.	Acknowledge			Acknowledge
2.	Keypad Operation <sup>1</sup>	X 0	[NYZ]	OPERATOR KEYPAD OPERATION
3.	Service Required <sup>1</sup>	X 1	[NYX]	SERVICE REQUIRED
4.	Set Time	X 2	[NJT]	TIME SET
5.	Battery Missing	X 9	[NYM]	BATTERY MISSING
6.	Battery Present <sup>1</sup>	X 10	[NYR]	BATTERY PRESENT
7.	Battery Bad	X 11	[NYT]	BATTERY LOW
8.	Battery Restore	X 12	[NYR]	BATTERY RESTORE
9.	AC Fail	X 13	[NAT]	AC FAIL
10.	AC Restore	X 14	[NAR]	AC RESTORE
11.	Paper In <sup>1</sup>	X 15	[NVI]	PAPER IN
12.	Paper Out <sup>1</sup>	X 16	[NVO]	PAPER OUT
13.	Local Parameter Program In <sup>1</sup>	X 17	[NLB]	LOCAL PARM PROGRAM IN
14.	Local Parameter Program Successful <sup>1</sup>	X 18	[NLS]	LOCAL PARM PROGRAM OK
15.	Local Software Program In <sup>1</sup>	X 41	[NLB]	LOCAL SOFTWARE PROG IN
16.	Local Software Program Successful <sup>1</sup>	X 42	[NLS]	LOCAL SOFTWARE PROG OK
17.	Local Program Failure <sup>1</sup>	X 43	[NLU]	LOCAL PROGRAM FAILURE
18.	Local Program Denied <sup>1</sup>	X 44	[NLD]	LOCAL PROGRAM DENIED
19.	Remote Parameter Program In	X 45	[NRB]	REMOTE PARM PROGRAM IN
20.	Remote Parameter Program Successful	X 46	[NRS]	REMOTE PARM PROGRAM OK
21.	Remote Software Program In	X 47	[NRB]	REMOTE SOFTWARE PROG IN
22.	Remote Software Program Successful	X 48	[NRS]	REMOTE PROGRAM SUCCESS
23.	Remote Program Failure	X 49	[NRU]	REMOTE PROGRAM FAILURE
24.	Remote Program Denied <sup>1</sup>	X 50	[NRD]	REMOTE PROGRAM DENIED
25.	Printer On Line <sup>1</sup>	X 19	[NVY]	PRINTER ON LINE

**Table 97: Internal Messages (continued)**

#	Internal Messages	D6500 Output <sup>2</sup>	SIA Output <sup>2</sup>	Printer Output
26.	Printer Off Line <sup>1</sup>	X 20	[NVZ]	PRINTER OFF LINE
27.	External PRT Error	X 21	[NVT]	EXTERNAL PRINTER ERROR
28.	External PRT Restore	X 22	[NVR]	EXTERNAL PRINTER RESTORE
29.	Internal PRT Error <sup>1</sup>	X 21	[NVT]	INTERNAL PRINTER ERROR
30.	Internal PRT Restore <sup>1</sup>	X 22	[NVR]	INTERNAL PRINTER RESTORE
31.	Busy Seconds	bbb B	[NYBbbb]	BUSY SECONDS bbb%
32.	COM3 Error	X 30	[NYC]	COMPUTER ERROR
33.	COM3 Trouble	X 31	[NYS]	COMPUTER TROUBLE
34.	COM3 Restore	X 32	[NYK]	COMPUTER RESTORE
35.	UPS AC Fail	X 33	[NUA01]	UPS AC FAIL
36.	UPS AC Restore	X 34	[NUR01]	UPS AC RESTORE
37.	UPS Battery Low	X 35	[NUA02]	UPS BATTERY LOW
38.	UPS Battery Restore	X 36	[NUR02]	UPS BATTERY RESTORE
39.	System Reset	X 37	[NYW01]	SYSTEM RESET
40.	System Default <sup>1</sup>	X 38	[NYG]	SYSTEM DEFAULT
41.	System Temperature High	X 39	[NKA]	SYSTEM TEMPERATURE HIGH
42.	System Temperature Restore	X 40	[NKR]	SYSTEM TEMPERATURE RESTORE
43.	Slotx/Linex (Lxx) Line Fault	X 5	[NLT]	PHONE LINE FAULT
44.	Slotx/Linex (Lxx) Line Restore	X 6	[NLR]	PHONE LINE RESTORE
45.	Slotx/Linex (Lxx) Line Card Trouble	X 7	[NYD]	LINE CARD TROUBLE
46.	Slotx/Linex (Lxx) Line Card Restore	X 8	[NYE]	LINE CARD RESTORE
47.	Slotx/Linex (Lxx) Audio In	*	[NLF]	AUDIO IN
48.	Slotx/Linex (Lxx) Audio Done	L	[NLE]	AUDIO DONE
49.	Slotx/Linex (Lxx) Communication Error <sup>1</sup>	X 60	[NUA03]	COMMUNICATION ERROR
50.	Slotx/Linex (Lxx) Communication Restr <sup>1</sup>	X 61	[NUR03]	COMMUNICATION RESTORE
51.	Slotx/Linex (Lxx) Data Error	X 62	[NYN]	DATA ERROR

**Table 97: Internal Messages (continued)**

#	Internal Messages	D6500 Output <sup>2</sup>	SIA Output <sup>2</sup>	Printer Output
52.	Slotx/Linex (Lxx) No Data Received	X 63	[NUT04]	NO DATA RECEIVED
53.	Slotx/Linex (Lxx) Reset	X 64	[NYW02]	LINE RESET
54.	Slotx/Linex (Lxx) Codec Error <sup>1</sup>	X 65	[NUT05]	CODEC ERROR
55.	Slotx/Linex (Lxx) Private Call	P	[NUT06]	PRIVATE CALL
56.	Slotx/Linex (Lxx) No Call Number	N	[NUT07]	NO CALL NUMBER
57.	Slotx/Linex (Lxx) Caller Unknown	U	[NUT08]	CALLER UNKNOWN
58.	Set Date	X 51	[NJD]	DATE SET
59.	Stop Two Way Audio	X 52	[CLK]	TWO WAY AUDIO STOP
60.	CPU Data Error <sup>1</sup>	X 53	[NYN01]	CPU DATA ERROR
61.	Network Error <sup>1</sup>	X 54	[NNT]	NETWORK ERROR
62.	Network Restore <sup>1</sup>	X 55	[NNR]	NETWORK RESTORE
63.	Account Status Failure	T B02	[NYC]	COMM FAIL
64.	Account Status Restore	N B02	[NYK]	COMM FAIL RESTR
65.	Supervision Rate Changed	X 66	[NCO0001]	SUPERVISION RATE CHANGED
66.	Switch To Intercept Mode	X 88	[NCO0002]	SWITCH TO INTERCEPT MODE
67.	Switch to Fallback Mode	X 81	[NCO0003]	SWITCH TO FALLBACK MODE
68.	Disable Intercept Mode	X 83	[NCO0004]	DISABLE INTERCEPT MODE
69.	Activate Output	X 84	[NCO0005]	ACTIVATE OUTPUT
70.	Deactivate Output	X 86	[NCO0006]	DEACTIVATE OUTPUT
71.	C900 Reboot	X 59	[NSC0001]	C900 REBOOT
72.	C900 Battery Low	X 58	[NSC0002]	C900 VOLTAGE LOW
73.	C900 Battery Restore	X 68	[NSC0003]	C900 VOLTAGE RESTORE

**Table 97: Internal Messages (continued)**

#	Internal Messages	D6500 Output <sup>2</sup>	SIA Output <sup>2</sup>	Printer Output
74.	C900 Switched to Intercept	X 87	[NSC0004]	C900 SWITCHED TO INTERCEPT
75.	C900 Switched to Fallback	X 82	[NSC0005]	C900 SWITCHED TO FALBACK
76.	C900 Output Activated	X 85	[NSC0006]	C900 OUTPUT ACTIVATED
77.	C900 Output Deactivated	X 94	[NSC0007]	C900 OUTPUT DEACTIVATED
78.	C900 Input Shorted	X 89	[NSC0008]	C900 INPUT SHORTED
79.	C900 Input Open	X 90	[NSC0009]	C900 INPUT OPEN
80.	C900 Input Restored	X 91	[NSC0010]	C900 INPUT RESTORED
81.	C900 Intercept Enabled	X 92	[NSC0011]	C900 INTERCEPT ENABLED
82.	C900 Intercept Disabled	X 93	[NSC0012]	C900 INTERCEPT DISABLED
83.	No Acknowledgement Received	X 71	[NYU0001]	NO ACKNOWLEDGEMENT RECEIVED
84.	Not Dialing	X 72	[NYU0002]	NOT DIALING
85.	Dialing Error	X 73	[NYU0003]	DIALING ERROR
86.	No Response to Handshake	X 74	[NYU0004]	NO RESPONSE TO HANDSHAKE
87.	No Response to Acknowledgement	X 75	[NYU0005]	NO RESPONSE TO ACK
88.	Message Unknown	X 76	[NYU0006]	MESSAGE UNKNOWN
89.	Invalid Message	X 77	[NYU0007]	INVALID MESSAGE
90.	30 Minutes Since Fallback Command	X 95	[NMI0001]	30 MIN SINCE FALBACK CMD
91.	Alarm for Panel Substitution	A D53	[Npt003AA 007]	ALARM-PNL SUBST
92.	Account Disable by Attack	TB03	[Npt003YC 008]	ACCOUNT DISABLED BY ATTACK
93.	Incompatible	X 99	[NIVn]	INCOMPATIBLE FIRMWARE
94.	Incompatible	X 100	[NIUn]	INCOMPATIBLE HARDWARE

<sup>1</sup> Internal message is not implemented.<sup>2</sup> Output messages are abbreviated.

## Appendix C: Modem4/ModemIIIa<sup>2</sup> Messages



For lines that are grouped, Gxx appears instead of Lxx.

The GV4 (v2.x.x and higher)/B5512/B4512 send 4-digit user and point numbers. Panels using Modem4 send 4-digit Point and User data.

New events added since the last revision of this document are identified as a New Message in the Comments column.

Comment numbers are identified in the ZONEX and Comex Translation section following this table.

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
1 Abort (No User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrlssssssaaasIsD4lt <header>[#aaaa NriaAB]	ABORT BY USER AREA=a
2 Abort	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrlssssssaaasIsiiit <header>[#aaaa Nria/iidiiAB]	ABORT BY USER AREA=a ID=iii
3 Abort (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrlssssssaaasIiitiit <header>[#aaaa Nriaa/idiiiAB]	ABORT BY USER AREA=aa ID=iii
4 Access Granted	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ACCESS GRANTED +++ACC aaaa AREA=a CRD=i-x POINT=PPP h1rrlssssssaaaaAGsppt <header>[#aaaa Nria/iidiiDGppp]	ACCESS GRANTED AREA=a CRD=i-x POINT=PPP
5 Access Granted (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ACCESS GRANTED +++ACC aaaa AREA=aa CRD=iii POINT=PPP h1rrlssssssaaaaAGsppt <header>[#aaaa Nriaa/idiiiDGppp]	ACCESS GRANTED AREA=aa CRD=iii POINT=PPP
6 Access Granted (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ACCESS GRANTED +++ACC aaaa AREA=aa CRD=i-x POINT=pppp h1rrlssssssaaaaAGpppt <header>[#aaaa Nriaa/idiiIDGppp]	ACCESS GRANTED AREA=aa CRD=i-x POINT=pppp
7 Access Granted (4-digit User / Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ACCESS GRANTED +++ACC aaaa AREA=aa CRD=iii POINT=pppp h1rrlssssssaaaaAGpppt <header>[#aaaa Nriaa/idiiiDGppp]	ACCESS GRANTED AREA=aa CRD=iii POINT=pppp
8 AC Fail	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa AC FAILURE +++ACC aaaa h1rrlssssssaaasPsssst <header>[#aaaa NriaaAT]	AC FAILURE AREA=aa
9 AC Fail (No Area)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa AC FAILURE h1rrlssssssaaasPsssst <header>[#aaaa NAT]	AC FAILURE
10 AC Restoral	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa AC RESTORAL +++ACC aaaa h1rrlssssssaaasRsss0t <header>[#aaaa NriaaAR]	AC RESTORAL AREA=aa
11 AC Restoral (No Area)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa AC RESTORAL h1rrlssssssaaasRsss0t <header>[#aaaa NAR]	AC RESTORAL
12 Alarm from Recent Closing (2 min of close) (No User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ALARM REPORT +++ACC aaaa RECENT CLOSING +++ACC aaaa AREA=a POINT=PPP h1rrlssssssaaasAspppt <header>[#aaaa NriaCrppp]	ALARM REPORT RECENT CLOSING AREA=a POINT=PPP
13 Alarm from Recent Closing (2 min of close)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ALARM REPORT +++ACC aaaa RECENT CLOSING +++ACC aaaa AREA=a ID=iii POINT=PPP h1rrlssssssaaasAspppt <header>[#aaaa Nria/iidiiCRpppl]	ALARM REPORT RECENT CLOSING AREA=a ID=iii POINT=PPP
14 Alarm from Recent Closing (2 min of close) (No User / 4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ALARM REPORT +++ACC aaaa RECENT CLOSING +++ACC aaaa AREA=aa POINT=pppp h1rrlssssssaaasApppt <header>[#aaaa NriaaCRppp]	ALARM REPORT RECENT CLOSING AREA=aa POINT=pppp

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

	<b>Event</b>	<b>Device/Mode</b>	<b>Display/Explanation</b>	<b>Comments</b>
15	Alarm from Recent Closing (2 min of close) (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ALARM REPORT +++ACC aaaa RECENT CLOSING +++ACC aaaa AREA=aa ID=iii POINT=pppp h1rrlssssssaaaasApppt <header>[#aaaa Nriaa/idiiiCRpppp]	
16	Alarm from Recent Closing (2 min of close) (4-digit User / Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ALARM REPORT +++ACC aaaa RECENT CLOSING +++ACC aaaa AREA=aa ID=iiii POINT=pppp h1rrlssssssaaaasApppt <header>[#aaaa Nriaa/idiiiiCRpppp]	
17	Alarm from Recent Closing / Ground Fault (2 min of close) (No User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ALARM REPORT +++ACC aaaa RECENT CLOSING +++ACC aaaa GROUND FAULT +++ACC aaaa AREA=a POINT=ppp h1rrlssssssaaaasAspppt <header>[#aaaa NriaaCrppp]	
18	Alarm from Recent Closing / Ground Fault (2 min of close)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ALARM REPORT +++ACC aaaa RECENT CLOSING +++ACC aaaa GROUND FAULT +++ACC aaaa AREA=a ID=iii POINT=ppp h1rrlssssssaaaasAspppt <header>[#aaaa Nriaa/idiiiCRppp]	
19	Alarm from Recent Closing / Ground Fault (2 min of close) (No User / 4-digit point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ALARM REPORT +++ACC aaaa RECENT CLOSING +++ACC aaaa GROUND FAULT +++ACC aaaa AREA=aa POINT=pppp h1rrlssssssaaaasApppt <header>[#aaaa Nriaa/CRpppp]	
20	Alarm from Recent Closing / Ground Fault (2 min of close) (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ALARM REPORT +++ACC aaaa RECENT CLOSING +++ACC aaaa GROUND FAULT +++ACC aaaa AREA=aa ID=iii POINT=pppp h1rrlssssssaaaasApppt <header>[#aaaa Nriaa/idiiiCRpppp]	
21	Alarm from Recent Closing / Ground Fault (2 min of close) (4-digit User / Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ALARM REPORT +++ACC aaaa RECENT CLOSING +++ACC aaaa GROUND FAULT +++ACC aaaa AREA=aa ID=iiii POINT=pppp h1rrlssssssaaaasApppt <header>[#aaaa Nriaa/idiiiiCRpppp]	
22	Alarm Cross Point	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ALARM REPORT +++ACC aaaa CROSS POINT +++ACC aaaa AREA=a CG=gg POINT=ppp h1rrlssssssaaaasAspppt <header>[#aaaa Nriaa/BMppp]	
23	Alarm Cross Point (No Area)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ALARM REPORT +++ACC aaaa CROSS POINT +++ACC aaaa POINT=ppp h1rrlssssssaaaasAspppt <header>[#aaaa NBMppp]	
24	Alarm Cross Point (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ALARM REPORT +++ACC aaaa CROSS POINT +++ACC aaaa AREA=aa CG=gg POINT=pppp h1rrlssssssaaaasApppt <header>[#aaaa Nriaa/BMpppp]	
25	Alarm Cross Point / Ground Fault	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ALARM REPORT +++ACC aaaa CROSS POINT, GROUND FAULT +++ACC aaaa AREA=a CG=gg POINT=ppp h1rrlssssssaaaasApppt <header>[#aaaa Nriaa/BMppp]	
26	Alarm Cross Point / Ground Fault (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ALARM REPORT +++ACC aaaa CROSS POINT, GROUND FAULT +++ACC aaaa AREA=aa CG=gg POINT=pppp h1rrlssssssaaaasApppt <header>[#aaaa Nriaa/BMpppp]	
27	Alarm Door Forced	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ALARM REPORT +++ACC aaaa DOOR FORCED +++ACC aaaa AREA=a POINT=ppp h1rrlssssssaaaasAspppt <header>[#aaaa NriaaDFppp]	
28	Alarm Door Forced (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ALARM REPORT +++ACC aaaa DOOR FORCED +++ACC aaaa AREA=aa POINT=pppp h1rrlssssssaaaasApppt <header>[#aaaa NriaaDFpppp]	

**Table 98: Modem4/ModemIIla<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
29 Alarm Exit Error (No User)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasAspppt <header>[#aaaa NriaEAppp]	ALARM REPORT EXIT ERROR AREA=a POINT=PPP
30 Alarm Exit Error (No user / 4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasAppppt <header>[#aaaa NriaaEAppp]	ALARM REPORT EXIT ERROR AREA=aa POINT=PPPP
31 Alarm Exit Error (No Area)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasAspppt <header>[#aaaa NidiiiEAppp]	ALARM REPORT EXIT ERROR ID=iii POINT=PPP
32 Alarm Exit Error	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasAspppt <header>[#aaaa Nriaa/idiiiEAppp]	ALARM REPORT EXIT ERROR AREA=a ID=iii POINT=PPP
33 Alarm Exit Error (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasAppppt <header>[#aaaa Nriaa/idiiiEAppp]	ALARM REPORT EXIT ERROR AREA=aa ID=iii POINT=PPPP
34 Alarm Exit Error (4-digit User / Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasAppppt <header>[#aaaa Nriaa/idiiiEAppp]	ALARM REPORT EXIT ERROR AREA=aa ID=iiii POINT=PPPP
35 Alarm Exit Error / Ground Fault	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasAspppt <header>[#aaaa Nriaa/idiiiEAppp]	ALARM REPORT EXIT ERROR, GROUND FAULT AREA=a ID=iii POINT=PPP
36 Alarm Exit Error / Ground Fault (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasAppppt <header>[#aaaa Nriaa/idiiiEAppp]	ALARM REPORT EXIT ERROR, GROUND FAULT AREA=aa ID=iii POINT=PPPP
37 Alarm Exit Error / Ground Fault (4-digit User / Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasAppppt <header>[#aaaa Nriaa/idiiiEAppp]	ALARM REPORT EXIT ERROR, GROUND FAULT AREA=aa ID=iiii POINT=PPPP
38 Alarm Exit Error / Ground Fault (No user)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasAspppt <header>[#aaaa NriaEAppp]	ALARM REPORT EXIT ERROR, GROUND FAULT AREA=a POINT=PPP
39 Alarm Exit Error / Ground Fault (No user / 4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasAppppt <header>[#aaaa NriaaEAppp]	ALARM REPORT EXIT ERROR, GROUND FAULT AREA=aa POINT=PPPP
40 Alarm Silenced (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasFspppt <header>[#aaaa NriaaFlppp]	ALARM SILENCED AREA=aa POINT=PPPP
41 Analog Restoral / Sensor Dirty	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrrlssssssaaaasRsssFt <header>[#aaaa NTC]	ALL PTS TESTED
42 Analog Restoral	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRspppt <header>[#aaaa NriaANppp]	ANALOG RESTORE AREA=a POINT=PPP
43 Analog Restoral / Sensor Dirty	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRspppt <header>[#aaaa NriaANppp]	ANALOG RESTORE SENSOR DIRTY AREA=a POINT=PPP
44 Analog Restoral (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRppppt <header>[#aaaa NriaANppp]	ANALOG RESTORE AREA=aa POINT=PPPP

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
45 Analog Restoral / Sensor Dirty (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ANALOG RESTORE +++ACC aaaa SENSOR DIRTY +++ACC aaaa AREA=aa POINT=pppp h1rrlssssssaaaasRpppt <header>[#aaaa NriaaANpppp]	
46 Analog Service	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ANALOG SERVICE +++ACC aaaa AREA=a POINT=PPP h1rrlssssssaaaasTspppt <header>[#aaaa NriaASppp]	
47 Analog Service / Dirty Sensor	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ANALOG SERVICE +++ACC aaaa SENSOR DIRTY +++ACC aaaa AREA=a POINT=ppp h1rrlssssssaaaasTspppt <header>[#aaaa NriaASppp]	
48 Analog Service (Level & Value)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ANALOG SERVICE +++ACC aaaa AREA=a POINT=ppp +++ACC aaaa LEVEL=111 VALUE=vvv h1rrlssssssaaaasTspppt <header>[#aaaa Nria/lvlll/vavvvAsppp]	
49 Analog Service (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ANALOG SERVICE +++ACC aaaa AREA=aa POINT=pppp h1rrlssssssaaaasTppppt <header>[#aaaa NriaaASpppp]	
50 Analog Service / Dirty Sensor (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ANALOG SERVICE +++ACC aaaa SENSOR DIRTY +++ACC aaaa AREA=aa POINT=pppp h1rrlssssssaaaasTppppt <header>[#aaaa NriaaASpppp]	
51 Analog Service (4-digit Point) (Level & Value)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa ANALOG SERVICE +++ACC aaaa AREA=aa POINT=pppp +++ACC aaaa LEVEL=111 VALUE=vvv h1rrlssssssaaaasTppppt <header>[#aaaa Nriaa/lvlll/vavvvAsppp]	
52 Area Watch Ended (No user)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa WATCH MODE END +++ACC aaaa AREA=a h1rrlssssssaaaasNsD5t <header>[#aaaa NriaTZ]	
53 Area Watch Ended	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa WATCH MODE END +++ACC aaaa AREA=a ID=iii h1rrlssssssaaaasNsD5t <header>[#aaaa Nria/idiiiTZ]	
54 Area Watch Ended (4-digit User)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa WATCH MODE END +++ACC aaaa AREA=aa ID=iii h1rrlssssssaaaasNsD5t <header>[#aaaa Nriaa/idiiiTZ]	
55 Area Watch Started (No user)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa WATCH START +++ACC aaaa AREA=a h1rrlssssssaaaasNsD5t <header>[#aaaa NriaTW]	
56 Area Watch Started	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa WATCH START +++ACC aaaa AREA=a ID=iii h1rrlssssssaaaasNsD5t <header>[#aaaa Nria/idiiiTW]	
57 Area Watch Started (4-digit User)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa WATCH START +++ACC aaaa AREA=aa ID=iiii h1rrlssssssaaaasNsD5t <header>[#aaaa Nriaa/idiiiiTW]	
58 Battery Low (System)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa BATTERY LOW h1rrlssssssaaaasTsss9t <header>[#aaaa NYT]	
59 Battery Low (Area Specific)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa BATTERY LOW +++ACC aaaa AREA=aa h1rrlssssssaaaasTsss9t <header>[#aaaa NriaAYT]	
60 Battery Missing (System)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa BATTERY MISSING h1rrlssssssaaaasTsss9t <header>[#aaaa NYM]	
61 Battery Restoral (System)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa BATTERY RESTORE h1rrlssssssaaaasRsss9t <header>[#aaaa NYR]	
62 Battery Restoral (Area Specific)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa BATTERY RESTORE +++ACC aaaa AREA=aa h1rrlssssssaaaasRsss9t <header>[#aaaa NriaAYR]	

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
63 Battery Trouble	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrlssssssaaaaasTsss9t <header>[#aaaa NYT]	BATTERY TROUBLE New Message
64 Battery Trouble (Device Specific)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrlssssssaaaaasTsss9t <header>[#aaaa NpiddddYT]	BATTERY TROUBLE SDI=dddd New Message
65 Battery Trouble Restoral	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrlssssssaaaaasRsss9t <header>[#aaaa NYR]	BATT TRBL REST New Message
66 Battery Trouble Restoral (Device Specific)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrlssssssaaaaasRsss9t <header>[#aaaa NpiddddYR]	BATT TRBL REST SDI=dddd New Message
67 Bypass Restore (No Area)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrlssssssaaaaRBsppt <header>[#aaaa NUUppp]	BYPASS RESTORE POINT=ppp
68 Bypass Restore	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrlssssssaaaaRBsppt <header>[#aaaa NriaUppp]	BYPASS RESTORE AREA=a POINT=PPP
69 Bypass Restore (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrlssssssaaaaRBpppt <header>[#aaaa NriaaUpppp]	BYPASS RESTORE AREA=aa POINT=pppp
70 Bypass Restore / Fire Point (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrlssssssaaaaRBpppt <header>[#aaaa NriaaFUpvvv]	BYPASS RESTORE FIRE POINT AREA=aa POINT=pppp
71 Bypass Restore / Supervisory Point (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrlssssssaaaaRBpppt <header>[#aaaa NriaaSUpvvv]	BYPASS RESTORE SUPERVISORY POINT AREA=aa POINT=pppp
72 Bypass Restore / Waterflow Point (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrlssssssaaaaRBpppt <header>[#aaaa NriaaWUpvvv]	BYPASS RESTORE WATERFLOW POINT AREA=aa POINT=pppp
73 Cancel Alarm (No Area)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrlssssssaaaa\siiit <header>[#aaaa NidiiiBC]	CANCEL ALARM ID=iiii
74 Cancel Alarm	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrlssssssaaaa\siiit <header>[#aaaa Nria/iidiiiBC]	CANCEL ALARM AREA=a ID=iiii
75 Cancel Alarm (No User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrlssssssaaaaas\sssst <header>[#aaaa NriaBC]	CANCEL ALARM AREA=a
76 Cancel Alarm (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrlssssssaaaaas\iiiiit <header>[#aaaa Nriaa/iidiiiBC]	CANCEL ALARM AREA=aa ID=iiii
77 Card Assigned by Programmer	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrlssssssaaaaasNsD30t <header>[#aaaa NpidddDAiiii]	CARD ASSIGNED BY PROGRAMMER CRD=iii-x SDI=ddd
78 Card Assigned by Programmer (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrlssssssaaaaasNsD30t <header>[#aaaa NpidddDAiiii]	CARD ASSIGNED BY PROGRAMMER CRD=iiii SDI=ddd
79 Card Assigned by Remote	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrlssssssaaaaasNsD30t <header>[#aaaa NDaiii]	CARD ASSIGNED BY REMOTE CRD=iii-x

<b>Table 98: Modem4/ModemIIIa<sup>2</sup> Messages</b>				
	<b>Event</b>	<b>Device/Mode</b>	<b>Display/Explanation</b>	<b>Comments</b>
80	Card Assigned by Remote (4-digit User)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaasNsD30t <header>[#aaaa NDAiiii]	CARD ASSIGNED BY REMOTE CRD=iiii
81	Card Assigned by User	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaasNsD30t <header>[#aaaa NidiiiiAiii]	CARD ASSIGNED BY USER CRD=iii-x ID=iiii
82	Card Assigned by User (4-digit User)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaasNsD30t <header>[#aaaa NidiiiiDAiiii]	CARD ASSIGNED BY USER CRD=iiii ID=iiii
83	Card Assigned by User (No User)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaasNsD30t <header>[#aaaa NDA]	CARD ASSIGNED BY USER
84	Card Deleted by User (No User)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaasNsD31t <header>[#aaaa NDB]	CARD DELETED BY USER
85	Card Deleted by User	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaasNsD31t <header>[#aaaa NidiiiiDBiiii]	CARD DELETED BY USER CRD=iii-x ID=iii
86	Card Deleted by User (4-digit User)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaasNsD31t <header>[#aaaa NidiiiiDBiiii]	CARD DELETED BY USER CRD=iiii ID=iiii
87	Card Deleted by Programmer	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaasNsD31t <header>[#aaaa NpiddDBiiii]	CARD DELETED BY PROGRAMMER CRD=iii-x SDI=ddd
88	Card Deleted by Programmer (4-digit User)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaasNsD31t <header>[#aaaa NpiddDBiiii]	CARD DELETED BY PROGRAMMER CRD=iiii SDI=ddd
89	Card Deleted by Remote	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaasNsD31t <header>[#aaaa NDBiiii]	CARD DELETED BY REMOTE CRD=iii-x
90	Card Deleted by Remote (4-digit User)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaasNsD31t <header>[#aaaa NDBiiii]	CARD DELETED BY REMOTE CRD=iiii
91	Checksum Fail	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrrlssssssaaasAsD12t <header>[#aaaa NYX]	CHECKSUM FAIL
92	Checksum Fail (Device Specific)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaasAsD12t <header>[#aaaa NpiddYYX]	CHECKSUM FAIL SDI=ddd
93	Closing by Account (No Area)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaasCsiiit <header>[#aaaa NidiiicL]	CLOSING REPORT ID=iiii
94	Closing by Area	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaasCsiiit <header>[#aaaa Nria/idiiicL]	CLOSING REPORT AREA=a ID=iiii
95	Closing by Area (No User)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaasCsssst <header>[#aaaa NriaCL]	CLOSING REPORT AREA=a

**Table 98: Modem4/ModemIIla<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
96 Closing by Area (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasCiiit <header>[#aaaa Nriaa/idiiiCL]	CLOSING REPORT AREA=aa ID=iiii
97 Closing Early by Area	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasCsiiit <header>[#aaaa Nriaa/idiiicK]	CLOSING EARLY AREA=a ID=iii
98 Closing Early by Area (No User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasCsssst <header>[#aaaa NriaCK]	CLOSING EARLY AREA=a
99 Closing Early by Area (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasCiiit <header>[#aaaa Nriaa/idiiicK]	CLOSING EARLY AREA=aa ID=iiii
100 Closing Late by Area	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasCsiiit <header>[#aaaa Nriaa/idiiicJ]	CLOSING LATE AREA=a ID=iii
101 Closing Late by Area (No User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasCsssst <header>[#aaaa NriaCJ]	CLOSING LATE AREA=a
102 Closing Late by Area (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasCiiit <header>[#aaaa Nriaa/idiiicJ]	CLOSING LATE AREA=aa ID=iiii
103 Command Bypass	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa COMMAND BYPASS +++ACC aaaa h1rrrlssssssaaaasNspppt <header>[#aaaa Nriaa/idiiiUBppp]	COMMAND BYPASS AREA=a ID=iii POINT=ppp
104 Command Bypas (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa COMMAND BYPASS +++ACC aaaa h1rrrlssssssaaaasNspppt <header>[#aaaa Nriaa/idiiiUBppp]	COMMAND BYPASS AREA=a ID=iiii POINT=ppp
105 Command Bypas (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa COMMAND BYPASS +++ACC aaaa h1rrrlssssssaaaasNppppt <header>[#aaaa Nriaa/idiiiUBpppp]	COMMAND BYPASS AREA=aa ID=iii POINT=pppp
106 Command Bypas (4-digit User / Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa COMMAND BYPASS +++ACC aaaa h1rrrlssssssaaaasNppppt <header>[#aaaa Nriaa/idiiiUBpppp]	COMMAND BYPASS AREA=aa ID=iiii POINT=pppp
107 Comm Fail / Phone Line	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa COMM FAIL +++ACC aaaa h1rrrlssssssaaaasTsB01t <header>[#aaaa NphhhYK]	COMM FAIL PH#=hh
108 Comm Fail / Route Group	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa COMM FAIL +++ACC aaaa h1rrrlssssssaaaasTsB01t <header>[#aaaa NrggYC]	COMM FAIL RG=g
109 Comm Fail / Route Group (Device Specific)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa COMM FAIL +++ACC aaaa h1rrrlssssssaaaasTsB01t <header>[#aaaa Nrgg/pidddyYC]	COMM FAIL RG=g SDI=ddd
110 Comm Fail Restoral / Phone Line	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa COMM FAIL RESTR +++ACC aaaa h1rrrlssssssaaaasNsB01t <header>[#aaaa NphhhYK]	COMM FAIL RESTR PH#=hh
111 Comm Fail Restoral / Route Group	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa COMM FAIL RESTR +++ACC aaaa h1rrrlssssssaaaasNsB01t <header>[#aaaa NrggYK]	COMM FAIL RESTR RG=g
112 Comm Fail Restoral / Route Group (Device Specific)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa COMM FAIL RESTR +++ACC aaaa h1rrrlssssssaaaasNsB01t <header>[#aaaa Nrgg/pidddyYK]	COMM FAIL RESTR RG=g SDI=ddd
113 Comm Trouble / Phone Line	Printer : D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa COMM TROUBLE +++ACC aaaa h1rrrlssssssaaaasTsB01t <header>[#aaaa NphhhYS]	COMM TROUBLE PH#=hh

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

	<b>Event</b>	<b>Device/Mode</b>	<b>Display/Explanation</b>	<b>Comments</b>
114	Comm Trouble / Route Group (Device Specific)	Printer : D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasTsB01t <header>[#aaaa Nrgg/pidddYS]	COMM TROUBLE RG=g SDI=ddd
115	Comm Trouble Restoral / Phone Line	Printer : D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasNsB01t <header>[#aaaa NphhhYK]	COMM TRBL RESTR PH#=hh
116	Comm Trouble Restoral / Route Group (Device Specific)	Printer : D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasNsB01t <header>[#aaaa Nrgg/pidddYK]	COMM TRBL RESTR RG=g SDI=ddd
117	Create Status Report	Printer : D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrrlssssssaaaasSsssst <header>[#aaaa NYY]	STATUS REPORT
118	Custom Function by Custom Fuction	Printer : D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa BY CUSTOM FUNCTION +++ACC aaaa CUST.FX=fff AREA=aa ICF=fff h1rrrlssssssaaaasNsD39t <header>[#aaaa Nrria/cffffCXfff]	CUSTOM FUNCTION
119	Custom Function by SKED	Printer : D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa BY SKED +++ACC aaaa CUST.FX=fff AREA=aa SKED=kkk h1rrrlssssssaaaasNsD39t <header>[#aaaa Nrria/aikkkCXfff]	CUSTOM FUNCTION
120	Custom Function by User	Printer : D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa BY USER +++ACC aaaa CUST.FX=fff AREA=aa ID=iii h1rrrlssssssaaaasNsD39t <header>[#aaaa Nrria/iidiiCXfff]	CUSTOM FUNCTION
121	Custom Function by User (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa CUSTOM FUNCTION +++ACC aaaa BY USER +++ACC aaaa CUST.FX=fff AREA=aa ID=iii h1rrrlssssssaaaasNsD39t <header>[#aaaa Nrria/idiiiCXfff]	CUSTOM FUNCTION
122	Custom Function by User (No User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa CUSTOM FUNCTION +++ACC aaaa BY USER +++ACC aaaa CUST.FX=fff AREA=aa h1rrrlssssssaaaasNsD39t <header>[#aaaa NrriaCXfff]	CUSTOM FUNCTION
123	Date Changed by User	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DATE CHANGED +++ACC aaaa ID=iii h1rrrlssssssaaaasNsD07t <header>[#aaaa NidiiiJD]	DATE CHANGED
124	Date Changed	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DATE CHANGED h1rrrlssssssaaaasNsD07t <header>[#aaaa NJD]	DATE CHANGED
125	Date Changed by User (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DATE CHANGED +++ACC aaaa ID=iii h1rrrlssssssaaaasNsD07t <header>[#aaaa NidiiiJD]	DATE CHANGED
126	Door Closed / Restoral	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa REST-DR CLOSED +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaasRppt <header>[#aaaa NrriaDhppp]	REST-DR CLOSED
127	Door Closed / Restoral (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa REST-DR CLOSED +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaasRppt <header>[#aaaa NrriaDhppp]	REST-DR CLOSED
128	Door Cycled	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DOOR CYCLED +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaasGsppt <header>[#aaaa NrriaDGppp]	DOOR CYCLED
129	Door Cycled by Programmer	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DOOR CYCLED +++ACC aaaa BY PROGRAMMER +++ACC aaaa AREA=a POINT=ppp SDI=ddd h1rrrlssssssaaaasGsppt <header>[#aaaa Nrria/pidddDGppp]	DOOR CYCLED
130	Door Cycled by Programmer (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DOOR CYCLED +++ACC aaaa BY PROGRAMMER +++ACC aaaa AREA=aa POINT=pppp SDI=ddd h1rrrlssssssaaaasGpppt <header>[#aaaa Nrria/pidddDGppp]	DOOR CYCLED

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
131 Door Cycled by Remote	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaAGspppt <header>[#aaaa NriaDGppp]	DOOR CYCLED BY REMOTE AREA=a POINT=PPP
132 Door Cycled by Remote (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaAGppppt <header>[#aaaa NriaaDGppp]	DOOR CYCLED BY REMOTE AREA=aa POINT=PPPP
133 Door Cycled by User	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaAGspppt <header>[#aaaa Nria/iidiiiDGppp]	DOOR CYCLED BY USER AREA=a ID=iii POINT=PPP
134 Door Cycled by User (4-digit User)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaAGspppt <header>[#aaaa Nria/idiiiiDGppp]	DOOR CYCLED BY USER AREA=a ID=iiii POINT=PPP
135 Door Cycled by User (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaAGppppt <header>[#aaaa Nriaa/idiiiiDGppp]	DOOR CYCLED BY USER AREA=aa ID=iii POINT=PPPP
136 Door Cycled by User (4-digit User / Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaAGppppt <header>[#aaaa Nriaa/idiiiiDGppp]	DOOR CYCLED BY USER AREA=aa ID=iiii POINT=PPPP
137 Door Cycled by User (No User)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaAGspppt <header>[#aaaa NriaDGppp]	DOOR CYCLED BY USER AREA=a POINT=PPP
138 Door Locked / Automatic	Printer :  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaALspppt <header>[#aaaa NriaDYppp]	DOOR LOCKED AUTOMATIC AREA=a POINT=PPP
139 Door Locked / Automatic (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaALppppt <header>[#aaaa NriaaDYpppp]	DOOR LOCKED AUTOMATIC AREA=aa POINT=PPPP
140 Door Locked by Programmer	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaALspppt <header>[#aaaa Nria/pidddDYppp]	DOOR LOCKED BY PROGRAMMER AREA=a POINT=PPP SDI=ddd
141 Door Locked by Programmer (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaALppppt <header>[#aaaa Nriaa/pidddDYpppp]	DOOR LOCKED BY PROGRAMMER AREA=aa POINT=PPPP SDI=ddd
142 Door Locked by Remote	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaALspppt <header>[#aaaa NriaDYppp]	DOOR LOCKED BY REMOTE AREA=a POINT=PPP
143 Door Locked by Remote (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaALppppt <header>[#aaaa NriaaDYpppp]	DOOR LOCKED BY REMOTE AREA=aa POINT=PPPP
144 Door Locked by SKED	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaALspppt <header>[#aaaa Nria/aikkkDYppp]	DOOR LOCKED BY SKED AREA=a POINT=PPP SKED=kkk
145 Door Locked by SKED (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaALppppt <header>[#aaaa Nriaa/aikkkDYppp]	DOOR LOCKED BY SKED AREA=aa POINT=PPPP SKED=kkk

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

	<b>Event</b>	<b>Device/Mode</b>	<b>Display/Explanation</b>	<b>Comments</b>
146	Door Locked by User	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa AREA=a ID=iii POINT=ppp h1rrlssssssaaaaALsppt <header>[#aaaa Nriaa/idiiiDYppp]	
147	Door Locked by User (4-digit Point)	Printer : D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa AREA=aa ID=iii POINT=pppp h1rrlssssssaaaaALpppt <header>[#aaaa Nriaa/idiiiDYppp]	
148	Door Locked by User (4-digit User / Point)	Printer : D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa AREA=aa ID=iyyy POINT=pppp h1rrlssssssaaaaALpppt <header>[#aaaa Nriaa/idiiiiDYppp]	
149	Door Locked by User (No User)	Printer : D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa AREA=a POINT=ppp h1rrlssssssaaaaALsppt <header>[#aaaa NriaaDYppp]	
150	Door Locked by User (No User / 4-digit Point)	Printer : D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa AREA=aa POINT=pppp h1rrlssssssaaaaALpppt <header>[#aaaa NriaaDYppp]	
151	Door Locked (4-digit Point)	Printer : D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa AREA=aa POINT=pppp h1rrlssssssaaaaALpppt <header>[#aaaa NriaaDYppp]	
152	Door Request To Enter	Printer : D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa REQUEST TO ENTR h1rrlssssssaaaaAGsppt <header>[#aaaa NriaDEppp]	
153	Door Request To Enter (4-digit Point)	Printer : D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa REQUEST TO ENTR h1rrlssssssaaaaAGpppt <header>[#aaaa NriaaDEppp]	
154	Door Request To Exit	Printer : D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa REQUEST TO EXIT h1rrlssssssaaaaAGsppt <header>[#aaaa NriaDXppp]	
155	Door Request To Exit (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa REQUEST TO EXIT h1rrlssssssaaaaAGpppt <header>[#aaaa NriaADXppp]	
156	Door Request To Enter Denied (Door Secured)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa REQUEST TO ENTR h1rrlssssssaaaaADsppt <header>[#aaaa NriaDKppp]	
157	Door Request To Enter Denied (Door Secured) (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa REQUEST TO ENTR h1rrlssssssaaaaADpppt <header>[#aaaa NriaaDKppp]	
158	Door Request To Enter Denied (Interlock)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa REQUEST TO ENTR h1rrlssssssaaaaADsppt <header>[#aaaa NriaDKppp]	
159	Door Request To Enter Denied (Interlock) (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa REQUEST TO ENTR h1rrlssssssaaaaADpppt <header>[#aaaa NriaaDKppp]	
160	Door Request To Exit Denied (Door Secured)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa REQUEST TO EXIT h1rrlssssssaaaaADsppt <header>[#aaaa NriaDKppp]	
161	Door Request To Exit Denied (Door Secured) (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa REQUEST TO EXIT h1rrlssssssaaaaADpppt <header>[#aaaa NriaaDKppp]	

**Table 98: Modem4/ModemIlla<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
162 Door Request To Exit Denied (Interlock)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaADspppt <header>[#aaaa NriaaDkppp]	REQUEST TO EXIT DENIED-INTERLOCK AREA=a POINT=PPP
163 Door Request To Exit Denied (Interlock) (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaADppppt <header>[#aaaa NriaaDkppp]	REQUEST TO EXIT DENIED-INTERLOCK AREA=aa POINT=PPPP
164 Door Secured	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaASspppt <header>[#aaaa NriaaDCppp]	DOOR SECURED AREA=a POINT=PPP
165 Door Secured (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaASppppt <header>[#aaaa NriaaDCppp]	DOOR SECURED AREA=aa POINT=PPPP
166 Door Secured / Automatic	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaASspppt <header>[#aaaa NriaaDCppp]	DOOR SECURED AUTOMATIC AREA=a POINT=PPP
167 Door Secured / Automatic (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaASppppt <header>[#aaaa NriaaDCppp]	DOOR SECURED AUTOMATIC AREA=aa POINT=PPPP
168 Door Secured by Programmer	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaASspppt <header>[#aaaa Nriaa/pidddDCppp]	DOOR SECURED BY PROGRAMMER AREA=a POINT=PPP SDI=ddd
169 Door Secured by Programmer (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaASppppt <header>[#aaaa Nriaa/pidddDCppp]	DOOR SECURED BY PROGRAMMER AREA=aa POINT=PPPP SDI=ddd
170 Door Secured by Remote	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaASspppt <header>[#aaaa NriaaDCppp]	DOOR SECURED BY REMOTE AREA=a POINT=PPP
171 Door Secured by Remote (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaASppppt <header>[#aaaa NriaaDCppp]	DOOR SECURED BY REMOTE AREA=aa POINT=PPPP
172 Door Secured by SKED	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaASspppt <header>[#aaaa Nriaa/aikkkDCppp]	DOOR SECURED BY SKED AREA=a POINT=PPP SKED=kkk
173 Door Secured by SKED (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaASppppt <header>[#aaaa Nriaa/aikkkDCppp]	DOOR SECURED BY SKED AREA=aa POINT=PPPP SKED=kkk
174 Door Secured by User	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaASspppt <header>[#aaaa Nriaa/idiiiDCppp]	DOOR SECURED BY USER AREA=a ID=iii POINT=PPP
175 Door Secured by User (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaASspppt <header>[#aaaa Nriaa/idiiiDCppp]	DOOR SECURED BY USER AREA=a ID=iii POINT=PPP
176 Door Secured by User (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaASppppt <header>[#aaaa Nriaa/idiiiDCppp]	DOOR SECURED BY USER AREA=aa ID=iii POINT=PPPP

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
177 Door Secured by User (4-digit User / Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DOOR SECURED +++ACC aaaa BY USER +++ACC aaaa AREA=aa ID=iiii POINT=pppp h1rrrlssssssaaaaASpppt <header>[#aaaa Nriaa/idiiiiDCpppp]	
178 Door Secured by User (No User)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DOOR SECURED +++ACC aaaa BY USER +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaaASpppt <header>[#aaaa NriaaDCppp]	
179 Door Secured by User (No User / 4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DOOR SECURED +++ACC aaaa BY USER +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaASpppt <header>[#aaaa NriaaDCpppp]	
180 Door Unlocked	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DOOR UNLOCKED +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaaAUsppt <header>[#aaaa NriaaDOppp]	
181 Door Unlocked (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DOOR UNLOCKED +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaAUpppt <header>[#aaaa NriaaDOpppp]	
182 Door Unlocked / Automatic	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DOOR UNLOCKED +++ACC aaaa AUTOMATIC +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaaAUsppt <header>[#aaaa NriaaDOppp]	
183 Door Unlocked / Automatic (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DOOR UNLOCKED +++ACC aaaa AUTOMATIC +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaAUpppt <header>[#aaaa NriaaDOpppp]	
184 Door Unlocked by Programmer	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DOOR UNLOCKED +++ACC aaaa BY PROGRAMMER +++ACC aaaa AREA=a POINT=ppp SDI=ddd h1rrrlssssssaaaaAUsppt <header>[#aaaa Nria/pidddDOppp]	
185 Door Unlocked by Programmer (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DOOR UNLOCKED +++ACC aaaa BY PROGRAMMER +++ACC aaaa AREA=aa POINT=pppp SDI=ddd h1rrrlssssssaaaaAUpppt <header>[#aaaa Nriaa/pidddDOpppp]	
186 Door Unlocked by Remote	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DOOR UNLOCKED +++ACC aaaa BY REMOTE +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaaAUsppt <header>[#aaaa NriaaDOppp]	
187 Door Unlocked by Remote (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DOOR UNLOCKED +++ACC aaaa BY REMOTE +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaAUpppt <header>[#aaaa NriaaDOpppp]	
188 Door Unlocked by SKED	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DOOR UNLOCKED +++ACC aaaa BY SKED +++ACC aaaa AREA=a POINT=ppp SKED=kkk h1rrrlssssssaaaaAUsppt <header>[#aaaa Nria/aikkDOppp]	
189 Door Unlocked by SKED (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DOOR UNLOCKED +++ACC aaaa BY SKED +++ACC aaaa AREA=aa POINT=pppp SKED=kkk h1rrrlssssssaaaaAUpppt <header>[#aaaa Nria/aikkDOpppp]	
190 Door Unlocked by User	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DOOR UNLOCKED +++ACC aaaa BY USER +++ACC aaaa AREA=a ID=iii POINT=ppp h1rrrlssssssaaaaAUsppt <header>[#aaaa Nria/idiiiDOppp]	
191 Door Unlocked by User (4-digit User)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DOOR UNLOCKED +++ACC aaaa BY USER +++ACC aaaa AREA=a ID=iiii POINT=ppp h1rrrlssssssaaaaAUsppt <header>[#aaaa Nria/idiiiiDOppp]	

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
192 Door Unlocked by User (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DOOR UNLOCKED +++ACC aaaa BY USER +++ACC aaaa AREA=aa ID=iii POINT=pppp h1rrrlssssssaaaaAUpppt <header>[#aaaa Nriaa/idiiiDOppp]	
193 Door Unlocked by User (4-digit User / Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DOOR UNLOCKED +++ACC aaaa BY USER +++ACC aaaa AREA=aa ID=iiii POINT=pppp h1rrrlssssssaaaaAUpppt <header>[#aaaa Nriaa/idiiiiDOppp]	
194 Door Unlocked by User (No User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DOOR UNLOCKED +++ACC aaaa BY USER +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaaAUsppt <header>[#aaaa NriaaDOppp]	
195 Door Unlocked by User (No User / 4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DOOR UNLOCKED +++ACC aaaa BY USER +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaAUpppt <header>[#aaaa NriaaDOppp]	
196 Duress	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DURESS +++ACC aaaa AREA=a ID=iii h1rrrlssssssaaaaasDsiiit <header>[#aaaa Nriaa/idiiiiHA]	
197 Duress (No Area)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DURESS +++ACC aaaa ID=iii h1rrrlssssssaaaaasDsiiit <header>[#aaaa NidiiiiHA]	
198 Duress (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DURESS +++ACC aaaa AREA=aa ID=iiii h1rrrlssssssaaaaasDiiii <header>[#aaaa Nriaa/idiiiiHA]	
199 Early to Close (No Area)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa CLOSING EARLY h1rrrlssssssaaaaCssts <header>[#aaaa NCK]	
200 Early To Open (No Area)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa EARLY TO OPEN h1rrrlssssssaaaaOssts <header>[#aaaa NOK]	
201 Equipment Fail	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa EQUIPMENT FAIL +++ACC aaaa SDI=ddd COND=nnn h1rrrlssssssaaaaasTsD29t <header>[#aaaa NpiddlAnnn]	
202 Equipment Restoral	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa EQUIP RESTORAL +++ACC aaaa SDI=ddd COND=nnn h1rrrlssssssaaaaasRsD29t <header>[#aaaa NpiddlRnnn]	
203 Extend Close Time by Area (No User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa EXTN CLOSE TIME +++ACC aaaa AREA=a TIME=hh:mm h1rrrlssssssaaaaasTsD26t <header>[#aaaa Nria/tihhmmCE]	
204 Extend Close Time by Area	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa EXTN CLOSE TIME +++ACC aaaa AREA=a ID=iii TIME=hh:mm h1rrrlssssssaaaaasTsD26t <header>[#aaaa Nriaa/idiii/tihhmmCE]	
205 Extend Close Time by Area (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa EXTN CLOSE TIME +++ACC aaaa AREA=aa ID=iiii TIME=hh:mm h1rrrlssssssaaaaasTsD26t <header>[#aaaa Nriaa/idiiii/tihhmmCE]	
206 External Device	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa EXTERNAL DEVICE +++ACC aaaa EXT.DEV=ddd COND=nnn h1rrrlssssssaaaaasNsD50t <header>[#aaaa NpiddlEXnnn]	
207 Extra Account	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa EXTRA ACCOUNT +++ACC aaaa PATH=ppp COND=nnn h1rrrlssssssaaaaasNsD46t <header>[#aaaa NpapppxAnnn]	
208 Extra Point	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa EXTRA POINT +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaaasTsppt <header>[#aaaa NriaXEppp]	
209 Extra Point (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa EXTRA POINT +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaasTppt <header>[#aaaa NriaaXEppp]	

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
210 Extra RF Point	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasTsD16t <header>[#aaaa NpiddDXF]	EXTRA RF POINT SDI=ddd
211 Extra RF Point (7112 Only)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasTsD16t <header>[#aaaa NXF]	EXTRA RF POINT
212 Fail To Call RPS	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasTsF02t <header>[#aaaa NRA]	BAD CALL TO RAM
213 Fail To Close by Area	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasTsssEt <header>[#aaaa NriaCI]	FAIL TO CLOSE AREA=a
214 Fail To Close / Delinquent	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasTsssEt <header>[#aaaa NriaCD]	DELNQNT CLOSING AREA=a
215 Fail to Execute / Door Unlocked (Interlock)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasNsD35t <header>[#aaaa NriaDKppp]	FAIL TO EXECUTE DOOR UNLOCKED-INTERLOCK AREA=a POINT=ppp
216 Fail to Execute / Door Unlocked (Interlock) (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasNsD35t <header>[#aaaa NriaaDKpppp]	FAIL TO EXECUTE DOOR UNLOCKED-INTERLOCK AREA=aa POINT=pppp
217 Fail to Execute / Door Unlocked (Door Secured)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasNsD35t <header>[#aaaa NriaDKppp]	FAIL TO EXECUTE DOOR UNLOCKED-DOOR SECURE AREA=a POINT=ppp
218 Fail to Execute / Door Unlocked (Door Secured) (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasNsD35t <header>[#aaaa NriaaDKpppp]	FAIL TO EXECUTE DOOR UNLOCKED-DOOR SECURE AREA=aa POINT=pppp
219 Fail to Execute / Door Cycled (Door Secured)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaADspppt <header>[#aaaa NriaDKppp]	FAIL TO EXECUTE DOOR CYCLED-DOOR SECURED AREA=a POINT=ppp
220 Fail to Execute / Door Cycled (Door Secured) (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaADppppt <header>[#aaaa NriaaDKpppp]	FAIL TO EXECUTE DOOR CYCLED-DOOR SECURED AREA=aa POINT=pppp
221 Fail to Execute / Door Cycled (Interlock)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaADspppt <header>[#aaaa NriaaDKppp]	FAIL TO EXECUTE DOOR CYCLED-INTERLOCK AREA=a POINT=ppp
222 Fail to Execute / Door Cycled (Interlock) (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaADppppt <header>[#aaaa NriaaDKpppp]	FAIL TO EXECUTE DOOR CYCLED-INTERLOCK AREA=aa POINT=pppp
223 Fail to Execute (Incorrect Response)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasNsD34t <header>[#aaaa NpiddYX]	FAIL TO EXECUTE INCORRECT RESPONSE SDI=ddd
224 Fail to Execute (No Response)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasNsD34t <header>[#aaaa NpiddYX]	FAIL TO EXECUTE NO RESPONSE SDI=ddd
225 Fail To Open by Area	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasTsssEt <header>[#aaaa NriaOI]	FAIL TO OPEN AREA=a

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
226 Fire Alarm	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasFsppt <header>[#aaaa NriaFAppp]	FIRE ALARM AREA=a POINT=ppp 7
227 Fire Alarm (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasFpppt <header>[#aaaa NriaaFAppp]	FIRE ALARM AREA=aa POINT=pppp
228 Fire Alarm (2112/2212)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasFsppt <header>[#aaaa NFAppp]	FIRE ALARM POINT=ppp
229 Fire Alarm / Cross Point	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasFsppt <header>[#aaaa NriaFMppp]	FIRE ALARM CROSS POINT AREA=a POINT=ppp
230 Fire Alarm / Cross Point (2112/2212)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasFsppt <header>[#aaaa NFMppp]	FIRE ALARM CROSS POINT POINT=ppp
231 Fire Alarm / Cross point (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasFpppt <header>[#aaaa NriaaFMppp]	FIRE ALARM CROSS POINT AREA=aa POINT=pppp
232 Fire Alarm / Smoke Detector	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasFsppt <header>[#aaaa NriaFAppp]	FIRE ALARM SMOKE DETECTOR AREA=a POINT=ppp
233 Fire Alarm / Smoke Detector (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasFpppt <header>[#aaaa NriaaFAppp]	FIRE ALARM SMOKE DETECTOR AREA=aa POINT=pppp
234 Fire Alarm / High Temp Sensor	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasFsppt <header>[#aaaa NriaKAppp]	FIRE ALARM HIGH TEMPERATURE SENSOR AREA=a POINT=ppp
235 Fire Alarm / High Temp Sensor (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasFpppt <header>[#aaaa NriaaKAppp]	FIRE ALARM HIGH TEMPERATURE SENSOR AREA=aa POINT=pppp
236 Fire Alarm / Waterflow Sensor	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasFsppt <header>[#aaaa NriaSAApp]	FIRE ALARM WATER FLOW SENSOR AREA=a POINT=ppp
237 Fire Alarm / Waterflow Sensor (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasFpppt <header>[#aaaa NriaaSAApp]	FIRE ALARM WATER FLOW SENSOR AREA=aa POINT=pppp
238 Fire Cancel	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaas\iiit <header>[#aaaa Nria/iidiiFC]	FIRE CANCEL AREA=a ID=iiii
239 Fire Cancel (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaas\iiit <header>[#aaaa Nriaa/iidiiFC]	FIRE CANCEL AREA=aa ID=iiii
240 Fire Missing	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasMspppt <header>[#aaaa NriaFYppp]	MISSING FIRE AREA=a POINT=ppp 7
241 Fire Missing (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasMpppt <header>[#aaaa NriaaFYppp]	MISSING FIRE AREA=aa POINT=pppp

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

	<b>Event</b>	<b>Device/Mode</b>	<b>Display/Explanation</b>	<b>Comments</b>
242	Fire Alarm Restoral (No Area)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FIRE ALM RESTOR +++ACC aaaa POINT=ppp h1rrlssssssaaaaHsspppt <header>[#aaaa NFHppp]	
243	Fire Alarm Restoral	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FIRE ALM RESTOR +++ACC aaaa AREA=a POINT=ppp h1rrlssssssaaaaHsspppt <header>[#aaaa NriaFHppp]	
244	Fire Alarm Restoral (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FIRE ALM RESTOR +++ACC aaaa AREA=aa POINT=pppp h1rrlssssssaaaaHsspppt <header>[#aaaa NriaaFHppp]	
245	Fire Restoral (Trouble/Missing/Supervision)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FIRE TBL RESTOR +++ACC aaaa AREA=a POINT=ppp h1rrlssssssaaaaHsspppt <header>[#aaaa NriaFJppp]	
246	Fire Restoral (Trouble/Missing/Supervision) (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FIRE TBL RESTOR +++ACC aaaa AREA=aa POINT=pppp h1rrlssssssaaaaHsspppt <header>[#aaaa NriaaFJppp]	
247	Fire Supervision	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FIRE SUPRVISION +++ACC aaaa AREA=a POINT=PPP h1rrlssssssaaaasEspppt <header>[#aaaa NriaaFSppp]	
248	Fire Supervision (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FIRE SUPRVISION +++ACC aaaa AREA=aa POINT=PPPP h1rrlssssssaaaasEppppt <header>[#aaaa NriaaFSppp]	
249	Fire Supervision / Waterflow Sensor	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FIRE SUPRVISION +++ACC aaaa WATER FLOW SENSOR +++ACC aaaa AREA=a POINT=ppp h1rrlssssssaaaasEspppt <header>[#aaaa NriaaFSppp]	
250	Fire Supervision / Waterflow Sensor (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FIRE SUPRVISION +++ACC aaaa WATER FLOW SENSOR +++ACC aaaa AREA=aa POINT=pppp h1rrlssssssaaaasEppppt <header>[#aaaa NriaaFSppp]	
251	Fire Supervision Restore	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FIRE SUPRV REST +++ACC aaaa AREA=a POINT=ppp h1rrlssssssaaaasEspppt <header>[#aaaa NriaFVppp]	
252	Fire Supervision Restore (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FIRE SUPRV REST +++ACC aaaa AREA=aa POINT=pppp h1rrlssssssaaaasEppppt <header>[#aaaa NriaaFVppp]	
253	Fire Supervision Restore / Waterflow Sensor	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FIRE SUPRV REST +++ACC aaaa WATER FLOW SENSOR +++ACC aaaa AREA=a POINT=ppp h1rrlssssssaaaasEspppt <header>[#aaaa NriaFVppp]	
254	Fire Supervision Restore / Waterflow Sensor (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FIRE SUPRV REST +++ACC aaaa WATER FLOW SENSOR +++ACC aaaa AREA=aa POINT=pppp h1rrlssssssaaaasEppppt <header>[#aaaa NriaaFVppp]	
255	Fire Supervision Trouble	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FIRE SUPRV TRBL +++ACC aaaa AREA=a POINT=PPP h1rrlssssssaaaaGsspppt <header>[#aaaa NriaFWppp]	
256	Fire Supervision Trouble (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FIRE SUPRV TRBL +++ACC aaaa AREA=aa POINT=pppp h1rrlssssssaaaaGsspppt <header>[#aaaa NriaaFWppp]	
257	Fire Supervision Trouble / Waterflow Sensor	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FIRE SUPRV TRBL +++ACC aaaa WATER FLOW SENSOR +++ACC aaaa AREA=a POINT=ppp h1rrlssssssaaaaGsspppt <header>[#aaaa NriaFWppp]	
258	Fire Supervision Trouble / Waterflow Sensor (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FIRE SUPRV TRBL +++ACC aaaa WATER FLOW SENSOR +++ACC aaaa AREA=aa POINT=pppp h1rrlssssssaaaaGsspppt <header>[#aaaa NriaaFWppp]	

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

	<b>Event</b>	<b>Device/Mode</b>	<b>Display/Explanation</b>	<b>Comments</b>
259	Fire Supervision Trouble Restore	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaHsspppt <header>[#aaaa NriaFQppp]	FIR SUPR TR RES AREA=a POINT=ppp
260	Fire Supervision Trouble Restore (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaHsspppt <header>[#aaaa NriaaFQppp]	FIR SUPR TR RES AREA=aa POINT=pppp
261	Fire Supervision Trouble Restore / Waterflow Sensor	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaHsspppt <header>[#aaaa NriaFQppp]	FIR SUPR TR RES WATER FLOW SENSOR AREA=a POINT=PPP
262	Fire Supervision Trouble Restore / Waterflow Sensor (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaHsspppt <header>[#aaaa NriaafQppp]	FIR SUPR TR RES WATER FLOW SENSOR AREA=aa POINT=pppp
263	Fire Trouble	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaGsspppt <header>[#aaaa NriaFTppp]	FIRE TROUBLE AREA=a POINT=ppp
264	Fire Trouble (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaGspppt <header>[#aaaa NriaaFTppp]	FIRE TROUBLE AREA=aa POINT=pppp
265	Fire Trouble / Smoke Detector	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaGsspppt <header>[#aaaa NriaFTppp]	FIRE TROUBLE SMOKE DETECTOR AREA=a POINT=ppp
266	Fire Trouble / Smoke Detector (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa <header>[#aaaa NriaaFTppp]	FIRE TROUBLE SMOKE DETECTOR AREA=aa POINT=pppp
267	Fire Trouble / High Temp Sensor	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaGsspppt <header>[#aaaa NriaKTppp]	FIRE TROUBLE HIGH TEMPERATURE SENSOR AREA=a POINT=ppp
268	Fire Trouble / High Temp Sensor (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaGspppt <header>[#aaaa NriaaKTppp]	FIRE TROUBLE HIGH TEMPERATURE SENSOR AREA=aa POINT=pppp
269	Fire Trouble / Waterflow Sensor	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaGsspppt <header>[#aaaa NriaSTppp]	FIRE TROUBLE WATER FLOW SENSOR AREA=a POINT=PPP
270	Fire Trouble / Waterflow Sensor (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaGspppt <header>[#aaaa NriaaSTppp]	FIRE TROUBLE WATER FLOW SENSOR AREA=aa POINT=pppp
271	Fire Trouble / Ground Fault	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaGsspppt <header>[#aaaa NriaFTppp]	FIRE TROUBLE GROUND FAULT AREA=a POINT=ppp
272	Fire Trouble / Ground Fault (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaGspppt <header>[#aaaa NriaafTppp]	FIRE TROUBLE GROUND FAULT AREA=aa POINT=pppp
273	Fire Walk End (No User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaRsstsFt <header>[#aaaa NriaFK]	FIRE WALK END AREA=a
274	Fire Walk End	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaRsstsFt <header>[#aaaa Nria/IdiiifK]	FIRE WALK END AREA=a ID=iii

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
275 Fire Walk End (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FIRE WALK END +++ACC aaaa AREA=aa ID=iiii h1rrrlssssssaaaasRsssFt <header>[#aaaa Nriaa/idiiifK]	
276 Fire Walk Start	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FIRE WALK START +++ACC aaaa AREA=a ID=iii h1rrrlssssssaaaasTsssFt <header>[#aaaa Nriaa/idiiifI]	
277 Fire Walk Start (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FIRE WALK START +++ACC aaaa AREA=aa ID=iiii h1rrrlssssssaaaasTsssFt <header>[#aaaa Nriaa/idiiifI]	
278 Fire Walk Start (No User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FIRE WALK START +++ACC aaaa AREA=a h1rrrlssssssaaaasTsssFt <header>[#aaaa NriaI]	
279 Force Close Early by Area	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FRC CLOSE EARLY +++ACC aaaa AREA=a ID=iii h1rrrlssssssaaaasCsiiit <header>[#aaaa Nriaa/idiiicF]	
280 Force Close Early by Area (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FRC CLOSE EARLY +++ACC aaaa AREA=aa ID=iiii h1rrrlssssssaaaasCsiiit <header>[#aaaa Nriaa/idiiicF]	
281 Force Close Early (7112 Only)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FRC CLOSE EARLY h1rrrlssssssaaaasCsssst <header>[#aaaa NCF]	
282 Force Close Late (7112 Only)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FORC CLOSE LATE h1rrrlssssssaaaasCsssst <header>[#aaaa NCF]	
283 Force Close Late by Area	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FORC CLOSE LATE +++ACC aaaa AREA=a ID=iiii h1rrrlssssssaaaasCsiiit <header>[#aaaa Nriaa/idiiicF]	
284 Force Close Late by Area (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FORC CLOSE LATE +++ACC aaaa AREA=aa ID=iiii h1rrrlssssssaaaasCsiiit <header>[#aaaa Nriaa/idiiicF]	
285 Force Close Perimeter Delay by Area (No User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa F CLOSE PR DLAY +++ACC aaaa AREA=a h1rrrlssssssaaaasCsssst <header>[#aaaa NriaNF]	
286 Force Close Perimeter Delay by Area	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa F CLOSE PR DLAY +++ACC aaaa AREA=a ID=iii h1rrrlssssssaaaasCsiiit <header>[#aaaa Nriaa/idiiinF]	
287 Force Close Perimeter Delay by Area (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa F CLOSE PR DLAY +++ACC aaaa AREA=aa ID=iiii h1rrrlssssssaaaasCsiiit <header>[#aaaa Nriaa/idiiinF]	
288 Force Close Perimeter Instant by Area (No User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa F CLOSE PR INST +++ACC aaaa AREA=a h1rrrlssssssaaaasCsssst <header>[#aaaa NriaNF]	
289 Force Close Perimeter Instant by Area	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa F CLOSE PR INST +++ACC aaaa AREA=a ID=iii h1rrrlssssssaaaasCsiiit <header>[#aaaa Nriaa/idiiinF]	
290 Force Close Perimeter Instant by Area (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa F CLOSE PR INST +++ACC aaaa AREA=aa ID=iiii h1rrrlssssssaaaasCsiiit <header>[#aaaa Nriaa/idiiinF]	
291 Force Close by Area (No Area)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FORCED CLOSE +++ACC aaaa ID=iii h1rrrlssssssaaaasCsiiit <header>[#aaaa NidiiciF]	
292 Force Close by Area	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FORCED CLOSE +++ACC aaaa AREA=a ID=iii h1rrrlssssssaaaasCsiiit <header>[#aaaa Nriaa/idiiicF]	
293 Force Close by Area (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa FORCED CLOSE +++ACC aaaa AREA=aa ID=iiii h1rrrlssssssaaaasCsiiit <header>[#aaaa Nriaa/idiiicF]	

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
294 Force Point	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasTpsspt <header>[#aaaa NriaaXWppp]	FORCED POINT AREA=a POINT=ppp
295 Force Point (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasTpsspt <header>[#aaaa NriaaXWpppp]	FORCED POINT AREA=aa POINT=pppp
296 Gas Alarm (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasApppt <header>[#aaaa NriaaGApppp]	GAS ALARM AREA=aa POINT=pppp
297 Gas Alarm Restore (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRpppt <header>[#aaaa NriaaGHpppp]	GAS ALARM REST AREA=aa POINT=pppp
298 Gas Cancel (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaas\iiit <header>[#aaaa Nriaa/idiiiGC]	GAS CANCEL AREA=aa ID=iiii
299 Gas Missing (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasVpppt <header>[#aaaa NriaaUZpppp]	GAS MISSING AREA=aa POINT=pppp
300 Gas Supervisory (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasJpppt <header>[#aaaa NriaaGSpppp]	GAS SUPERVISORY AREA=aa POINT=pppp
301 Gas Supervisory Restore (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRpppt <header>[#aaaa NriaaGJpppp]	GAS SUPV REST AREA=aa POINT=pppp
302 Gas Trouble (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasTpsspt <header>[#aaaa NriaaGTpppp]	GAS TROUBLE AREA=aa POINT=pppp
303 Gas Trouble Restore (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRpppt <header>[#aaaa NriaaGJpppp]	GAS TRBL REST AREA=aa POINT=pppp
304 High Temp Alarm (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasJpppt <header>[#aaaa NriaaKApppp]	HIGH TEMP ALARM AREA=aa POINT=pppp
305 High Temp Alarm Restore (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRpppt <header>[#aaaa NriaaKHpppp]	HIGH TEMP REST AREA=aa POINT=pppp
306 Hold-Up Alarm (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasDpppt <header>[#aaaa NriaaHApppp]	HOLD-UP ALARM AREA=aa POINT=pppp
307 Hold-Up Missing (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasVpppt <header>[#aaaa NriaaUZpppp]	HOLD-UP MISSING AREA=aa POINT=pppp
308 Hold-Up Restore (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRpppt <header>[#aaaa NriaaHRpppp]	HOLD-UP RESTORE AREA=aa POINT=pppp
309 Hold-Up Supervisory (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasJpppt <header>[#aaaa NriaaHSpppp]	HOLD-UP SUPV AREA=aa POINT=pppp
310 Hold-Up Supervisory Restore (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRpppt <header>[#aaaa NriaaHRpppp]	HOLD-UP SU REST AREA=aa POINT=pppp
311 Hold-Up Trouble (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasTpsspt <header>[#aaaa NriaaHTpppp]	HOLD-UP TROUBLE AREA=aa POINT=pppp
312 Hold-Up Trouble Restore (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRpppt <header>[#aaaa NriaaHTpppp]	HOLD-UP TR REST AREA=aa POINT=pppp

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
313 Late To Open (7112 Only)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrrlssssssaaaasOsssst <header>[#aaaa NOJ]	LATE TO OPEN
314 Listen In	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaas*sssst <header>[#aaaa NtihhmmLF]	LISTEN IN TIME=hh:mm
315 Log Overflow	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrrlssssssaaaasDs01t <header>[#aaaa NJO]	LOG OVERFLOW
316 Log Threshold	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrrlssssssaaaasTsD01t <header>[#aaaa NJL]	LOG THRESHOLD
317 Low Signal Strength	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasNsD48t <header>[#aaaa Nlv111/pappXL]	LOW SIGNAL LEVL LEVEL=111 PATH=ppp
318 Low Temperature Alarm	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasLsppt <header>[#aaaa NriaZapp]	LOW TEMPERATURE AREA=a POINT=ppp
319 Low Temperature Alarm (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasLpppt <header>[#aaaa NriaaZApppp]	LOW TEMPERATURE AREA=aa POINT=pppp
320 Low Temperature Restoral	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasLsppt <header>[#aaaa NriaZRppp]	LOW TEMP RESTOR AREA=a POINT=ppp
321 Low Temperature Restoral (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasLpppt <header>[#aaaa NriaaZRppp]	LOW TEMP RESTOR AREA=aa POINT=pppp
322 Medical Alarm by User (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasUiilit <header>[#aaaa NidiiiiMA]	MEDICAL ALARM ID=iiii New Message
323 Medical Alarm by Point (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasApppt <header>[#aaaa Nriaa MApppp]	MEDICAL ALARM AREA=aa POINT=pppp New Message
324 Medical Alarm Restore (4-digit User / Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRpppt <header>[#aaaa Nriaa MHpppp]	MED ALARM REST AREA=aa POINT=pppp New Message
325 Memory Fail	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrrlssssssaaaasAsD13t <header>[#aaaa NYX]	MEMORY FAIL
326 Missing Alarm (2212)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasMspppt <header>[#aaaa NUZppp]	MISSING ALARM POINT=ppp
327 Missing Alarm	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasMspppt <header>[#aaaa NriaaUZppp]	MISSING ALARM AREA=a POINT=ppp
328 Missing Alarm (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasMpppt <header>[#aaaa NriaaUZpppp]	MISSING ALARM AREA=aa POINT=pppp
329 Missing Alarm / Cross Point	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasMspppt <header>[#aaaa NriaXMppp]	MISSING ALARM CROSS POINT AREA=a CG=gg POINT=ppp
330 Missing Alarm / Cross Point (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasMpppt <header>[#aaaa NriaXMpppp]	MISSING ALARM CROSS POINT AREA=aa CG=gg POINT=pppp
331 Missing Alarm from Recent Closing (2 min of close) (No User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasMspppt <header>[#aaaa NriaCMppp]	MISSING ALARM RECENT CLOSING AREA=a POINT=ppp

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
332 Missing Alarm from Recent Closing (2 min of close) (No User / 4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasMpppt <header>[#aaaa NriaaCMpppt]	MISSING ALARM RECENT CLOSING AREA=aa POINT=pppp
333 Missing Alarm from Recent Closing (2 min of close)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasMsppt <header>[#aaaa Nria/iidiiiCMppp]	MISSING ALARM RECENT CLOSING AREA=a ID=iii POINT=ppp
334 Missing Alarm from Recent Closing (2 min of close) (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasMpppt <header>[#aaaa Nriaa/idiiiiCMppp]	MISSING ALARM RECENT CLOSING AREA=aa ID=iii POINT=pppp
335 Missing Alarm from Recent Closing (2 min of close) (4-digit User / Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasMpppt <header>[#aaaa Nriaa/idiiiiCMppp]	MISSING ALARM RECENT CLOSING AREA=aa ID=iiii POINT=pppp
336 Missing Alarm Exit Error (No User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasMsppt <header>[#aaaa NriaEZppp]	MISSING ALARM EXIT ERROR AREA=a POINT=ppp
337 Missing Alarm Exit Error (No User / 4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasMpppt <header>[#aaaa NriaaEZppp]	MISSING ALARM EXIT ERROR AREA=aa POINT=pppp
338 Missing Alarm Exit Error	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasMsppt <header>[#aaaa Nria/iidiiiEZppp]	MISSING ALARM EXIT ERROR AREA=a ID=iii POINT=ppp
339 Missing Alarm Exit Error (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasMpppt <header>[#aaaa Nriaa/idiiiiEZppp]	MISSING ALARM EXIT ERROR AREA=aa ID=iii POINT=pppp
340 Missing Alarm Exit Error (4-digit User / Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasMpppt <header>[#aaaa Nriaa/idiiiiEZppp]	MISSING ALARM EXIT ERROR AREA=aa ID=iiii POINT=pppp
341 Missing Fire Supervision	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasGMsppt <header>[#aaaa NriaFZppp]	MISS FIR SUPRVN AREA=a POINT=ppp
342 Missing Fire Supervision (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasGMpppt <header>[#aaaa NriaaFZppp]	MISS FIR SUPRVN AREA=aa POINT=pppp
343 Missing Fire Supervision / Waterflow Sensor	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasGMsppt <header>[#aaaa NriaFZppp]	MISS FIR SUPRVN WATER FLOW SENSOR AREA=a POINT=ppp
344 Missing Fire Supervision / Waterflow Sensor (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasGMpppt <header>[#aaaa NriaaFZppp]	MISS FIR SUPRVN WATER FLOW SENSOR AREA=aa POINT=pppp
345 Missing Gas Supervision	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasVpppt <header>[#aaaa NriaaGSppp]	MISS GAS SUPV AREA=aa POINT=pppp
346 Missing Supervision	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasMTsppt <header>[#aaaa NriaBZppp]	MISSING SUPRVSN AREA=a POINT=ppp
347 Missing Supervision (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasMTpppt <header>[#aaaa NriaaBZppp]	MISSING SUPRVSN AREA=aa POINT=pppp

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

	<b>Event</b>	<b>Device/Mode</b>	<b>Display/Explanation</b>	<b>Comments</b>
348	Missing Trouble (2212)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa MISSING TROUBLE +++ACC aaaa POINT=ppp h1rrlssssssssaaasVspppt <header>[#aaaa NUYppp]	
349	Missing Trouble from Keyfob	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa MISSING TROUBLE +++ACC aaaa KEYFOB +++ACC aaaa ID=iii h1rrlssssssssaaasVsD10t <header>[#aaaa NidiiiUY]	
350	Missing Trouble from Keyfob (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa MISSING TROUBLE +++ACC aaaa KEYFOB +++ACC aaaa ID=iii h1rrlssssssssaaasVsD10t <header>[#aaaa NidiiiUY]	
351	Missing Trouble	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa MISSING TROUBLE +++ACC aaaa AREA=a POINT=ppp h1rrlssssssssaaasVspppt <header>[#aaaa NriaaUYppp]	7
352	Missing Trouble (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa MISSING TROUBLE +++ACC aaaa AREA=aa POINT=pppp h1rrlssssssssaaasVppppt <header>[#aaaa NriaaUYppp]	
353	Network Condition	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa NETWORK COND +++ACC aaaa PATH=ppp COND=nnn h1rrlssssssssaaasNsD44t <header>[#aaaa NpapppNCnnn]	
354	Network Failure	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa NETWORK FAIL +++ACC aaaa PATH=ppp COND=nnn h1rrlssssssssaaasNsD42t <header>[#aaaa NpapppNTnnn]	
355	Network Failure (4-digit Device)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa NETWORK FAIL +++ACC aaaa SDI=dddd COND=nnn h1rrlssssssssaaasNsD42t <header>[#aaaa NpiddDDNTnnn]	New Message
356	Network Restoral	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa NETWORK RESTORE +++ACC aaaa PATH=ppp COND=nnn h1rrlssssssssaaasNsD43t <header>[#aaaa NpapppNRnnn]	
357	Network Restoral (4-digit Device)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa NETWORK RESTORE +++ACC aaaa SDI=dddd COND=nnn h1rrlssssssssaaasNsD43t <header>[#aaaa NpiddDDNRnnn]	New Message
358	No Entry (Anti-Passback)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa NO ENTRY-PASSBK +++ACC aaaa AREA=a CRD=i-x POINT=ppp h1rrlssssssssaaasAdsppt <header>[#aaaa Nria/iidiiDIppp]	
359	No Entry (Door Secured)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa NO ENTRY-SECURE +++ACC aaaa AREA=a CRD=i-x POINT=ppp h1rrlssssssssaaasAdsppt <header>[#aaaa Nria/iidiiIDppp]	
360	No Entry (Interlock Deny)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa NO ENTRY-INTRLK +++ACC aaaa AREA=a CRD=i-x POINT=ppp h1rrlssssssssaaasAdsppt <header>[#aaaa Nria/iidiiDWppp]	
361	No Entry (No Rights in Area)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa NO ENTRY-LEVEL +++ACC aaaa AREA=a CRD=i-x POINT=ppp h1rrlssssssssaaasAdsppt <header>[#aaaa Nria/iidiiDVppp]	
362	No Entry (Outside Time Window)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa NO ENTRY-TIME +++ACC aaaa AREA=a CRD=i-x POINT=ppp h1rrlssssssssaaasAdsppt <header>[#aaaa Nria/iidiiDPppp]	
363	No Entry (Unknown ID)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa NO ENTRY-UNK ID +++ACC aaaa AREA=a POINT=PPP h1rrlssssssssaaasAdsppt <header>[#aaaa NriaDDppp]	
364	No Entry (Wrong Arming State)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa NO ENTRY-ARMED +++ACC aaaa AREA=a CRD=i-x POINT=PPP h1rrlssssssssaaasAdsppt <header>[#aaaa Nria/iidiiDQppp]	
365	No Entry (Unknown ID) (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa NO ENTRY-UNK ID +++ACC aaaa AREA=aa POINT=pppp h1rrlssssssssaaasAdpppt <header>[#aaaa NriaaDDppp]	

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
366 No Entry (Wrong Arming State) (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa NO ENTRY-ARMED +++ACC aaaa AREA=aa CRD=iii-x POINT=pppp h1rrrlssssssaaaaADpppt <header>[#aaaa Nriaa/idiiiDQppp]	
367 No Entry (Anti-Passback) (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa NO ENTRY-PASSBK +++ACC aaaa AREA=aa CRD=iii-x POINT=pppp h1rrrlssssssaaaaADpppt <header>[#aaaa Nriaa/idiiiDIppp]	
368 No Entry (Door Secured) (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa NO ENTRY-SECURE +++ACC aaaa AREA=aa CRD=iii-x POINT=pppp h1rrrlssssssaaaaADpppt <header>[#aaaa Nriaa/idiiiDZppp]	
369 No Entry (Interlock Deny) (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa NO ENTRY-INTRLK +++ACC aaaa AREA=aa CRD=iii-x POINT=pppp h1rrrlssssssaaaaADpppt <header>[#aaaa Nriaa/idiiiDWppp]	
370 No Entry (No Rights in Area) (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa NO ENTRY-LEVEL +++ACC aaaa AREA=aa CRD=iii-x POINT=pppp h1rrrlssssssaaaaADpppt <header>[#aaaa Nriaa/idiiiDVppp]	
371 No Entry (Outside Time Window) (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa NO ENTRY-TIME +++ACC aaaa AREA=aa CRD=iii-x POINT=pppp h1rrrlssssssaaaaADpppt <header>[#aaaa Nriaa/idiiiDPppp]	
372 No Entry (Anti-Passback) (4-digit User / Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa NO ENTRY-PASSBK +++ACC aaaa AREA=aa CRD=iiii POINT=pppp h1rrrlssssssaaaaADpppt <header>[#aaaa Nriaa/idiiiDIppp]	
373 No Entry (Door Secured) (4-digit User / Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa NO ENTRY-SECURE +++ACC aaaa AREA=aa CRD=iiii POINT=pppp h1rrrlssssssaaaaADpppt <header>[#aaaa Nriaa/idiiiDZppp]	
374 No Entry (Interlock Deny) (4-digit User / Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa NO ENTRY-INTRLK +++ACC aaaa AREA=aa CRD=iiii POINT=pppp h1rrrlssssssaaaaADpppt <header>[#aaaa Nriaa/idiiiDWppp]	
375 No Entry (No Rights in Area) (4-digit User / Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa NO ENTRY-LEVEL +++ACC aaaa AREA=aa CRD=iiii POINT=pppp h1rrrlssssssaaaaADpppt <header>[#aaaa Nriaa/idiiiDVppp]	
376 No Entry (Outside Time Window) (4-digit User / Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa NO ENTRY-TIME +++ACC aaaa AREA=aa CRD=iiii POINT=pppp h1rrrlssssssaaaaADpppt <header>[#aaaa Nriaa/idiiiDPppp]	
377 No Entry (Wrong Arming State) (4-digit User / Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa NO ENTRY-ARMED +++ACC aaaa AREA=aa CRD=iiii POINT=pppp h1rrrlssssssaaaaADpppt <header>[#aaaa Nriaa/idiiiDQppp]	
378 Opening by Account (2112/2212)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa OPENING REPORT +++ACC aaaa ID=iii h1rrrlssssssaaaaOsiiit <header>[#aaaa NidiiioP]	
379 Opening by Account	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa OPENING REPORT +++ACC aaaa ID=iii h1rrrlssssssaaaaOsiiit <header>[#aaaa NidiiioP]	
380 Opening by Account from Alarm (2212)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa OPEN FROM ALARM +++ACC aaaa ID=iii h1rrrlssssssaaaaOsiiit <header>[#aaaa Nidiiior]	
381 Opening by Account from Alarm (No Area)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa OPEN FROM ALARM +++ACC aaaa ID=iii h1rrrlssssssaaaaOsiiit <header>[#aaaa Nidiiior]	
382 Opening by Area	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa OPENING REPORT +++ACC aaaa AREA=a ID=iii h1rrrlssssssaaaaOsiiit <header>[#aaaa Nriaa/idiiioP]	
383 Opening by Area (No User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa OPENING REPORT +++ACC aaaa AREA=a ID=iii h1rrrlssssssaaaaOsosst <header>[#aaaa NriaaOP]	
384 Opening by Area (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa OPENING REPORT +++ACC aaaa AREA=aa ID=iii h1rrrlssssssaaaaOsiiit <header>[#aaaa Nriaa/idiiioP]	

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

	<b>Event</b>	<b>Device/Mode</b>	<b>Display/Explanation</b>	<b>Comments</b>
385	Opening by Area from Alarm (No User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasOsssst <header>[#aaaa NriaOR]	OPEN FROM ALARM AREA=a
386	Opening by Area from Alarm	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasOsiiit <header>[#aaaa Nria/idiiiOR]	OPEN FROM ALARM AREA=a ID=iii
387	Opening by Area from Alarm (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasOiiit <header>[#aaaa Nriaa/idiiiOR]	OPEN FROM ALARM AREA=aa ID=iii
388	Opening Early by Area	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasOsiiit <header>[#aaaa Nria/idiiiOK]	EARLY TO OPEN AREA=a ID=iii
389	Opening Early by Area (No User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasOsssst <header>[#aaaa NriaOK]	EARLY TO OPEN AREA=a
390	Opening Early by Area (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasOiiit <header>[#aaaa Nriaa/idiiiOK]	EARLY TO OPEN AREA=aa ID=iii
391	Opening Early by Area from Alarm (No User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa OP ERLY FRM-ALM +++ACC aaaa h1rrrlssssssaaaasOsssst <header>[#aaaa NriaOH]	OP ERLY FRM-ALM AREA=a
392	Opening Early by Area from Alarm	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa OP ERLY FRM-ALM +++ACC aaaa h1rrrlssssssaaaasOsiiit <header>[#aaaa Nria/idiiiOH]	OP ERLY FRM-ALM AREA=a ID=iii
393	Opening Early by Area from Alarm (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa OP ERLY FRM-ALM +++ACC aaaa h1rrrlssssssaaaasOiiit <header>[#aaaa Nriaa/idiiiOH]	OP ERLY FRM-ALM AREA=aa ID=iii
394	Opening Late by Area	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasOsiiit <header>[#aaaa Nria/idiiiOJ]	LATE TO OPEN AREA=a ID=iii
395	Opening Late by Area (No User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa LATE TO OPEN +++ACC aaaa h1rrrlssssssaaaasOsssst <header>[#aaaa NriaOJ]	LATE TO OPEN AREA=a
396	Opening Late by Area (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa LATE TO OPEN +++ACC aaaa h1rrrlssssssaaaasOiiit <header>[#aaaa Nriaa/idiiiOJ]	LATE TO OPEN AREA=aa ID=iii
397	Opening Late by Area from Alarm	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa OP LATE FRM-ALM +++ACC aaaa h1rrrlssssssaaaasOsiiit <header>[#aaaa Nria/idiiiOL]	OP LATE FRM-ALM AREA=a ID=iii
398	Opening Late by Area from Alarm (No User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa OP LATE FRM-ALM +++ACC aaaa h1rrrlssssssaaaasOsssst <header>[#aaaa NriaOL]	OP LATE FRM-ALM AREA=a
399	Opening Late by Area from Alarm (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa OP LATE FRM-ALM +++ACC aaaa h1rrrlssssssaaaasOiiit <header>[#aaaa Nriaa/idiiiOL]	OP LATE FRM-ALM AREA=aa ID=iii
400	Output State	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa OUTPUT-TROUBLE +++ACC aaaa h1rrrlssssssaaaasTsD47t <header>[#aaaa NOUuuu]	OUTPUT-TROUBLE OUTPUT=uuu
401	Output State (4-digit Output)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa OUTPUT-TROUBLE +++ACC aaaa h1rrrlssssssaaaasTsD47t <header>[#aaaa NOUuuu]	OUTPUT-TROUBLE OUTPUT=uuuu
402	Output State Restore	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa OUTPUT-TRBL RST +++ACC aaaa h1rrrlssssssaaaasRsd47t <header>[#aaaa NOVuuu]	OUTPUT-TRBL RST OUTPUT=uuu

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
403 Output State Restore (4-digit Output)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRsD47t <header>[#aaaa NOVuuuu]	OUTPUT=TRBL RST OUTPUT=uuuu
404 Panic Alarm (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasApppt <header>[#aaaa Nrriaa PApppp]	PANIC ALARM AREA=aa POINT=pppp New Message
405 Panic Restore (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRpppt <header>[#aaaa Nrriaa PHpppp]	PANIC RESTORE AREA=aa POINT=pppp New Message
406 Parameters Changed	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa D6500 Mode: h1rrrlssssssaaaasNsD02t <header>[#aaaa NYG]	PARAMS CHANGED
407 Parameter Checksum Fail	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrrlssssssaaaasTsD15t <header>[#aaaa NYF]	PARMS BAD CKSUM
408 Parameter Checksum Fail (Device Specific)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasTsD15t <header>[#aaaa NpiddYYF]	PARMS BAD CKSUM SDI=ddd
409 Perimeter Delay by Area (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasCiiit <header>[#aaaa Nrriaa/idiiiNL]	PERM DLAY ARMED AREA=aa ID=iiii
410 Perimeter Delay by Area (User Defined) (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasCiiit <header>[#aaaa Nrriaa/idiiiNM]	PERM DLAY ARMED USER DEFINED AREA=aa ID=iiii
411 Perimeter Instant (2112/2212)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasCsiiit <header>[#aaaa NidiiiNL]	PERM INST ARMED ID=iii
412 Perimeter Instant by Area	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasCsiiit <header>[#aaaa Nrria/idiiiNL]	PERM INST ARMED AREA=a ID=iii
413 Perimeter Instant by Area (No User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasCsssst <header>[#aaaa NrriaNL]	PERM INST ARMED AREA=a
414 Perimeter Instant by Area (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasCiiit <header>[#aaaa Nrria/idiiiNL]	PERM INST ARMED AREA=aa ID=iiii
415 Perimeter Instant by Area (User Defined) (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasCiiit <header>[#aaaa Nrriaa/idiiiNM]	PERM INST ARMED USER DEFINED AREA=aa ID=iiii
416 Phone Line Fail (Line 1)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasTsssBt <header>[#aaaa NLT1]	PHONE LINE FAIL PHONE LINE=1
417 Phone Line Fail (Line2)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasTsssCt <header>[#aaaa NLT2]	PHONE LINE FAIL PHONE LINE=2
418 Phone Line Fail / Ground Fault (Line 1)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasTsssBt <header>[#aaaa NLT1]	PHONE LINE FAIL GROUND FAULT PHONE LINE=1
419 Phone Line Fail / Ground Fault (Line 2)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasTsssCt <header>[#aaaa NLT2]	PHONE LINE FAIL GROUND FAULT PHONE LINE=2
420 Phone Line Restoral (Line 1)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRsssBt <header>[#aaaa NLR1]	PHONE RESTORAL PHONE LINE=1

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

	<b>Event</b>	<b>Device/Mode</b>	<b>Display/Explanation</b>	<b>Comments</b>
421	Phone Line Restoral (Line 2)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRsssCt <header>[#aaaa NLR2]	PHONE RESTORAL PHONE LINE=2
422	Point Bus Fail (No Area)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasTsssDt <header>[#aaaa NET]	PT BUS TROUBLE
423	Point Bus Fail	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasTsssDt <header>[#aaaa NriaaET]	PT BUS TROUBLE AREA=aa
424	Point Bus Fail / Ground Fault	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasTsssDt <header>[#aaaa NET]	PT BUS TROUBLE GROUND FAULT
425	Point Bus Restoral (No Area)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrrlssssssaaaasRsssDt <header>[#aaaa NER]	PT BUS RESTORAL
426	Point Bus Restoral	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRsssDt <header>[#aaaa NriaaER]	PT BUS RESTORAL AREA=aa
427	Point Bypass (2112/2212)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasNspppt <header>[#aaaa NUBppp]	POINT BYPASS POINT=PPP
428	Point Bypass	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasNspppt <header>[#aaaa NriaUBppp]	POINT BYPASS AREA=a POINT=PPP
429	Point Bypass (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasNppppt <header>[#aaaa NriaaUBppp]	POINT BYPASS AREA=aa POINT=pppp
430	Point Bypass / Fire	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasNspppt <header>[#aaaa NriaFBppp]	POINT BYPASS FIRE POINT AREA=a POINT=ppp
431	Point Bypass / Fire (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasNppppt <header>[#aaaa NriaaFBppp]	POINT BYPASS FIRE POINT AREA=aa POINT=pppp
432	Point Bypass / Supervisory	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasNspppt <header>[#aaaa NriaSBppp]	POINT BYPASS SUPERVISORY POINT AREA=a POINT=ppp
433	Point Bypass / Supervisory (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasNppppt <header>[#aaaa NriaaSBppp]	POINT BYPASS SUPERVISORY POINT AREA=aa POINT=pppp
434	Point Bypass / Waterflow	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasNspppt <header>[#aaaa NriaWBppp]	POINT BYPASS WATERFLOW POINT AREA=a POINT=ppp
435	Point Bypass / Waterflow (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasNppppt <header>[#aaaa NriaaWBppp]	POINT BYPASS WATERFLOW POINT AREA=aa POINT=pppp
436	Point Closing	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasCsppt <header>[#aaaa NriaCZppp]	POINT CLOSING AREA=a POINT=ppp
437	Point Closing (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasCpppt <header>[#aaaa NriaaCZppp]	POINT CLOSING AREA=aa POINT=pppp

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
438 Point Opening	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasOsppt <header>[#aaaa NriaOZppp]	POINT OPENING AREA=a POINT=ppp 7
439 Point Opening (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasOpppt <header>[#aaaa NriaaOZpppp]	POINT OPENING AREA=aa POINT=pppp
440 Point Status Report (7112 only)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrrlssssssaaaasXsssst <header>[#aaaa N00]	BAD 9112 PACKET
441 Printer Status / Off Line	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasTsssst <header>[#aaaa NpiddDVZ]	PRINTR-OFF LINE SDI=ddd
442 Printer Status / On Line	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasTsssst <header>[#aaaa NpiddDVY]	PRINTER-ON LINE SDI=ddd
443 Printer Status / Paper In	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasTsssst <header>[#aaaa NpiddDV1]	PRINTR-PAPER IN SDI=ddd
444 Printer Status / Paper Out	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasTsssst <header>[#aaaa NpiddDV0]	PRNTR-PAPER OUT SDI=ddd
445 Programmer Bypass	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasNsppt <header>[#aaaa Nria/pidddUBppp]	PROGRAMR BYPASS AREA=a POINT=ppp SDI=ddd
446 Programmer Bypass (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasNpppt <header>[#aaaa Nriaa/pidddUBpppp]	PROGRAMR BYPASS AREA=aa POINT=pppp SDI=ddd
447 Re-Boot	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrrlssssssaaaasNsD14t <header>[#aaaa NRR]	RE-BOOT
448 Re-Boot / Power Up (4-digit Device) (Version text)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasNsD14t <header>[#aaaa NpidddRR012]	RE-BOOT SDI=dddd COND=012 SDI=xxxxxx Vx.xx New Message
449 Re-Boot / Firmware Update (4-digit Device) (Version text / New Version)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasNsD14t <header>[#aaaa NpidddRR013]	RE-BOOT SDI=dddd COND=013 SDI=xxxxxx Vx.xx New Message
450 Re-Boot (Device Specific)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrrlssssssaaaasNsD14t <header>[#aaaa NpidddRR]	RE-BOOT SDI=ddd
451 Relay Reset by Programmer	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrrlssssssaaaasNsD22t <header>[#aaaa NpidddROrr]	RELAY RESET BY PROGRAMMER RELAY#=rrr SDI=ddd
452 Relay Reset by Remote	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrrlssssssaaaasNsD24t <header>[#aaaa NROrr]	RELAY RESET BY REMOTE RELAY#=rrr
453 Relay Reset by SKED	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrrlssssssaaaasNsD20t <header>[#aaaa NaikkR0rr]	RELAY RESET BY SKED RELAY#=rrr SKED=kkk
454 Relay Reset by User	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrrlssssssaaaasNsD18t <header>[#aaaa NidiiR0rr]	RELAY RESET BY USER ID=iii RELAY#=rrr

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

	<b>Event</b>	<b>Device/Mode</b>	<b>Display/Explanation</b>	<b>Comments</b>
455	Relay Reset by User (4-digit User)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrlssssssaaaasNsD18t <header>[#aaaa NidiiiROrrr]	RELAY RESET BY USER ID=iiii RELAY#=rrr
456	Relay Reset by Programmer (4-digit Relay)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrlssssssaaaasNsD22t <header>[#aaaa NpidddROrrr]	RELAY RESET BY PROGRAMMER RELAY#=rrrr SDI=ddd
457	Relay Reset by Remote (4-digit Relay)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrlssssssaaaasNsD24t <header>[#aaaa NROrrr]	RELAY RESET BY REMOTE RELAY#=rrrr
458	Relay Reset by SKED (4-digit Relay)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrlssssssaaaasNsD20t <header>[#aaaa NaikkROrrr]	RELAY RESET BY SKED RELAY#=rrrr SKED=kkk
459	Relay Reset by User (4-digit Relay)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrlssssssaaaasNsD18t <header>[#aaaa NidiiiROrrr]	RELAY RESET BY USER ID=iii RELAY#=rrrr
460	Relay Reset by User (4-digit User / Relay)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrlssssssaaaasNsD18t <header>[#aaaa NidiiiROrrr]	RELAY RESET BY USER ID=iiii RELAY#=rrrr
461	Relay Set by Programmer	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrlssssssaaaasNsD21t <header>[#aaaa NpidddRCrr]	RELAY SET BY PROGRAMMER RELAY#=rrr SDI=ddd
462	Relay Set by Remote	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrlssssssaaaasNsD23t <header>[#aaaa NRCrr]	RELAY SET BY REMOTE RELAY#=rrr
463	Relay Set by SKED	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrlssssssaaaasNsD19t <header>[#aaaa NaikkRCrkk]	RELAY SET BY SKED RELAY#=rrr SKED=kkk
464	Relay Set by User	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrlssssssaaaasNsD28t <header>[#aaaa NidiiiRCrr]	RELAY SET BY USER ID=iii RELAY#=rrr
465	Relay Set by User (4-digit User)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrlssssssaaaasNsD28t <header>[#aaaa NidiiiRCrr]	RELAY SET BY USER ID=iiii RELAY#=rrr
466	Relay Set by Programmer (4-digit Relay)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrlssssssaaaasNsD21t <header>[#aaaa NpidddRCrr]	RELAY SET BY PROGRAMMER RELAY#=rrrr SDI=ddd
467	Relay Set by Remote (4-digit Relay)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrlssssssaaaasNsD23t <header>[#aaaa NRCrr]	RELAY SET BY REMOTE RELAY#=rrrr
468	Relay Set by SKED (4-digit Relay)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrlssssssaaaasNsD19t <header>[#aaaa NaikkRCrkk]	RELAY SET BY SKED RELAY#=rrrr SKED=kkk
469	Relay Set by User (4-digit Relay)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrlssssssaaaasNsD28t <header>[#aaaa NidiiiRCrr]	RELAY SET BY USER ID=iii RELAY#=rrrr

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
470 Relay Set by User (4-digit User / Relay)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasNsD28t <header>[#aaaa NidiiiRCrrrr]	RELAY SET BY USER ID=iiii RELAY#=rrrr
471 Remote Bypass / Callback	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa AREA=a POINT=ppp PH#=hh h1rrrlssssssaaaasNspppt <header>[#aaaa Nria/phhhUBppp]	RAM BYPASS AREA=a POINT=ppp PH#=hh
472 Remote Bypass / Callback (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa AREA=aa POINT=pppp PH#=hh h1rrrlssssssaaaasNppppt <header>[#aaaa Nriaa/phhhUBpppp]	RAM BYPASS AREA=aa POINT=pppp PH#=hh
473 Remote Bypass	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasNspppt <header>[#aaaa NriaUBppp]	RAM BYPASS AREA=a POINT=ppp
474 Remote Bypass (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasNppppt <header>[#aaaa NriaaUBpppp]	RAM BYPASS AREA=aa POINT=pppp
475 Remote Reset	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrrlssssssaaaasNsD11t <header>[#aaaa NRN]	REMOTE RESET
476 Restoral (2112/2212)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRsppt <header>[#aaaa NBRppp]	RESTORAL REPORT POINT=PPP
477 Restoral (Trouble / Missing / Non-Fire Supervision)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRsppt <header>[#aaaa NriaBRppp]	RESTORAL REPORT AREA=a POINT=PPP
478 Restoral from Alarm	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRsppt <header>[#aaaa NriaBppp]	RESTORE FRM ALM AREA=a POINT=PPP
479 Restoral from Alarm (No Area)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRsppt <header>[#aaaa NBppp]	RESTORE FRM ALM POINT=PPP
480 Restoral from Alarm (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRpppt <header>[#aaaa NriaaBpppp]	RESTORE FRM ALM AREA=aa POINT=pppp
481 Restoral from Keyfob	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRsD10t <header>[#aaaa NidiiiUR]	RESTORAL REPORT KEYFOB ID=iii
482 Restoral from Keyfob (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRsD10t <header>[#aaaa NidiiiUR]	RESTORAL REPORT KEYFOB ID=iiii
483 Restoral (Trouble / Missing / Non-Fire Supervision) (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRpppt <header>[#aaaa NriaaBRpppp]	RESTORAL REPORT AREA=aa POINT=pppp
484 RF Interference	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasTsD08t <header>[#aaaa NpidddXQ]	RF INTERFERENCE SDI=ddd
485 RF Interference Restoral	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRsD08t <header>[#aaaa NpidddXH]	RF INTRFER-REST SDI=ddd
486 RF Receiver Tamper (2212)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasXss35t <header>[#aaaa NpidddXS]	RCVR TAMPER SDI=ddd
487 RF Receiver Tamper Restoral (2212)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasXss36t <header>[#aaaa NpidddXJ]	RCVR TAMPR REST SDI=ddd

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

	<b>Event</b>	<b>Device/Mode</b>	<b>Display/Explanation</b>	<b>Comments</b>
488	RF Receiver Trouble (2212)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasTsD17t <header>[#aaaa NpiddET]	RCVR TROUBLE SDI=ddd
489	RF Receiver Trouble Restoral (2212)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasRsD17t <header>[#aaaa NpiddER]	RCVR TBL RESTOR SDI=ddd
490	RF Transmitter Battery Restoral (2212)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasRppt <header>[#aaaa NXRppt]	RF BATT RESTORE POINT=ppp
491	RF Transmitter Battery Restoral	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasRsD10t <header>[#aaaa NpiddXR]	RF BATT RESTORE SDI=ddd
492	RF Transmitter Battery Restoral from Keyfob	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasRsD10t <header>[#aaaa NidiiiXR]	RF BATT RESTORE KEYFOB ID=iii
493	RF Transmitter Battery Restoral from Keyfob (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasRsD10t <header>[#aaaa NidiiiXR]	RF BATT RESTORE KEYFOB ID=iii
494	RF Transmitter Battery Restoral	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasRppt <header>[#aaaa NriaXRppt]	RF BATT RESTORE AREA=a POINT=ppp
495	RF Transmitter Battery Restoral (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasRppt <header>[#aaaa NriaaXRppt]	RF BATT RESTORE AREA=aa POINT=pppp
496	RF Transmitter Low Battery (2212)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasTppt <header>[#aaaa NXTpp]	RF BATTERY LOW POINT=ppp
497	RF Transmitter Low Battery	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasTsD10t <header>[#aaaa NpiddXT]	RF BATTERY LOW SDI=ddd
498	RF Transmitter Low	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasTspp <header>[#aaaa NriaXTpp]	RF BATTERY LOW AREA=a POINT=ppp
499	RF Transmitter Low Battery (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasTppt <header>[#aaaa NriaaXTpp]	RF BATTERY LOW AREA=aa POINT=pppp
500	RF Transmitter Low Battery from Keyfob	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasTsD10t <header>[#aaaa NidiiiXT]	RF BATTERY LOW KEYFOB ID=iii
501	RF Transmitter Low Battery from Keyfob (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasTsD10t <header>[#aaaa NidiiiXT]	RF BATTERY LOW KEYFOB ID=iii
502	RF Transmitter Tamper Alarm (2212)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasAsppt <header>[#aaaa NTApp]	RF TAMPER ALARM POINT=ppp
503	RF Transmitter Tamper Alarm	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasAsppt <header>[#aaaa NriaTapp]	RF TAMPER ALARM AREA=a POINT=ppp
504	RF Transmitter Tamper Alarm (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasApppt <header>[#aaaa NriaaTApp]	RF TAMPER ALARM AREA=aa POINT=pppp

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
505 RF Transmitter Tamper Restoral (2212)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa RF TMPR RSTORAL +++ACC aaaa POINT=ppp h1rrrlssssssaaaasRppt <header>[#aaaa NTrppp]	
506 RF Transmitter Tamper Restoral	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa RF TMPR RSTORAL +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaasRppt <header>[#aaaa NriaTRppp]	
507 RF Transmitter Tamper Restoral (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa RF TMPR RSTORAL +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaasRppt <header>[#aaaa NriaaTRppp]	
508 RF Transmitter Tamper Trouble (2212)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa RF TMPR TROUBLE +++ACC aaaa POINT=ppp h1rrrlssssssaaaasTspppt <header>[#aaaa NTTppt]	
509 RF Transmitter Tamper Trouble	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa RF TMPR TROUBLE +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaasTspppt <header>[#aaaa NriaTTppp]	
510 RF Transmitter Tamper Trouble (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa RF TMPR TROUBLE +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaasTppt <header>[#aaaa NriaaTTppp]	
511 SDI Bus Fail / Ground Fault	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SDI FAILURE +++ACC aaaa GROUND FAULT +++ACC aaaa SDI=ddd h1rrrlssssssaaaasTsssDt <header>[#aaaa NpidddDET]	
512 SDI Bus Fail	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SDI FAILURE +++ACC aaaa SDI=ddd h1rrrlssssssaaaasTsssDt <header>[#aaaa NpidddDET]	
513 SDI Bus Restoral / Ground Fault	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SDI RESTORAL +++ACC aaaa GROUND FAULT +++ACC aaaa SDI=ddd h1rrrlssssssaaaasRsssDt <header>[#aaaa NpidddER]	
514 SDI Bus Restoral	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SDI RESTORAL +++ACC aaaa SDI=ddd h1rrrlssssssaaaasRsssDt <header>[#aaaa NpidddER]	
515 SDI Device AC Failure	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DEVICE AC FAIL +++ACC aaaa SDI=ddd h1rrrlssssssaaaasTsssDt <header>[#aaaa NpidddEP]	
516 SDI Device AC Restoral	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DEV AC RESTORE +++ACC aaaa SDI=ddd h1rrrlssssssaaaasRsssDt <header>[#aaaa NpidddEQ]	
517 SDI Device Battery Trouble	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DEVICE BAT TRBL +++ACC aaaa SDI=ddd h1rrrlssssssaaaasTsssDt <header>[#aaaa NpidddEB]	
518 SDI Device Low Battery (4-digit Device)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DEVICE LOW BATT +++ACC aaaa BATT=bbb SDI=dddd h1rrrlssssssaaaasTsssDt <header>[#aaaa NpidddEBbb]	New Message
519 SDI Device Low Battery Restore (4-digit Device)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa LOW BAT RESTORE +++ACC aaaa BATT=bbb SDI=dddd h1rrrlssssssaaaasRsssDt <header>[#aaaa NpidddEVbb]	New Message
520 SDI Device Missing	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DEVICE MISSING +++ACC aaaa SDI=ddd h1rrrlssssssaaaasTsssDt <header>[#aaaa NpidddEM]	
521 SDI Device Missing (4-digit Device)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DEVICE MISSING +++ACC aaaa SDI=ddd h1rrrlssssssaaaasTsssDt <header>[#aaaa NpidddEM]	New Message
522 SDI Device Missing Restore	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DEV MISSING RST +++ACC aaaa SDI=ddd h1rrrlssssssaaaasRsssDt <header>[#aaaa NpidddEN]	

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
523 SDI Device Missing Restore (4-digit Device)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DEV MISSING RST +++ACC aaaa h1rrrlssssssaaaasRsssDt <header>[#aaaa NpiddddEN]	New Message
524 SDI Device Missing Battery (4-digit Device)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DEVICE MIS BATT +++ACC aaaa BATT=bb SDI=dddd h1rrrlssssssaaaasTsssDt <header>[#aaaa NpidddEBbb]	New Message
525 SDI Device Missing Battery Reset (4-digit Device)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa MISS BATT REST +++ACC aaaa BATT=bb SDI=dddd h1rrrlssssssaaaasRsssDt <header>[#aaaa NpiddddEVbb]	New Message
526 SDI Device Low Battery Restoral	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DEV BAT RESTORE +++ACC aaaa h1rrrlssssssaaaasRsssDt <header>[#aaaa NpidddEV]	
527 SDI Device Missing (4-digit Device)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DEVICE MISSING +++ACC aaaa SDI=dddd h1rrrlssssssaaaasTsssDt <header>[#aaaa NpidddEM]	New Message
528 SDI Device Missing Restore (4-digit Device)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DEV MISSING RST +++ACC aaaa h1rrrlssssssaaaasRsssDt <header>[#aaaa NpiddddEN]	New Message
529 SDI Device Trouble	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DEVICE TROUBLE +++ACC aaaa SDI=ddd h1rrrlssssssaaaasTsssDt <header>[#aaaa NpidddET]	
530 SDI Device Trouble Restore	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa DEV TROUBLE RST +++ACC aaaa SDI=ddd h1rrrlssssssaaaasRsssDt <header>[#aaaa NpidddER]	
531 Sensor Reset	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SENSOR RESET +++ACC aaaa AREA=a ID=iii RELAY#=rrr h1rrrlssssssaaaasNsD27t <header>[#aaaa Nrria/idiiixIrrr]	4
532 Sensor Reset (4-digit Relay)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SENSOR RESET +++ACC aaaa AREA=aa ID=iii RELAY#=rrrr h1rrrlssssssaaaasNsD27t <header>[#aaaa Nrriaa/idiiixIrrr]	
533 Sensor Reset (4-digit User / Device)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SENSOR RESET +++ACC aaaa AREA=a ID=iiii RELAY#=rrrr h1rrrlssssssaaaasNsD27t <header>[#aaaa Nrria/idiiiiXIr rr]	
534 Sensor Reset	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SENSOR RESET +++ACC aaaa AREA=aa ID=iii RELAY#=rrr h1rrrlssssssaaaasNsD27t <header>[#aaaa Nrriaa/idiiiiXIr rr]	
535 Sensor Reset (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SENSOR RESET +++ACC aaaa AREA=aa ID=iiii RELAY#=rrr h1rrrlssssssaaaasNsD27t <header>[#aaaa Nrriaa/idiiiiXIr rr]	
536 Sensor Restore	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SENSOR RESTORE +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaasQsp ppt <header>[#aaaa NrriaXNppp]	
537 Sensor Restore (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SENSOR RESTORE +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaasRQpp ppt <header>[#aaaa NrriaXNppp p]	
538 Sensor Trouble	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SENSOR TROUBLE +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaasQsp ppt <header>[#aaaa NrriaXKppp]	
539 Sensor Trouble (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SENSOR TROUBLE +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaasQpp ppt <header>[#aaaa NrriaXKppp p]	
540 Service Bypass (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SERVICE BYPASS +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaasNpp ppt <header>[#aaaa NrriaUBppp p]	New Message

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
541 Service Bypass Restore (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SERVICE RESTORE +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaRBpppt <header>[#aaaa NriaUUpppp]	New Message
542 Service End (2212)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SERVICE END h1rrrlssssssaaaaasRsssFt <header>[#aaaa NTE]	
543 Service End	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SERVICE END +++ACC aaaa AREA=a h1rrrlssssssaaaaasRsssFt <header>[#aaaa NriaTE]	
544 Service End (No Area)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SERVICE END +++ACC aaaa ID=iii h1rrrlssssssaaaaasRsssFt <header>[#aaaa NidiitiE]	
545 Service Request	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SERVICE REQUEST h1rrrlssssssaaaaasNsD45t <header>[#aaaa NYX]	
546 Service Start (2212)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SERVICE START h1rrrlssssssaaaaasTsssFt <header>[#aaaa NTS]	
547 Service Start by User	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SERVICE START +++ACC aaaa AREA=a ID=iii h1rrrlssssssaaaaasTsssFt <header>[#aaaa Nria/idiiITS]	
548 Service Start	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SERVICE START +++ACC aaaa AREA=a h1rrrlssssssaaaaasTsssFt <header>[#aaaa NriaTS]	
549 Service Start (No Area)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SERVICE START +++ACC aaaa ID=iii h1rrrlssssssaaaaasTsssFt <header>[#aaaa NidiitiTS]	
550 Service Start by User (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SERVICE START +++ACC aaaa AREA=aa ID=iii h1rrrlssssssaaaaasTsssFt <header>[#aaaa Nriaa/idiiITS]	
551 SKED Bypass	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SKED BYPASS +++ACC aaaa AREA=a POINT=ppp SKED=kkk h1rrrlssssssaaaaasNspppt <header>[#aaaa Nria/aikkUBpppl]	
552 SKED Bypass (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SKED BYPASS +++ACC aaaa AREA=aa POINT=pppp SKED=kkk h1rrrlssssssaaaaasNpppt <header>[#aaaa Nriaa/aikkUBpppp]	
553 SKED Changed	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SKED CHANGED +++ACC aaaa SKED=kkk h1rrrlssssssaaaaasNsD06t <header>[#aaaa NaikkJJS]	
554 SKED Changed by User	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SKED CHANGED +++ACC aaaa ID=iii SKED=kkk h1rrrlssssssaaaaasNsD06t <header>[#aaaa Nidiiji/aikkJS]	
555 SKED Changed by User (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SKED CHANGED +++ACC aaaa ID=iiiii SKED=kkk h1rrrlssssssaaaaasNsD06t <header>[#aaaa Nidiiji/aikkJS]	
556 SKED Executed	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SKED EXECUTED +++ACC aaaa SKED=kkk h1rrrlssssssaaaaasNsD25t <header>[#aaaa NaikkJR]	
557 Status: Alarm	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:ALARM +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaaasAspppt <header>[#aaaa OriaBAppp]	
558 Status: Alarm (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:ALARM +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaasAApppt <header>[#aaaa OriaBApppp]	
559 Status: Analog Service	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:ANALOG SERVCE +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaaasSTspppt <header>[#aaaa OriaASppp]	

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

	<b>Event</b>	<b>Device/Mode</b>	<b>Display/Explanation</b>	<b>Comments</b>
560	Status: Analog Service (Level & Value)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:ANALOG SERVCE +++ACC aaaa +++ACC aaaa h1rrlssssssaaaaSTspppt <header>[#aaaa Oria/lv111/vavvvASppp]	
561	Status: Analog Service (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:ANALOG SERVCE +++ACC aaaa h1rrlssssssaaaaSTppppt <header>[#aaaa OriaaASpppp]	
562	Status: Analog Service (Level & Value) (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:ANALOG SERVCE +++ACC aaaa +++ACC aaaa h1rrlssssssaaaaSTppppt <header>[#aaaa Oriaa/lv111/vavvvASpppp]	
563	Status: Close by Area	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:CLOSING +++ACC aaaa h1rrlssssssaaaaSCsssst <header>[#aaaa OriaCL]	
564	Status: Door Forced	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:DOOR FORCED +++ACC aaaa h1rrlssssssaaaaSAspppt <header>[#aaaa OriaDFppp]	
565	Status: Door Forced (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:DOOR FORCED +++ACC aaaa h1rrlssssssaaaaSAppppt <header>[#aaaa OriaaDFpppp]	
566	Status: Door Left Open	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:DR LEFT OPEN +++ACC aaaa h1rrlssssssaaaaSIspppt <header>[#aaaa OriaDNppp]	
567	Status: Door Left Open (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:DR LEFT OPEN +++ACC aaaa h1rrlssssssaaaaSIppppt <header>[#aaaa OriaaDNpppp]	
568	Status: Fire Alarm	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:FIRE ALARM +++ACC aaaa h1rrlssssssaaaaSFspppt <header>[#aaaa OriaFAppp]	
569	Status: Fire Alarm / Cross Point	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:FIRE ALARM +++ACC aaaa +++ACC aaaa h1rrlssssssaaaaSFspppt <header>[#aaaa OriaFappp]	
570	Status: Fire Alarm / Smoke Detector	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:FIRE ALARM +++ACC aaaa +++ACC aaaa h1rrlssssssaaaaSFspppt <header>[#aaaa OriaFAppp]	
571	Status: Fire Alarm / High Temp Sensor	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:FIRE ALARM +++ACC aaaa +++ACC aaaa h1rrlssssssaaaaSFspppt <header>[#aaaa OriaFAppp]	
572	Status: Fire Alarm / Waterflow Sensor	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:FIRE ALARM +++ACC aaaa +++ACC aaaa h1rrlssssssaaaaSFspppt <header>[#aaaa OriaFAppp]	
573	Status: Fire Alarm (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:FIRE ALARM +++ACC aaaa h1rrlssssssaaaaSFppppt <header>[#aaaa OriaFApppp]	
574	Status: Fire Alarm / Cross Point (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:FIRE ALARM +++ACC aaaa +++ACC aaaa h1rrlssssssaaaaSFppppt <header>[#aaaa OriaaFApppp]	
575	Status: Fire Alarm / Smoke Detector (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:FIRE ALARM +++ACC aaaa +++ACC aaaa h1rrlssssssaaaaSFppppt <header>[#aaaa OriaaFApppp]	

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

	<b>Event</b>	<b>Device/Mode</b>	<b>Display/Explanation</b>	<b>Comments</b>
576	Status: Fire Alarm / High Temp Sensor (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:FIRE ALARM +++ACC aaaa HIGH TEMPERATURE SENSOR +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSFppppt <header>[#aaaa OriaaFApppp]	
577	Status: Fire Alarm / Waterflow Sensor (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:FIRE ALARM +++ACC aaaa WATER FLOW SENSOR +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSFppppt <header>[#aaaa OriaaFApppp]	
578	Status: Fire Missing	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:FIRE MISSING +++ACC aaaa AREA=a POINT=pppp h1rrrlssssssaaaaSZsppt <header>[#aaaa OriaaFYppp]	
579	Status: Fire Missing (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:FIRE MISSING +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSZpppt <header>[#aaaa OriaaFYppp]	
580	Status: Fire Supervision	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:FIRE SUPERVISN +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaaSEsppt <header>[#aaaa OriaFSppp]	
581	Status: Fire Supervision (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:FIRE SUPERVISN +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSEpppt <header>[#aaaa OriaFSppp]	
582	Status: Fire Supervision / Waterflow Sensor	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:FIRE SUPERVISN +++ACC aaaa WATER FLOW SENSOR +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaaSEsppt <header>[#aaaa OriaFSppp]	
583	Status: Fire Supervision / Waterflow Sensor (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:FIRE SUPERVISN +++ACC aaaa WATER FLOW SENSOR +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSEpppt <header>[#aaaa OriaFSppp]	
584	Status: Fire Trouble	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:FIRE TROUBLE +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaaSGsppt <header>[#aaaa OriaFTppp]	
585	Status: Fire Trouble / Smoke Detector	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:FIRE TROUBLE +++ACC aaaa SMOKE DETECTOR +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaaSGsppt <header>[#aaaa OriaFTppp]	
586	Status: Fire Trouble / High Temp Sensor	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:FIRE TROUBLE +++ACC aaaa HIGH TEMPERATURE SENSOR +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaaSGsppt <header>[#aaaa OriaFTppp]	
587	Status: Fire Trouble / Waterflow Sensor	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:FIRE TROUBLE +++ACC aaaa WATER FLOW SENSOR +++ACC aaaa AREA=a POINT=PPP h1rrrlssssssaaaaSGsppt <header>[#aaaa OriaFTppp]	
588	Status: Fire Trouble (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:FIRE TROUBLE +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSGpppt <header>[#aaaa OriaaFTpppp]	
589	Status: Fire Trouble / Smoke Detector (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:FIRE TROUBLE +++ACC aaaa SMOKE DETECTOR +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSGpppt <header>[#aaaa OriaFTpppp]	
590	Status: Fire Trouble / High Temp Sensor (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:FIRE TROUBLE +++ACC aaaa HIGH TEMPERATURE SENSOR +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSGpppt <header>[#aaaa OriaaFTpppp]	
591	Status: Fire Trouble / Waterflow Sensor (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:FIRE TROUBLE +++ACC aaaa WATER FLOW SENSOR +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSGpppt <header>[#aaaa OriaaFTpppp]	

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
592 Status: Gas Alarm (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:GAS ALARM +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSApppt <header>[#aaaa NriaaGApppp]	New Message
593 Status: Gas Missing (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:GAS MISSING +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSVspppt <header>[#aaaa NriaaUZppp]	New Message
594 Status: Gas Supervisory (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:GAS SUPV +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaJSpppt <header>[#aaaa NriaaGSppp]	New Message
595 Status: Gas Trouble (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:GAS TROUBLE +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSTpppt <header>[#aaaa NriaaGTpppp]	New Message
596 Status: High Temp Alarm (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S: HIGH-TEMP ALM +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSJpppt <header>[#aaaa NriaaKApppp]	New Message
597 Status: Hold-Up Alarm (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:HOLD-UP ALARM +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSDpppt <header>[#aaaa NriaaHApppp]	New Message
598 Status: Hold-Up Missing (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:HOLD-UP MISS +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSVpppt <header>[#aaaa NriaaUZpppp]	New Message
599 Status: Hold-Up Supervisory	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:HOLD-UP TRL +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSTpppt <header>[#aaaa NriaaHTpppp]	New Message
600 Status: Hold-Up Trouble (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:HOLD-UP TRL +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSTpppt <header>[#aaaa NriaaHTpppp]	New Message
601 Status: Missing Alarm	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:MISSING ALARM +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaaSZspppt <header>[#aaaa OriaaUZppp]	
602 Status: Missing Alarm (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:MISSING ALARM +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSZpppt <header>[#aaaa OriaaUZpppp]	
603 Status: Missing Fire Supervision	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:MIS FIR SUPRV +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaaSYspppt <header>[#aaaa OriaFZppp]	
604 Status: Missing Fire Supervision / Waterflow Sensor	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:MIS FIR SUPRV +++ACC aaaa WATER FLOW SENSOR +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaaSYspppt <header>[#aaaa OriaFZppp]	
605 Status: Missing Fire Supervision (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:MIS FIR SUPRV +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSYpppt <header>[#aaaa OriaaFZpppp]	
606 Status: Missing Fire Supervision / Waterflow Sensor (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:MIS FIR SUPRV +++ACC aaaa WATER FLOW SENSOR +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSYpppt <header>[#aaaa OriaaFZpppp]	
607 Status: Missing Supervision	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:MISS SUPERVISN +++ACC aaaa AREA=a POINT=PPP h1rrrlssssssaaaaSYspppt <header>[#aaaa OriaaBZppp]	
608 Status: Missing Supervision (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:MISS SUPERVISN +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSYpppt <header>[#aaaa OriaaBZpppp]	
609 Status: Missing Trouble	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:MISSING TRBL +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaaSVspppt <header>[#aaaa OriaaUYppp]	

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
610 Status: Missing Trouble (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:MISSING TRBL +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSVpppt <header>[#aaaa OriaaUYpppp]	
611 Status: Open by Area	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:OPENING +++ACC aaaa AREA=a h1rrrlssssssaaaaSOsssst <header>[#aaaa OriaOP]	
612 Status: Perimeter Delay by Area	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:PERIM DELAY +++ACC aaaa AREA=a h1rrrlssssssaaaaSCsssst <header>[#aaaa OriaNL]	
613 Status: Perimeter Instant by Area	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:PERIM INSTANT +++ACC aaaa AREA=a h1rrrlssssssaaaaSCsssst <header>[#aaaa OriaNL]	
614 Status: RF Transmitter Low Battery (Device Specific)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:RF BATTRY LOW +++ACC aaaa SDI=ddd h1rrrlssssssaaaaSTsD10t <header>[#aaaa OpiddXT]	
615 Status: RF Transmitter Low Battery	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:RF BATTRY LOW +++ACC aaaa AREA=a POINT=PPP h1rrrlssssssaaaaSTsppt <header>[#aaaa OriaXTppp]	
616 Status: RF Transmitter Low Battery (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:RF BATTRY LOW +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSTpppt <header>[#aaaa OriaaXTpppp]	
617 Status: RF Transmitter Tamper Alarm	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:RF TMPR-ALARM +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaaSAspppt <header>[#aaaa OriaTaAppp]	
618 Status: RF Transmitter Tamper Alarm (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:RF TMPR-ALARM +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSAppppt <header>[#aaaa OriaaTaApppp]	
619 Status: RF Transmitter Tamper Trouble	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:RF TMPR-TRBL +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaaSTsppt <header>[#aaaa OriaTaApppp]	
620 Status: RF Transmitter Tamper Trouble (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:RF TMPR-TRBL +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSTpppt <header>[#aaaa OriaaTaApppp]	
621 Status: Supervision	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:SUPERVISION +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaaSTsppt <header>[#aaaa OriaBSppt]	
622 Status: Supervision (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:SUPERVISION +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSTpppt <header>[#aaaa OriaaBSppp]	
623 Status: Trouble	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:TROUBLE +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaaSTsppt <header>[#aaaa OriaBTppp]	
624 Status: Trouble (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S:TROUBLE +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSTpppt <header>[#aaaa OriaaBTpppp]	
625 Status: Water Alarm (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa S: Water Alarm +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaaSJpppt <header>[#aaaa OriaaWApppp]	New Message
626 Supervision(Non-Fire)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SUPERVISION +++ACC aaaa AREA=a POINT=PPP h1rrrlssssssaaaaasJsppt <header>[#aaaa NriaBSppp]	
627 Supervision / Ground Fault (Non-Fire)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa GROUND FAULT +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaaasJsppt <header>[#aaaa NriaBSppp]	

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

	<b>Event</b>	<b>Device/Mode</b>	<b>Display/Explanation</b>	<b>Comments</b>
628	Supervision (Non Fire) (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SUPERVISION +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssssaaaasJppppt <header>[#aaaa NriaaBSpppp]	
629	Supervision / Ground Fault (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SUPERVISION +++ACC aaaa GROUND FAULT +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssssaaaasJppppt <header>[#aaaa NriaaBSpppp]	
630	Swinger Bypass	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SWINGER BYPASS +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssssaaaasNspppt <header>[#aaaa NriaaUBppp]	
631	Swinger Bypass (2112/2212)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SWINGER BYPASS +++ACC aaaa POINT=ppp h1rrrlssssssssaaaasNspppt <header>[#aaaa NUBppp]	
632	Swinger Bypass (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SWINGER BYPASS +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssssaaaasNppppt <header>[#aaaa NriaaUBpppp]	
633	Swinger Bypass (7112)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa SWINGER BYPASS h1rrrlssssssssaaaasNssts <header>[#aaaa NUB]	
634	Tamper Alarm (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa TAMPER ALARM +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssssaaaasAppppt <header>[#aaaa NriaaTAffff]	New Message
635	Tamper Alarm Restore (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa TAMPER RESTORE +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssssaaaasRppppt <header>[#aaaa NriaaTHffff]	New Message
636	Test Failed	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa TEST FAILED +++ACC aaaa PATH=ppp COND=nnn h1rrrlssssssssaaaasTsD49t <header>[#aaaa NpapppXXnnn]	

**Table 98: Modem4/ModemIlla<sup>2</sup> Messages**

	<b>Event</b>	<b>Device/Mode</b>	<b>Display/Explanation</b>	<b>Comments</b>
637	Test-Off Normal Expanded	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaaasRsssst h1rrrlssssssaaaaasBsssst h1rrrlssssssaaaaaSLsssst h1rrrlssssssaaaaaSTsssst h1rrrlssssssaaaaaSRsssst h1rrrlssssssaaaaaSTsssst h1rrrlssssssaaaaaSTsssst h1rrrlssssssaaaaaSTsssst h1rrrlssssssaaaaaSUsssst h1rrrlssssssaaaaaSDsssst h1rrrlssssssaaaaaSPsssst h1rrrlssssssaaaaaSTsssst h1rrrlssssssaaaaaSPsssst h1rrrlssssssaaaaaSTsssst h1rrrlssssssaaaaaSTsssst h1rrrlssssssaaaaaSTsssst h1rrrlssssssaaaaaSTsssst h1rrrlssssssaaaaaSTsssst h1rrrlssssssaaaaaSTsssst h1rrrlssssssaaaaaSTsssst h1rrrlssssssaaaaaSTsssst h1rrrlssssssaaaaaSTsssst h1rrrlssssssaaaaaSTsssst h1rrrlssssssaaaaaSTsssst h1rrrlssssssaaaaaSTsssst h1rrrlssssssaaaaaSTsssst h1rrrlssssssaaaaaSTsssst h1rrrlssssssaaaaaSTsssst h1rrrlssssssaaaaaSTsssst h1rrrlssssssaaaaaSTsssst h1rrrlssssssaaaaaSTsssst h1rrrlssssssaaaaaSTsssst h1rrrlssssssaaaaaSTsssst <header>[#aaaa NRY] <header>[#aaaa OJL] <header>[#aaaa OJO] <header>[#aaaa OET] <header>[#aaaa OLS] <header>[#aaaa OET] <header>[#aaaa ORA] <header>[#aaaa OJA] <header>[#aaaa OET] <header>[#aaaa OYC] <header>[#aaaa OIA] <header>[#aaaa OAT] <header>[#aaaa OYM] <header>[#aaaa OYT] <header>[#aaaa OYF] <header>[#aaaa OLT] <header>[#aaaa OXF] <header>[#aaaa OXQ] <header>[#aaaa OFS] <header>[#aaaa OAS] <header>[#aaaa OFT] <header>[#aaaa OBT] <header>[#aaaa OBT] <header>[#aaaa ONT] <header>[#aaaa OXS]	TEST-OFF NORMAL LOG THRESHOLD LOG OVERFLOW PT BUS TROUBLE PROG ACCESS OK RF RCVR TROUBLE BAD CALL TO RAM USER TAMPER SDI FAILURE COMM FAILURE EQUIPMENT FAIL AC FAILURE BATTERY MISSING BATTERY LOW PARMS BAD CKSUM PHONE FAIL EXTRA RF POINT RF INTERFERENCE FIRE SUPERVISION ANALOG SERVICE FIRE FAULT CTRL POINT FAULT CHK DEVICE FAULT NETWORK FAILURE RF RCVR TAMPER

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
639 Test Report (Non-Expanded)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrrlssssssaaaasRssssEt <header>[#aaaa NRP]	TEST REPORT
640 Test Report / Off Normal (Non-Expanded)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa TEST-OFF NORMAL h1rrrlssssssaaaasRssssEt <header>[#aaaa NRY]	
641 Time Changed by User	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa TIME CHANGED +++ACC aaaa h1rrrlssssssaaaasNsD07t <header>[#aaaa NidiiiJT]	ID=iii
642 Time Changed	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa TIME CHANGED h1rrrlssssssaaaasNsD07t <header>[#aaaa NJT]	
643 Time Changed by User (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa TIME CHANGED +++ACC aaaa h1rrrlssssssaaaasNsD07t <header>[#aaaa NidiiiJT]	ID=iiii
644 Trouble	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa TROUBLE REPORT +++ACC aaaa h1rrrlssssssaaaasTspppt <header>[#aaaa NriaBTppp]	AREA=a POINT=ppp
645 Trouble (2112/2212)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa TROUBLE REPORT +++ACC aaaa h1rrrlssssssaaaasTspppt <header>[#aaaa NBTPppp]	POINT=ppp
646 Trouble / Ground Fault	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa TROUBLE REPORT +++ACC aaaa GROUND FAULT +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaasTspppt <header>[#aaaa NriaBTppp]	
647 Trouble / Ground Fault (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa TROUBLE REPORT +++ACC aaaa GROUND FAULT +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaasTppppt <header>[#aaaa NriaaBTpppp]	
648 Trouble / Door Forced	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa TROUBLE REPORT +++ACC aaaa DOOR FORCED +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaasTspppt <header>[#aaaa NriaDJppp]	
649 Trouble / Door Forced (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa TROUBLE REPORT +++ACC aaaa DOOR FORCED +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaasTppppt <header>[#aaaa NriaaDJpppp]	
650 Trouble (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa TROUBLE REPORT +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaasTppppt <header>[#aaaa NriaaBTpppp]	
651 Unverified Event / Burg	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa UNVRFD EVT-BURG +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaasKspppt <header>[#aaaa NriaBGppp]	
652 Unverified Event / Fire	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa UNVRFD EVT-FIRE +++ACC aaaa AREA=a POINT=ppp h1rrrlssssssaaaasKspppt <header>[#aaaa NriaFGppp]	
653 Unverified Event / Burg	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa UNVRFD EVT-BURG +++ACC aaaa AREA=a CG=gg POINT=ppp h1rrrlssssssaaaasKspppt <header>[#aaaa NriaBGppp]	
654 Unverified Event / Fire	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa UNVRFD EVT-FIRE +++ACC aaaa AREA=a CG=gg POINT=ppp h1rrrlssssssaaaasKspppt <header>[#aaaa NriaFGppp]	
655 Unverified Event	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa UNVERIFIED EVENT +++ACC aaaa AREA=a CG=gg POINT=ppp h1rrrlssssssaaaasKspppt <header>[#aaaa NriaUGppp]	
656 Unverified Event / Burg (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa UNVRFD EVT-BURG +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaasKppppt <header>[#aaaa NriaaBGpppp]	

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
657 Unverified Event / Fire (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa UNVRFD EVT-FIRE +++ACC aaaa AREA=aa POINT=pppp h1rrrlssssssaaaasKppppt <header>[#aaaa NriaaFGpppp]	
658 Unverified Event / Burg (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa UNVRFD EVT-BURG +++ACC aaaa AREA=aa CG=gg POINT=pppp h1rrrlssssssaaaasKppppt <header>[#aaaa NriaaBGpppp]	
659 Unverified Event / Fire (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa UNVRFD EVT-FIRE +++ACC aaaa AREA=aa CG=gg POINT=pppp h1rrrlssssssaaaasKppppt <header>[#aaaa NriaaFGpppp]	
660 User Alarm 7 by User	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa USER ALARM CMD7 +++ACC aaaa AREA=a ID=iii h1rrrlssssssaaaasUsss7t <header>[#aaaa Nriaa/idiiiUA]	
661 User Alarm 7 (No User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa USER ALARM CMD7 +++ACC aaaa AREA=a h1rrrlssssssaaaasUsss7t <header>[#aaaa NriaUA]	
662 User Alarm 7 by User (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa USER ALARM CMD7 +++ACC aaaa AREA=aa ID=iii h1rrrlssssssaaaasUsss7t <header>[#aaaa Nriaa/idiiiUA]	
663 User Alarm 9 by User	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa USER ALARM CMD9 +++ACC aaaa AREA=a ID=iii h1rrrlssssssaaaasUsss9t <header>[#aaaa Nriaa/idiiiPA]	
664 User Alarm 9 (No User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa USER ALARM CMD9 +++ACC aaaa AREA=a h1rrrlssssssaaaasUsss9t <header>[#aaaa NriaPA]	
665 User Alarm 9 by User (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa USER ALARM CMD9 +++ACC aaaa AREA=aa ID=iii h1rrrlssssssaaaasUsss9t <header>[#aaaa Nriaa/idiiiPA]	
666 User Code Added by User	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa USER CODE ADDED +++ACC aaaa CODE ID=ccc ID=iii h1rrrlssssssaaaasNsD38t <header>[#aaaa NidiiiJYccc]	
667 User Code Added by User (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa USER CODE ADDED +++ACC aaaa CODE ID=cccc ID=iii h1rrrlssssssaaaasNsD38t <header>[#aaaa NidiiiJYcccc]	
668 User Code Changed by User	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa USR CODE CHANGE +++ACC aaaa CODE ID=ccc ID=iii h1rrrlssssssaaaasNsD04t <header>[#aaaa NidiiiJVccc]	
669 User Code Changed by User (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa USR CODE CHANGE +++ACC aaaa CODE ID=cccc ID=iii h1rrrlssssssaaaasNsD04t <header>[#aaaa NidiiiJVcccc]	
670 User Code Deleted by User	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa USR CODE DELETE +++ACC aaaa CODE ID=ccc ID=iii h1rrrlssssssaaaasNsD05t <header>[#aaaa NidiiiJXccc]	
671 User Code Deleted (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa USR CODE DELETE +++ACC aaaa CODE ID=cccc h1rrrlssssssaaaasNsD05t <header>[#aaaa NJXcccc]	
672 User Code Deleted by User (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa USR CODE DELETE +++ACC aaaa CODE ID=cccc ID=iii h1rrrlssssssaaaasNsD05t <header>[#aaaa NidiiiJXcccc]	
673 User Code Tamper (5 attempts in 5min)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa USR CODE TAMPER +++ACC aaaa AREA=a h1rrrlssssssaaaasNsD03t <header>[#aaaa NriaJA]	
674 User Code Tamper (2112/2212)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa USR CODE TAMPER h1rrrlssssssaaaasNsD03t <header>[#aaaa NJA]	
675 User Level Set by User	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa USER LEVEL SET +++ACC aaaa CODE ID=ccc ID=iii h1rrrlssssssaaaasNsD40t <header>[#aaaa NidiiiJZccc]	

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments
676 User Level Set	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasNsD40t <header>[#aaaa NJZcccc]	USER LEVEL SET CODE ID=cccc
677 User Level Set by User (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasNsD40t <header>[#aaaa NidiiiJZcccc]	USER LEVEL SET CODE ID=cccc ID=iiii
678 Valid Access	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa D6500 PROG ACCESS OK h1rrrlssssssaaaasRsF01t <header>[#aaaa NLS]	PROG ACCESS OK
679 Valid Access (SDI Device / D5360)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRsF01t <header>[#aaaa NpidddLS]	PROG ACCESS OK SDI=ddd
680 Valid Remote Access (2112/2212)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa D6500 RAM ACCESS OK h1rrrlssssssaaaasRsssFt <header>[#aaaa NRS]	RAM ACCESS OK
681 Valid Remote Access / Callback	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRsssFt <header>[#aaaa NphhhRS]	RAM ACCESS OK PH#=hh
682 Walk Test End by User (Invisible Points)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRsssFt <header>[#aaaa Nria/idiiiTE]	WALK TEST END INVISIBLE POINTS AREA=a ID=iiii
683 Walk Test End by User (Invisible Points) (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRsssFt <header>[#aaaa Nriaa/idiiiTE]	WALK TEST END INVISIBLE POINTS AREA=aa ID=iiii
684 Walk Test End (No User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRsssFt <header>[#aaaa NriaTE]	WALK TEST END AREA=a
685 Walk Test End by User	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRsssFt <header>[#aaaa Nria/idiiiTE]	WALK TEST END AREA=a ID=iiii
686 Walk Test End by User (4-digit User)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasRsssFt <header>[#aaaa Nriaa/idiiiTE]	WALK TEST END AREA=aa ID=iiii
687 Walk Test Point	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasZsppt <header>[#aaaa NriaBXppp]	WALK TEST PT AREA=a POINT=ppp
688 Walk Test Point (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasZpppt <header>[#aaaa NriaaBXppp]	WALK TEST PT AREA=aa POINT=pppp
689 Walk Test Point / Fire	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasZsppt <header>[#aaaa NriaFXppp]	WALK TST PT-FIR AREA=a POINT=ppp
690 Walk Test Point / Fire (4-digit Point)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasZpppt <header>[#aaaa NriaFXppp]	WALK TST PT-FIR AREA=aa POINT=pppp
691 Walk Test Start by User	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrrlssssssaaaasTsssFt <header>[#aaaa Nria/idiiITS]	WALK TEST START AREA=a ID=iiii
692 Walk Test Start by User (Invisible Points)	Printer: D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrrlssssssaaaasTsssFt <header>[#aaaa Nria/idiiITS]	WALK TEST START INVISIBLE POINTS AREA=a ID=iiii

**Table 98: Modem4/ModemIIIa<sup>2</sup> Messages**

Event	Device/Mode	Display/Explanation	Comments	
			Printer:	SIA Mode:
693 Walk Test Start by User (Invisible Points) (4-digit User)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrlssssssaaaaasTsssFt <header>[#aaaa Nriaa/idiiITS]	WALK TEST START INVISIBLE POINTS AREA=aa ID=iiii	
694 Walk Test Start	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrlssssssaaaaasTsssFt <header>[#aaaa NriaITS]	WALK TEST START AREA=a	
695 Walk Test Start by User (4-digit User)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrlssssssaaaaasTsssFt <header>[#aaaa Nriaa/idiiITS]	WALK TEST START AREA=aa ID=iiii	
696 Was Force Armed	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrlssssssaaaaasWsssst <header>[#aaaa NCW]	WAS FORCE ARMED	
697 Watchdog Reset	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa h1rrlssssssaaaaasNsD09t <header>[#aaaa NYW]	WATCHDOG RESET	
698 Watchdog Reset	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrlssssssaaaaasNsD09t <header>[#aaaa NpidddYW]	WATCHDOG RESET SDI=dddd D9412GV4 V2.01	New Message
699 Watchdog Reset (Device Specific)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrlssssssaaaaasNsD09t <header>[#aaaa NpidddyW]	WATCHDOG RESET SDI=ddd	
700 Watchdog Reset (4-digit Device) (Version text)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa +++ACC aaaa h1rrlssssssaaaaasNsD09t <header>[#aaaa NpidddyW]	WATCHDOG RESET SDI=dddd xxxxxxxx Vx.xx	New Message
701 Water Alarm (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrlssssssaaaaasJppppt <header>[#aaaa Nriaa/WApppp]	WATER ALARM AREA=aa POINT=pppp	New Message
702 Water Alarm Restore (4-digit Point)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Lxx ACC aaaa +++ACC aaaa h1rrlssssssaaaaasRppppt <header>[#aaaa Nriaa/WHpppp]	WATER ALM REST AREA=aa POINT=pppp	New Message

## ZONEX and Comex Translation

These items supply additional information related to Appendix C: Modem4/ModemIIla<sup>2</sup> Messages. Some of these numbered items are also referenced in the Comments section of Appendix C.

1. When **Point User Flag** is programmed to **Yes** in panel programming of panels that support this function, the zone and point information will be translated. The receiver converts point data to ZONEX format and user IDs to Comex format. Table 99 shows the translation of point data and Table 100 shows the translation of User IDs. If **Point User Flag** is programmed to a **No** in the panel, then the zone and point information are sent as received.

**Table 99: Point to ZONEX Translation**

Point	ZONEX
001-008	100-800
009-024	101-116
025-040	201-216
041-056	301-316
057-072	401-416
073-088	501-516
089-104	601-616
105-120	701-716
121-136	801-816
137-152	117-132
153-168	217-232
169-184	317-332
185-200	417-432
201-216	517-532
217-232	617-632
233-247	717-731

**Table 100: User ID to Comex Translation**

ID	COMEX
0	0
1-5	001-005
0-13	601-608
14-21	701-708
22-29	801-808
30-37	B01-B08
38-45	C01-C08
46-53	D01-D08
54-61	E01-E08
62-69	F01-F08
70-249	000

2. When the D7112 is transmitting a test report in Modem II format, the area number is sent to the automation system if the output format is in SIA communications mode.
3. When transmitted by a D7112, the identification number, if any, also prints. Refer to Forced Point in the D9112B Program Entry Guide.
4. For these events, the area denotes the location of the keypad used to initiate the event (see Sensor Reset).
5. BFSK Format: For the D9112, unless otherwise specified, the zone digit “z” uses the “BFSK Zone Code” as a base for a given point. This code is programmed in the control panel by point. The zone digit “i” indicates the most significant digit of the user ID.

6. For the D7112, unless otherwise specified, Table 101 is the basis for the zone digit “z” and ID translation; however, actual IDs only go up to 25.

<b>Table 101: Reported Zone/ID to Actual Point/ID</b>								
	Reported Zone/ID							
	1	2	3	4	5	6	7	8
Actual Point/ID	1	2	3	4	5	6	7	8
	9	10	11	12	13	14	15	16
	17	18	19	20	21	22	23	24
	25	26	27	28	29	30	31	32
	33	34	35	36	37	38	39	40
	41	42	43	44	45	46	47	48

#### Example 1: Label RF Point

```
dd/dd tt:tt ql ACC aaaa FIRE ALARM
+++ ACC aaaa AREA=a RF POINT=ppp
```

7. This message reports from a D7112 RF point. The internal or external printer prints the label “RF POINT=” instead of “POINT=” in the second line (Example 2).



## Appendix D: Network Messages



For networked accounts, Nxx appears instead of Lxx in the line number.

**Table 102: Network Messages**

	<b>Event</b>	<b>Device/Mode</b>	<b>Display</b>
1	Alarm Panel Substitution	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa      ALARM-PNL SUBST +++ ACC aaaa      PATH=003 COND=007 hlrrlssssssaaaaAsD53t <header>[#aaaa Npt003AA007]
2	Change of Status (C900 Voltage Low)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa      STATUS CHANGED +++ aaaa      C900 VOLTAGE LOW hlrrlssssssaaaaasXss58t <header>[#aaaa NSC0002]
3	Change of Status (C900 Voltage Restore)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa      STATUS CHANGED +++ aaaa      C900 VOLTAGE RESTORE hlrrlssssssaaaaasXss68t <header>[#aaaa NSC0003]
4	Change of Status (C900 Input Restored)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa      STATUS CHANGED +++ aaaa      C900 INPUT RESTORED hlrrlssssssaaaaasXss91t <header>[#aaaa NSC0010]
5	Change of Status (C900 Input Shorted)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa      STATUS CHANGED +++ aaaa      C900 INPUT SHORTED hlrrlssssssaaaaasXss89t <header>[#aaaa NSC0008]
6	Change of Status (C900 Intercept Disabled)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa      STATUS CHANGED +++ aaaa      C900 INTERCEPT DISABLED hlrrlssssssaaaaasXss93t <header>[#aaaa NSC0012]
7	Change of Status (C900 Intercept Enabled)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa      STATUS CHANGED +++ aaaa      C900 INTERCEPT ENABLED hlrrlssssssaaaaasXss92t <header>[#aaaa NSC0011]
8	Change of Status (C900 Output Activated)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa      STATUS CHANGED +++ aaaa      C900 OUTPUT ACTIVATED hlrrlssssssaaaaasXss85t <header>[#aaaa NSC0006]
9	Change of Status (C900 Output Deactivated)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa      STATUS CHANGED +++ aaaa      C900 OUTPUT DEACTIVATED hlrrlssssssaaaaasXss94t <header>[#aaaa NSC0007]
10	Change of Status (C900 Input Open)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa      STATUS CHANGED +++ aaaaC900 INPUT OPEN HlrrlssssssaaaaasXss90t <header>[#aaaa NSC0009]
11	Change of Status (C900 Reboot)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa      STATUS CHANGED +++ aaaa      C900 REBOOT hlrrlssssssaaaaasXss59t <header>[#aaaa NSC0001]
12	Change of Status (C900 Switched to Fallback)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa      STATUS CHANGED +++ aaaa      C900 SWITCHED TO FALBACK hlrrlssssssaaaaasXss82t <header>[#aaaa NSC0005]
13	Change of Status (C900 Switched to Intercept)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa      STATUS CHANGED +++ aaaa      C900 SWITCHED TO INTERCPT hlrrlssssssaaaaasXss87t <header>[#aaaa NSC0004]
14	C900 Command Sent (Activate Output)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa      COMMAND SENT +++ aaaa      ACTIVATE OUTPUT hlrrlssssssaaaaasXss84t <header>[#aaaa NCO0005]

**Table 102: Network Messages**

	<b>Event</b>	<b>Device/Mode</b>	<b>Display</b>
15	C900 Command Sent (Deactivate Output)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa COMMAND SENT +++ aaaa DEACTIVATE OUTPUT hlrrlssssssaaaaasXss86t <header>[#aaaa NCO0006]
16	C900 Command Sent (Disable Intercept Mode)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa COMMAND SENT +++ aaaa DISABLE INTERCEPT MODE hlrrlssssssaaaaasXss83t <header>[#aaaa NCO0004]
17	C900 Command Sent (Switch to Fallback Mode)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa COMMAND SENT +++ aaaa SWITCH TO FALLBACK MODE hlrrlssssssaaaaasXss81t <header>[#aaaa NCO0003]
18	C900 Command Sent (Switch to Intercept Mode)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa COMMAND SENT +++ aaaa SWITCH TO INTERCEPT MODE hlrrlssssssaaaaasXss88t <header>[#aaaa NCO0002]
19	C900 Command Sent (Supervision Rate Changed)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa COMMAND SENT +++ aaaa SUPERVISION RATE CHANGED hlrrlssssssaaaaasXss66t <header>[#aaaa NCO0001]
20	Communications Fail (Account Disabled by Attack)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa COMM FAIL +++ ACC aaaa ACCOUNT DISABLED BY ATTACK +++ ACC aaaa PATH=003 COND=008 hlrrlssssssaaaaasTsB03t <header>[#aaaa Npt003YC008]
21	Communications Fail (Polling Lost)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa COMM FAIL +++ ACC aaaa PATH=003 COND=009 hlrrlssssssaaaaasTsB02t <header>[#aaaa Npt003YC009]
22	Communications Fail Restore (Polling Restore)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa COMM FAIL RESTR +++ ACC aaaa PATH=003 COND=009 hlrrlssssssaaaaasNsB02t <header>[#aaaa Npt003YK009]
23	Dialer Error (Dialing Error)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa DIALER ERROR +++ aaaa DIALING ERROR hlrrlssssssaaaaasXss73t <header>[#aaaa NYU0003]
24	Dialer Error (Invalid Message)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa DIALER ERROR +++ aaaa INVALID MESSAGE hlrrlssssssaaaaasXss77t <header>[#aaaa NYU0007]
25	Dialer Error (Message Unknown)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa DIALER ERROR +++ aaaa MESSAGE UNKNOWN hlrrlssssssaaaaasXss76t <header>[#aaaa NYU0006]
26	Dialer Error (No Acknowledgement Received)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa DIALER ERROR +++ aaaa NO ACKNOWLEDGMNT RECEIVED hlrrlssssssaaaaasXss71t <header>[#aaaa NYU0001]
27	Dialer Error (Not Dialing)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa DIALER ERROR +++ aaaa NOT DIALING hlrrlssssssaaaaasXss72t <header>[#aaaa NYU0002]
28	Dialer Error (No Response to Acknowledgement)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa DIALER ERROR +++ aaaa NO RESPONSE TO ACK hlrrlssssssaaaaasXss75t <header>[#aaaa NYU0005]
29	Dialer Error (No Response to Handshake)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa DIALER ERROR +++ aaaa NO RESPONSE TO HANDSHAKE hlrrlssssssaaaaasXss74t <header>[#aaaa NYU0004]

<b>Table 102: Network Messages</b>			
	<b>Event</b>	<b>Device/Mode</b>	<b>Display</b>
30	Miscellaneous Message (30 Min Since Fallback Command)	Printer:  D6500 Mode: SIA Mode:	dd/dd tt:tt Nxx ACC aaaa +++ aaaa 30 MIN SINCE FALLBACK CMD hlrrlssssssaaaaasXss95t <header>[#aaaa NMI0001]



## Appendix E: Pulse Output

 Table 103 to Table 111 vary depending on the account number specified and the digit parameter programmed using the drop-down menus in Menu Item 3.1.7 Event 3/1 or 4/1 (Figure 27).

The output of the receiver depends on the reporting digit. Use the settings in Figure 27 that can be changed by the user:

Reporting digits 0 to 9 and A are alarms


Reporting digit B is an opening

Reporting digit C is a closing

Reporting digit D is a cancel

Reporting digit E is a restore

Figure 21: D6200 Receiver Software Line Card Configuration



**Table 103: Pulse 3/1 Format**

#	Event	Account Number	Reporting Digit	Device/Mode	Displays
1.	ALARM	123	4	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 123 ALARM_ZN 4 [10]1011ssssss123sAsss4 [13] [10]602415[9]00030101[#s123 NBA4] [13]
2.	OPENING	123	B	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 123 OPENING [10]1011ssssss123sOssss [13] [10]AA4214[9]00040101[#s123 NOP] [13]
3.	CLOSING	123	C	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 123 CLOSING [10]1011ssssss123sCssss [13] [10]F94B14[9]00050101[#s123 NCL] [13]
#	Event	Account Number	Reporting Digit	Device/Mode	Displays
4.	CANCEL	123	D	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 123 CANCEL [10]1011ssssss123s\ssss [13] [10]FBCE14[9]00060101[#s123 NOC] [13]
5.	RESTORE	123	E	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 123 RESTORE [10]1011ssssss123sRssss [13] [10]FC2214[9]00070101[#s123 NUR] [13]
6.	TROUBLE	123	F	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 123 TROUBLE [10]1011ssssss123sTssss [13] [10]ACD414[9]00080101[#s123 NBT] [13]

**Table 104: Pulse 3/1E Menu 3.1.3.12 3-1 Extended Format = 1**

#	Event	Account Number	Reporting Digit	Device/Mode	Displays
7.	ALARM	123	45	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 123 ALARM_ZN 45 [10]1011ssssss123sAss45 [13] [10]720816[9]00090101[#s123 NBA45] [13]
8.	OPENING	123	B5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 123 OPENING_ZN 5 [10]1011ssssss123sOssss5 [13] [10]B0B115[9]00100101[#s123 NOP5] [13]
9.	CLOSING	123	C5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 123 CLOSING_ZN 5 [10]1011ssssss123sCssss5 [13] [10]B62215[9]00110101[#s123 NCL5] [13]
10.	CANCEL	123	D5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 123 CANCEL_ZN 5 [10]1011ssssss123s\ssss5 [13] [10]15E115[9]00120101[#s123 NOC5] [13]
11.	RESTORE	123	E5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 123 RESTORE_ZN 5 [10]1011ssssss123sRssss5 [13] [10]98E715[9]00130101[#s123 NUR5] [13]
12.	TROUBLE	123	F5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 123 TROUBLE_ZN 5 [10]1011ssssss123sTssss5 [13] [10]1CB015[9]00140101[#s123 NBT5] [13]

**Table 105: Pulse 3/1E Menu 3.1.3.12 3-1 Extended Format = 2**

#	Event	Account Number	Reporting Digit	Device/Mode	Displays
13.	ALARM	123	45	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 123 ALARM_ZN 45 [10]1011sssssss123sAss45[13] [10]210D16[9]00450102[#s123 NBA45] [13]
14.	OPENING	123	B5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 123 OPENING ZN B5 [10]1011sssssss123sOssB5[13] [10]829516[9]00460102[#s123 NOPB5] [13]
15.	CLOSING	123	C5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 123 CLOSING ZN C5 [10]1011sssssss123sCssC5[13] [10]2F8216[9]00470102[#s123 NCLC5] [13]
16.	CANCEL	123	D5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 123 CANCEL ZN D5 [10]1011sssssss123s\ssD5[13] [10]EC1316[9]00480102[#s123 NOCD5] [13]
17.	RESTORE	123	E5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 123 RESTORE ZN E5 [10]1011sssssss123sRssE5[13] [10]2E4F16[9]00490102[#s123 NURE5] [13]
18.	TROUBLE	123	F5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 123 TROUBLE ZN F5 [10]1011sssssss123sTssF5[13] [10]C72516[9]00500102[#s123 NBTF5] [13]

**Table 106: Pulse 3/2**

#	Event	Account Number	Reporting Digit	Device/Mode	Displays
19.	ALARM	123	45	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 123 ALARM_ZN 45 [10]1011sssssss123sAss45[13] [10]446B16[9]00150101[#s123 NBA45] [13]
20.	OPENING	123	B5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 123 OPENING B5 [10]1011sssssss123sOssB5[13] [10]17F616[9]00160101[#s123 NOPB5] [13]
21.	CLOSING	123	C5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 123 CLOSING B5 [10]1011sssssss123sCssC5[13] [10]BAE116[9]00170101[#s123 NCLC5] [13]
22.	CANCEL	123	D5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 123 CANCEL B5 [10]1011sssssss123s\ssD5[13] [10]797016[9]00180101[#s123 NOCD5] [13]
23.	RESTORE	123	E5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 123 RESTORE B5 [10]1011sssssss123sRssE5[13] [10]BB2C16[9]00190101[#s123 NURE5] [13]
24.	TROUBLE	123	F5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 123 TROUBLE B5 [10]1011sssssss123sTssF5[13] [10]EA3F16[9]00200101[#s123 NBTF5] [13]

**Table 107:** Pulse 4/1

#	Event	Account Number	Reporting Digit	Device/Mode	Displays
25.	ALARM	1234	5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 ALARM_ZN 5 [10]1011ssssss1234sAsss5[13] [10]97CE15[9]00210101[#1234 NBA5][13]
26.	OPENING	1234	B	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 OPENING [10]1011ssssss1234sOssss[13] [10]020A14[9]00220101[#1234 NOP][13]
27.	CLOSING	1234	C	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 CLOSING [10]1011ssssss1234sCsss[13] [10]510314[9]00230101[#1234 NCL][13]
28.	CANCEL	1234	D	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 CANCEL [10]1011ssssss1234s\ssss[13] [10]908414[9]00240101[#1234 NOC][13]
29.	RESTORE	1234	E	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 RESTORE [10]1011ssssss1234sRssss[13] [10]976814[9]00250101[#1234 NUR][13]
30.	TROUBLE	1234	F	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 TROUBLE [10]1011ssssss1234sTssss[13] [10]C29B14[9]00260101[#1234 NBT][13]

**Table 108:** Pulse 4/1E Menu 3.1.3.3 4/1 Extended = 1

#	Event	Account Number	Reporting Digit	Device/Mode	Displays
31.	ALARM	1234	45	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 ALARM_ZN 45 [10]1011ssssss1234sAss45[13] [10]418416[9]00270101[#1234 NBA45][13]
32.	OPENING	1234	B5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 OPENING ZN 5 [10]1011ssssss1234sOssss5[13] [10]C5C215[9]00280101[#1234 NOP5][13]
33.	CLOSING	1234	C5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 CLOSING ZN 5 [10]1011ssssss1234sCsss5[13] [10]C35115[9]00290101[#1234 NCL5][13]
34.	CANCEL	1234	D5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 CANCEL ZN 5 [10]1011ssssss1234s\ssss5[13] [10]3EE515[9]00300101[#1234 NOC5][13]
35.	RESTORE	1234	E5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 RESTORE ZN 5 [10]1011ssssss1234sRssss5[13] [10]B3E315[9]00310101[#1234 NUR5][13]
36.	TROUBLE	1234	F5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 TROUBLE ZN 5 [10]1011ssssss1234sTssss5[13] [10]F6F615[9]00320101[#1234 NBT5][13]

**Table 109: Pulse 4/1E Menu 3.1.3.3 4/1 Extended = 2**

#	Event	Account Number	Reporting Digit	Device/Mode	Displays
37.	ALARM	1234	45	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 ALARM_ZN 45 [10]1011ssssss1234sAss45[13] [10]599816[9]00510102[#1234 NBA45][13]
38.	OPENING	1234	B5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 OPENING ZN B5 [10]1011ssssss1234sOssB5[13] [10]FA0016[9]00520102[#1234 NOPB5][13]
39.	CLOSING	1234	C5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 CLOSING ZN C5 [10]1011ssssss1234sCssC5[13] [10]571716[9]00530102[#1234 NCLC5][13]
40.	CANCEL	1234	D5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 CANCEL ZN D5 [10]1011ssssss1234s\ssD5[13] [10]F60416[9]00540102[#1234 NOCD5][13]
41.	RESTORE	1234	E5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 RESTORE ZN E5 [10]1011ssssss1234sRssE5[13] [10]345816[9]00550102[#1234 NURE5][13]
42.	TROUBLE	1234	F5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 TROUBLE ZN F5 [10]1011ssssss1234sTssF5[13] [10]FB2C16[9]00560102[#1234 NBTF5][13]

**Table 110: Pulse 4/2**

#	Event	Account Number	Reporting Digit	Device/Mode	Displays
43.	ALARM	1234	45	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 ALARM_ZN 45 [10]1011ssssss1234sAss45[13] [10]220516[9]00330101[#1234 NBA45][13]
44.	OPENING	1234	B5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 OPENING B5 [10]1011ssssss1234sOssB5[13] [10]708D16[9]00340101[#1234 NOPB5][13]
45.	CLOSING	1234	C5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 CLOSING C5 [10]1011ssssss1234sCssC5[13] [10]DD9A16[9]00350101[#1234 NCLC5][13]
46.	CANCEL	1234	D5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 CANCEL D5 [10]1011ssssss1234s\ssD5[13] [10]4DC816[9]00360101[#1234 NOCD5][13]
47.	RESTORE	1234	E5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 RESTORE E5 [10]1011ssssss1234sRssE5[13] [10]8F9416[9]00370101[#1234 NURE5][13]
48.	TROUBLE	1234	F5	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 TROUBLE F5 [10]1011ssssss1234sTssF5[13] [10]132316[9]00380101[#1234 NBTF5][13]

**Table 111: Pulse 4/3**

#	Event	Account Number	Reporting Digit	Device/Mode	Displays
49.	ALARM	1234	456	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 ALARM_ZN 456 [10]1011ssssss1234sAs456[13] [10]D5C017[9]00390101[#1234 NBA456] [13]
50.	OPENING	1234	B45	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 OPENING B45 [10]1011ssssss1234sOsB45[13] [10]114C17[9]00400101[#1234 NOPB45] [13]
51.	CLOSING	1234	C45	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 CLOSING C45 [10]1011ssssss1234sCsC45[13] [10]1FA117[9]00410101[#1234 NCLC45] [13]
52.	CANCEL	1234	D45	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 CANCEL D45 [10]1011ssssss1234s\sD45[13] [10]E2B017[9]00420101[#1234 NOCD45] [13]
53.	RESTORE	1234	E45	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 RESTORE E45 [10]1011ssssss1234sRsE45[13] [10]DB7217[9]00430101[#1234 NURE45] [13]
54.	TROUBLE	1234	F45	Printer: D6500 Mode: SIA Mode:	DD/DD TT:TT L01 ACCT 1234 TROUBLE F45 [10]1011ssssss1234sTsF45[13] [10]CC4C17[9]00440101[#1234 NBTF45] [13]

## Appendix F: Format ID (by Message Type)



If CONETTIX B6800-SR equals 1, the following outputs apply.

Generic Example

### D6500 Byte Description

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
h	9	r	r	l	s	s	s	s	a	a	a	a	C	C	C	C	C	C	C	t	

**Table 112:** Generic Byte Description

#	Title	Description
1	Header Character (h)	Optional, check with the computer automation software for compatibility
2	Message Type	9
3-4	Receiver Number	Receiver gateway number from 01 to 99
5	Line/Group Number	Line number in the receiver gateway that sent the message
6-9	Spaces	Six spaces
10-13	Account Number	Account number, four digits
14-21	Channels	Channels 1 to 8
22	Trailer Character	Typically, this is HEX 14

Generic Example

### SIA Mode Description

<LF><CRC><LEN><9><sequence#><receiver#><line#>[#aaaa|CCCCCCCC]<CR>

**Table 113:** Generic SIA Byte Description

Title	Description
L	Standard line feed character
CRC	Cyclical redundancy check number
LEN	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
Message Type	9
sequence#	The message sequence number, the valid sequence number range is 0001 to 9999
receiver#	The receiver gateway that sent the message, valid digits are 01 to 99
line# (Line/Group #)	The line number of the line in the receiver gateway that sent the message. Valid digits are 00 to 99. The receiver uses Line 0 (zero) for internal messages.
account#	The communicator's account number, four digits.
CCCCCCCC	Channel 1 to 8



The heavier outlined row in Table 112 and Table 113 indicates the meaning of the shaded digit in the D6500 Byte Description, SIA Mode Description Generic Examples, and Table 114.

Table 114 shows examples for each format that the receiver supports. If Menu Item 2.5.17 = 1, the following message type follows a specific format ID. If Menu Item 2.5.17 = 0, the output to automation follows the standard message type ID.

<b>Table 114: Message Examples</b>			
#	Communication Format	Mode	Message
	Acron Super Fast	SIA: D6500:	[10]146D18900120101[#123 45678912][13] [10]9011sssss12345678912[14]
	Ademco Contact-ID	SIA: D6500:	[10]6A721Ca00140101[#7401 18113003003][13] [10]a011s740118113003003[14]
	Ademco 4-1 Express	SIA: D6500:	[10]1FDC12b00150101[#1234 7][13] [10]b011sssss1234sAsss7[14]
	Ademco 4-2 Express	SIA: D6500:	[10]9D2F13c00160101[#1234 55][13] [10]c011sssss1234sAss55[14]
Ademco High Speed/ Scancom	4-8-1	SIA: D6500:	[10]C3651Cf00180101[#1234 5678s9123s4][13] [10]f011ss1234s5678s9123s4[14]
	5-8-1	SIA: D6500:	[10]69311Df00190101[#12345 6789s1234s5][13] [10]f011s1234s5678s9123s5[14]
	6-8-1	SIA: D6500:	[10]42CD1Ef00200101[#123456 7891s2345s6][13] [10]f011123456s7891s2345s6[14]
	ADT SIA	SIA: D6500:	[10]0BB619G00480101[#0308 Nid39OP2][13] [10]G011[#0308 Nid39OP2][14]
	Caller ID	SIA: D6500:	[10]257B1Ce00570101[#0000 &9569688558][13] [10]e011sssss9569688558[14]
	CFSK	SIA: D6500:	[10]BDAE17f00270101[#123ABC 0108][13] [10]f011sssss123ABC0108ss[14]
	DSC/Sur-Gard 4-3	SIA: D6500:	[10]99EA17d00170101[#1234 NBA567][13] [10]d011sssss1234sAs567[14]
	DTMF 4-1	SIA: D6500:	[10]02A215t00400101[#1234 NBA5][13] [10]t011sssss1234sAsss5[14]
	DTMF 4-2	SIA: D6500:	[10]40EC16u00410101[#1234 NBA56][13] [10]u011sssss1234sAss56[14]
	FBI Super Fast	SIA: D6500:	[10]921C15F00470101[#1234 5678][13] [10]F011sssss12345678ss[14]
	Internal Message	SIA: D500:	[10]5FB90EZ00090124[NLT][13] [10]Z010ssssssssssXss51[14]
	ITI	SIA: D6500:	[10]ABFB19f00490101[#MMTST g090A31][13] [10]f011ssssMvMTSTg090A31[14]
	Link Test	SIA: D6500:	[10]2D270B[9]00920100[][13] [10]1010ssssssssss@ssss[14]
Pulse	3-1	SIA: D6500:	[10]827316p00340101[#s123 NBA12][13] [10]p011sssss123sAss12[14]
	3-1E	SIA: D6500:	[10]16A815p00330101[#s706 NBA1][13] [10]p011sssss706sAsss1[14]
	Pulse 3-2	SIA: D6500:	[10]C37A16q00350101[#s706 NBA61][13] [10]q011sssss706sAss61[14]

<b>Table 115: Message Examples (continued)</b>				
	Pulse	4-1	SIA: D6500:	[10]608F15r00360101[#7066 NBA0][13] [10]r011sssss7066sAsss0[14]
		4-1E	SIA: D6500:	[10]5ACC16r00370101[#1234 NBA12][13] [10]r011sssss1234sAss12[14]
	Pulse	4-2	SIA: D6500:	[10]8A7F16s00380101[#7066 NBA02][13] [10]s011sssss7066sAss02[14]
		4-2E	SIA: D6500:	[10]185317s00390101[#1234 NBA566][13] [10]s011sssss1234sAs566[14]
	Modem4/ModemIIa <sup>2</sup> /ModemIId	SIA: D6500:		[10]8B9C1AA00440101[#1234 Nti1158LF][13] [10]A011sssss1234s*ssss[14]
	Modem II	SIA: D6500:		[10]942B15B00450101[#1481 NUR2][13] [10]B011sssss1481sRsss2[14]
	BFSK	SIA: D6500:		[10]FFF115C00460101[#s2B2 NBA3][13] [10]C011ssssss2B2sAsss3[14]
	Robofon	SIA: D6500:		[10]2D3B15j00280101[#123ABC 12][13] [10]j011ssss123ABC12ssss[14]
	Scancom	4-16-1	SIA: D6500:	[10]D47C26g00210101[#1234 2222s2222s2222s2222s2][13] [10]g011ss1234s2222s2222s2222s2222s2[14]
		5-16-1	SIA: D6500:	[10]91FC27g00220101[#12345 2222s2222s2222s2222s2][13] [10]g011s12345s2222s2222s2222s2222s2[14]
		6-16-1	SIA: D6500:	[10]13EA28g00230101[#123456 2222s2222s2222s2222s2][13] [10]g011123456s2222s2222s2222s2222s2[14]
	Scancom	4-24-1	SIA: D6500:	[10]091930h00240101[#1234 2222s2222s2222s2222s2222s2222s2][13] [10]h011ss1234s2222s2222s2222s2222s2222s2222s2[14]
		5-24-1	SIA: D6500:	[10]D4ED31h00250101[#12345 2222s2222s2222s2222s2222s2222s2222s2][13] [10]h011s12345s2222s2222s2222s2222s2222s2222s2[14]
		6-24-1	SIA: D6500:	[10]B51132h00260101[#123452 2222s2222s2222s2222s2222s2222s2222s2222s2222s2][13] [10]h011123452s2222s2222s2222s2222s2222s2222s2222s2[14]
	Seriee DTMF	SIA: D6500:		[10]61F619K00900101[#7080*#000***][13] [10]K01113*7080*#000***[14]
	Seriee FSK	SIA: D6500:		[10]352815k00290101[#123AB 101][13] [10]k011sssss123ABs1s01[14]
	Sescoa Super Speed	SIA: D6500:		[10]787215700110101[#0258 A56s][13] [10]7011sssss0258sA56ss[14]
	SIA	SIA: D6500:		[10]86E416[9]00500101[#7080 NBA01][13] [10]S011[#7080 NBA01][14]

**Table 116: Message Examples (continued)**

Silent Knight	FSK 0	SIA: D6500:	[10]3E6714E01040101[#4444 NOP][13] [10]E011ssssss4444sOssss[13]	
	FSK80	SIA: D6500:	[10]3E6714E01040101[#4444 NBA13][13] [10]E011ssssss4444sAss08[14]	
Silent Knight	FSK1	SIA: D6500:	[10]DC7115m00300101[#7654 sA01][13] [10]m011s7654"sA01[14]	
	FSK2	SIA: D6500:	[10]8AAC17m00310101[#123456 HA00][13] [10]m011s123456"HA00[14]	
Telim		SIA: D6500:	[10]C2EB26n00320101[#000257 1090000000110000000][13] [10]n011s000257s1s090000000110000000[14]	
Varitech FSK 4- 1, Varitec h FSK 4- 2	VFSK 4- 2	SIA: D6500:	[10]8EFA16v00430101[#1234 NBA98][13] [10]v011ssssss1234sAss98[14]	
	VFSK 4- 1	SIA: D6500:	[10]802515v00420101[#1234 NBA9][13] [10]v011ssssss1234sAsss9[14]	
VONK		SIA: D6500:	[10]802515v00450101[#55 123456789ABCDEFG][13] [10]v01155123456789ABCDEFG [14]	
X-SIA		SIA: D6500:	[10]86E416[9]01430101[#1234 6011100*THISISATEST'12][13] [10]S011[#1234 6011100*THISISATEST'12][14]	

## Appendix G: ADT SIA Report Codes

**Table 117:** ADT SIA Report Codes

Description	ADT SIA
<b>System Event</b>	
System Reset	
Reset Memory	
AC Fail	AA
AC Restore	AH
AC Fail 4 hour	AT
AC Fail 4 hour Restore	AJ
TELCO Line Trouble (Line 1 or Line 2)	LT
TELCO Line Trouble Restore (Line 1 or Line 2)	LR
Low Battery System	YT
Low Battery Restore	YR
Change Date	

Description	ADT SIA
<b>Expansion Module</b>	
Interactive Keypad Tamper	IA
Interactive Keypad Trouble – Supervision	IT
Interactive Keypad Restore	IR
Cardreader Alarm	DA
Cardreader Trouble	DT
Cardreader Restore	DR
Point Gateway Tamper Alarm	EA
Point Gateway Tamper – Supervision	ET
Point Gateway Restore	ER
Printer Tamper Alarm	PA
Printer Trouble – Supervision	PT
Printer Restore	PR

Description	ADT SIA
<b>Downloading</b>	
DLL Aborted	RA
Start DLL	RB
DLL Interrupted	RI
End DLL Altered	RS
DLL Comm Fail	RT
End DLL Not Altered	RG

Description	ADT SIA
<b>Burglary</b>	
BA Burg Alarm	BA
BA PT Bypass	BB
BA Restore	BR
BA Trouble	BT
BA PT Unbypass	BU

Description	ADT SIA
<b>Open/Close</b>	
BA Auto Close	CA
BA Auto Close with Bypass – within Group	CB
BA Trouble Closing (closed with burg during exit)	CF
BA Bypass Closing – within Group	CG
BA Closing	CL
BA Auto Open	OA
BA Irregular Opening	OI
BA Opening	OP
BA No Close – Sched close time expire	OT
BA Exit Fail, exit error (user)	EF

Description	ADT SIA
<b>Fire</b>	
Fire Alarm	FA
Fire Trouble	FT
Fire Restore	FR
Fire Alarm Silence	
Fire Point Bypass	FB
Fire Alarm Point Unbypass	FU
Supervisory Alarm	SS
Supervisory Trouble	ST
Supervisory Restore	SR
Supervisory Point Bypass	SB
Supervisory Unbypass	SU

Description	ADT SIA
<b>Panic</b>	
Hold-Up Alarm	HA
Hold-Up Point Trouble (sensor trouble)	HT
Hold-Up Restore	HR
Hold-Up Point Bypass	HB
Hold-Up Point Unbypass	HU
Hostage Alarm (Duress)	HH
Hostage Restore	HR
Medical Alarm	MA
Medical Restore	MR

Description	ADT SIA
<b>Scheduling</b>	
BA Change Close Time	
Change Auto On Level	
Change Close Time Print Only	

Description	ADT SIA
<b>Other</b>	
Supervised Bell Alarm	UA
Supervised Bell Trouble	UT
Supervised Bell Restore	UR
Remote Power Supply Alarm	UA
Remote Power Supply Trouble	UT
Remote Power Supply Restore	UR
Keyswitch Alarm	UA
Keyswitch Trouble	UT
Keyswitch Restore	UR
Janitor Keyswitch Alarm	UA
Janitor Keyswitch Trouble	UT
Janitor Keyswitch Restore	UR
Janitor On Premises (user on premises)	JI
Janitor Off Premises (user on premises restore)	JO
ADT On Premises	SI
ADT Off Premises	SO
Tamper Alarm	TA
Tamper Restore	TR
VVS Bypass	VB
VVS Unbypass	VU
Keypad Active	AC
Audible Walk Test	AT

Description	ADT SIA
Change Code	
Change Early Open	
Change Holiday	
Change Latest Close (sent to CMC only if Closing sched is altered)	CL
Change Open Time, schedule change	
Change Time, time/date reset	

Description	ADT SIA
<b>System Test</b>	
Walk Test, walk test mode	WT
Bell Test	BT
Hold-Up Test Alarm (sent to printer)	
Hold-Up Test Restore (sent to printer)	
Start FA Test, fire test	FM
End FA Test, fire test restore	FK
Start BA Test	BN
End BA Test	BK
Start Supervision Test	SM
End Supervision Test	SK
Start Hold-Up Test	HM
End Hold-Up Test	HK
Long Print	
Short Print	
Supervisory Test Print, manual trigger test report	ST
Supervisory Test Restore	ST
Fire Test Alarm Print, fire test	FA
Fire Test Restore Print, fire test restore	FR
BA Point Test Print	BT
BA Point Test Restore Print	BT
Hold-Up Suspicion Print	HS
Keypad No Access	NA
Untyped Bypass	UB
Untyped Unbypass	UU
Tamper Bypass	TB
Tamper Unbypass	TU
BA Diagnostics	BW
FA Diagnostics	FW
Output Trouble	UT
Output Restore	UR
Point Trouble	UT

Description	ADT SIA
Point Alarm, general alarm	UA
Point Restore, general alarm restore	UR
Untyped Diagnostics	UW
BA Weak Battery	BL
FA Weak Battery	FL
HA Weak Battery	HL
SA Weak Battery	SL
UA Weak Battery	UL

Description	ADT SIA
<b>Access</b>	
2 Man 2 <sup>nd</sup> Person	
Keypad Lockout	
Cardreader Irregular Access	DI
Manual PB Access, remote arm/disarm opening	MP
Access Denied Code Known, access denied	DK
Access Denied Code Unknown, access denied	DD

Description	ADT SIA
<b>Dialer Test Report</b>	
Dialer Test Report	RP1
Dialer Test Report with System Trouble	RP5



## Appendix H: RB2000 Messages



For lines that are grouped, Gxx appears instead of Lxx.

**Table 118:** RB2000 Messages

#	Event	Device/ Mode	Display
1.	Mains Power Failure	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxxxxxx +++ 0E 00 00 00 32 <header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxxxxxx +++ 0E 00 00 00 34
2.	Mains Power Return	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxxxxxx +++ 0E 00 00 00 B2 <header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxxxxxx +++ 0E 00 00 00 B4
3.	Battery Broken	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxxxxxx +++ 0E 00 00 00 33
4.	RF Y Battery Empty	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxxxxxx +++ 0E 00 02 XY 33
5.	RF Y Battery Full	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxxxxxx +++ 0E 00 00 00 B7
6.	HTS Battery Empty	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxxxxxx +++ 0E 00 00 00 37
7.	HTS Battery Full	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxxxxxx +++ 0E 00 00 00 B7
8.	Sensor Battery	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxxxxxx +++ 0E 00 00 00 38 <header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxxxxxx +++ 0E 00 00 00 B8
9.	Technical Alarm	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxxxxxx +++ 0E 00 00 00 41

**Table 118: RB2000 Messages (continued)**

#	Event	Device/ Mode	Display
10.	Technical Alarm Confirmed	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 00 00 C1
11.	PRO 100 Transmitter	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 00 00 42
		SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 00 00 C2
12.	PRO 100 Pull Cord	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 00 00 43
		SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 00 00 C3
13.	PRO 100 Situation Alarm	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 00 00 44
		SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 00 00 C4
14.	Pull Switch	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 00 00 46
		SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 00 00 C6
15.	Confirmation at Local Unit	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 00 00 47
		SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 00 00 C7
16.	Hand Transmitter/ Button	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 00 00 48
		SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 00 00 C8

**Table 118: RB2000 Messages (continued)**

#	Event	Device/ Mode	Display
17.	Emergency Button	SIA Printer	<header>[<VDS message>]<CR> <header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 C9
18.	External Input X	SIA Printer SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 01 XX 49 <header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 01 XX C9
19.	RF Y - Alarm	SIA Printer SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 02 XY 49 <header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 02 XY C9
20.	Activity Monitor	SIA Printer SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 4A <header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 CA
21.	Fire Alarm	SIA Printer SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 4B <header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 CB
22.	Fire Alarm from Ext Input X	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 01 XX 4B
23.	Intrusion	SIA Printer SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 4C <header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 CC
24.	Intrusion from Ext Input X	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 01 XX 4C

**Table 118: RB2000 Messages (continued)**

#	Event	Device/ Mode	Display
25.	Intrusion from RF X	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 01 XX 4C
26.	External Alarm Button	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 4D
		SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 CD
27.	Protocol Error	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 4E
		SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 CE
28.	RF Y Error	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 02 XY 51
		SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 02 XY D1
29.	RF Y Maintenance	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 02 XY 52
		SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 02 XY D2
30.	RF Y Start	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 02 XY 53
		SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 02 XY D3
31.	RF Y Disassembly	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 02 XY 54
		SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 02 XY D4

**Table 118: RB2000 Messages (continued)**

#	Event	Device/ Mode	Display
32.	RF Y Test OK	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 02 XY 55
		SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 02 XY D5
33.	RF Y Test NOK	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 02 XY 56
		SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 02 XY D6
34.	RF Y Plug	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 02 XY 57
		SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 02 XY D7
35.	RF Y Test	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 02 XY 58
		SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 02 XY D8
36.	Outgoing Call HNZ	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 60
37.	Resetting	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 61
38.	Personal Sign In	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx+++ 0E 00 00 00 62
39.	Personal Sign Out	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 63
40.	Door Alarm	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 64
41.	Bed Alarm	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 65

**Table 118: RB2000 Messages (continued)**

#	Event	Device/ Mode	Display
42.	Medical Remind	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 66
43.	Message 1	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 67
44.	Message 2	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 68
45.	Message 3	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 69
46.	Sign Out	SIA Printer  SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 71  <header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 78
47.	Sign In	SIA Printer  SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 F1  <header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 F8
48.	Service Call	SIA Printer  SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 72  <header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 F2
49.	Repeated Call	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 73
50.	Confirmation Call	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 F3
51.	Pager Call Activated	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 00 00 74

**Table 118: RB2000 Messages (continued)**

#	Event	Device/ Mode	Display
52.	Full Duplex Communication	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 00 00 75
53.	Test Call	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 00 00 79
		SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 00 00 F9
54.	RF Jamming	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 00 00 7A
		SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 00 00 FA
55.	RF Y No Alive	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 02 XY 7B
		SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 02 XY FB
56.	Call for Assistance	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 00 00 7C
		SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 00 00 FC
57.	Registration Call	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 00 00 7D
		SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 00 00 FD
58.	Manual Test Call	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 00 00 7E
		SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ OE 00 00 00 FE

**Table 118: RB2000 Messages (continued)**

#	Event	Device/ Mode	Display
59.	Release Code XX XX	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 00 XX XX FF
60.	Error Message HNZ2001	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 01 YY XX 42
61.	Error Ended HNZ2001	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 0E 01 YY XX C2
62.	Status: Mains Power Failure	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ A2 00 00 00 32
63.	Status: Battery Broken	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ A2 00 00 00 33
	Status: Battery Empty	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ A2 00 00 00 37
64.	Status: Signed Out	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ A2 00 00 00 71
65.	Remote Programming Request	SIA Printer	<header>[<VDS message>]<CR> MM/DD HH:MM Lxx RB2 ACCT xxxxxxxxxxxx +++ 10 00 xx yy 70

## Appendix I: SafeCom Messages



In D6500 Mode, the line number sent to the computer is only one digit. Refer to Table 119.



If Virtual Line is 00, it is disabled.

**Table 119: Virtual Line Conversion Table**

Line#	Converted to		Line#	Converted to	
	D6500	SIA		D6500	SIA
01	1	01	13	J	13
02	2	02	14	K	14
03	3	03	15	L	15
04	4	04	16	M	16
05	5	05	17	N	17
06	6	06	18	O	18
07	7	07	19	P	19
08	8	08	1A	Q	1a
09	9	09	1B	R	1b
0A	A	0a	1C	S	1c
0B	B	0b	1D	T	1d
0C	C	0c	1E	U	1e
0D	D	0d	1F	V	1f
0E	E	0e	20	W	20
0F	F	0f	21	X	21
10	G	10	22	Y	22
11	H	11	23	Y	22
12	I	12	FF	Y	22



For D6500 Mode, any Virtual Line greater than or equal to 22 is reported as Y.

For SIA Mode, any Virtual Line greater than or equal to 22 is reported as 22.

**Table 120: SafeCom Messages - Line Card or Account Signals**

#	Event	Device/ Mode	Display	Notes on Auto Output
1.	System Startup	6500 SIA <sup>1</sup>	hprrl00000100t <header>[#0000 0100]	
		Printer <sup>2</sup>	dd/dd tt:tt Sxx SYSTEM STARTUP	
2.	Radio Restart	6500 SIA <sup>1</sup>	hprrl0aaa0100t <header>[#0aaa 0100]	
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>restart	
3.	Battery Trouble	6500 SIA <sup>1</sup>	hprrl0aaa0103t <header>[#0aaa 0103]	
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>BATTERY TROUBLE	
4.	Battery Restoral	6500 SIA <sup>1</sup>	hprrl0aaa0104t <header>[#0aaa 0104]	
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa battery restore	
5.	Aux. Fault	6500 SIA <sup>1</sup>	hprrl0aaa0103t <header>[#0aaa 0103]	Valid only for DP1000, PID-FE10
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>AUX FAULT	
6.	Aux. Restoral	6500 SIA <sup>1</sup>	hprrl0aaa0104t <header>[#0aaa 0104]	Valid only for DP1000, PID-FE10
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa aux restore	
7.	AC Trouble	6500 SIA <sup>1</sup>	hprrl0aaa0105t <header>[#0aaa 0105]	
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>AC TROUBLE	
8.	AC Restoral	6500 SIA <sup>1</sup>	hprrl0aaa0106t <header>[#0aaa 0106]	
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa ac restore	
9.	External Power Fail	6500 SIA <sup>1</sup>	hprrl0aaa0105t <header>[#0aaa 0105]	SC3100 PID-0330 or 0340, SC2104 PID-0430 or 0440
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>POWER TROUBLE	
10.	External Power Restoral	6500 SIA <sup>1</sup>	hprrl0aaa0106t <header>[#0aaa 0106]	SC3100 PID-0330 or 0340, SC2104 PID-0430 or 0440
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa power restore	
11.	Remote Com Restore	6500 SIA <sup>1</sup>	hprrl0aaa0110t <header>[#0aaa 0110]	This indicates that the radio could not report a previous message (until just now).
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>REMOTE COM RESTORE	
12.	RF Trouble	6500 SIA <sup>1</sup>	hprrl0aaa0111t <header>[#0aaa 0111]	
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>RF TROUBLE	

**Table 120: SafeCom Messages - Line Card or Account Signals**

#	Event	Device/ Mode	Display	Notes on Auto Output
13.	RF Restore	6500 SIA <sup>1</sup>	hprrl0aaa0112t <header>[#0aaa 0112]	
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa rf restore	
14.	System RF Channel Busy	6500 SIA <sup>1</sup>	hprrl0000011lt <header>[#0000 0111]	
		Printer <sup>2</sup>	dd/dd tt:tt Sxx CHn>CHANNEL BUSY	
15.	System RF Channel Clear	6500 SIA <sup>1</sup>	hprrl00000112t <header>[#0000 0112]	
		Printer <sup>2</sup>	dd/dd tt:tt Sxx CHn channel clear	
16.	Channel Busy	6500 SIA <sup>1</sup>	hprrl0aaa0121t <header>[#0aaa 0121]	
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>CHANNEL BUSY	
17.	Channel Clear	6500 SIA <sup>1</sup>	hprrl0aaa0122t <header>[#0aaa 0122]	
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa channel clear	
18.	Dialer Error	6500 SIA <sup>1</sup>	hprrl0aaa022000t <header>[#0aaa 022000]	Dialer error is reported to automation in a format similar to 3-1 event.
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>DIALER ERROR e	
			"e" is error code. See below for details:	
			0 -unknown error 1 -dialing error 2 -handshake error 3 -noise error	
			4 -unexpected disconnect 5 -validation error 6 -priority error	
19.	Tamper Fault	6500 SIA <sup>1</sup>	hprrl0aaa03200301t <header>[#0aaa 03200301]	
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>TAMPER FAULT	
20.	Tamper Restore	6500 SIA <sup>1</sup>	hprrl0aaa03200101t <header>[#0aaa 03200101]	
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa tamper restore	
21.	Phone Line Fail	6500 SIA <sup>1</sup>	hprrl0aaa03200301t <header>[#0aaa 03200301]	Valid only for SC2104
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>TELCO TROUBLE	
22.	Phone Line Restore	6500 SIA <sup>1</sup>	hprrl0aaa03200101t <header>[#0aaa 03200101]	Valid only for SC2104
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa telco restore	
23.	Aux. Power Fail	6500 SIA <sup>1</sup>	hprrl0aaa03200301t <header>[#0aaa 03200301]	Valid only for SC5000
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>AUX POWER TROUBLE	

**Table 120: SafeCom Messages - Line Card or Account Signals**

#	Event	Device/ Mode	Display	Notes on Auto Output
24.	Aux. Power Restore	6500 SIA <sup>1</sup>	hprrl0aaa03200101t <header>[#0aaa 03200101]	Valid only for SC5000
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa aux power restore	
25.	Fire Panic	6500 SIA <sup>1</sup>	hprrl0aaa03200302t <header>[#0aaa 03200302]	Valid only for SC5000
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>FIRE PANIC	
26.	Burglary Panic	6500 SIA <sup>1</sup>	hprrl0aaa03200303t <header>[#0aaa 03200303]	Valid only for SC5000
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>BURGLARY PANIC	
27.	Silent/Medical Panic	6500 SIA <sup>1</sup>	hprrl0aaa03200304t <header>[#0aaa 03200304]	Valid only for SC5000
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>SILENT/MEDICAL PANIC	
28.	Operator Evacuation Bell	6500 SIA <sup>1</sup>	hprrl0aaa03200305t <header>[#0aaa 03200305]	Valid only for SC5000
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>OPERATOR EVACUATION	
29.	Input Normal	6500 SIA <sup>1</sup>	hprrl0aaa0320011it <header>[#0aaa 0320011i]	
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa normal: input i	
30.	Input Open	6500 SIA <sup>1</sup>	hprrl0aaa0320021it <header>[#0aaa 0320021i]	
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>OPENED: input i	
31.	Input Short	6500 SIA <sup>1</sup>	hprrl0aaa0320031it <header>[#0aaa 0320031i]	
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>SHORTED: input i	
32.	Input Bypass	6500 SIA <sup>1</sup>	hprrl0aaa0320041it <header>[#0aaa 0320041i]	
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa bypass: input i	
33.	Input Unbypass	6500 SIA <sup>1</sup>	hprrl0aaa0320051it <header>[#0aaa 0320051i]	
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa unbypass: input i	
34.	Zone Restore	6500 SIA <sup>1</sup>	hprrl0aaa0320011zt <header>[#0aaa 0320011z]	Valid only for SC5000
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa restore: zone z	

**Table 120: SafeCom Messages - Line Card or Account Signals**

#	Event	Device/ Mode	Display	Notes on Auto Output
35.	Zone Trouble	6500 SIA <sup>1</sup>	hprrl0aaa0320021zt <header>[#0aaa 0320021z]	Valid only for SC5000
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>TROUBLE: zone z	
36.	Fire Alarm	6500 SIA <sup>1</sup>	hprrl0aaa0320031zt <header>[#0aaa 0320031z]	Valid only for SC5000, depending on the zone type
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>FIRE: zone z	
37.	Silent Alarm	6500 SIA <sup>1</sup>	hprrl0aaa0320031zt <header>[#0aaa 0320031z]	Valid only for SC5000, depending on the zone type
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>SILENT: zone z	
38.	Burglary Alarm	6500 SIA <sup>1</sup>	hprrl0aaa0320031zt <header>[#0aaa 0320031z]	Valid only for SC5000, depending on the zone type
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>BURGLARY: zone z	
39.	Zone Bypass	6500 SIA <sup>1</sup>	hprrl0aaa0320041zt <header>[#0aaa 0320041z]	Valid only for SC5000
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa BYPASS: zone z	
40.	Zone Unbypass	6500 SIA <sup>1</sup>	hprrl0aaa0320051zt <header>[#0aaa 0320051z]	Valid only for SC5000
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa unbypass: zone z	
41.	Operator Armed	6500 SIA <sup>1</sup>	hprrl0aaa0320060t <header>[#0aaa 03200600]	Valid only for SC5000
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa OPERATOR ARMED	
42.	User Armed	6500 SIA <sup>1</sup>	hprrl0aaa0320060ut <header>[#0aaa 0320060u]	Valid only for SC5000
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa ARMED: user u	
43.	Operator Disarmed	6500 SIA <sup>1</sup>	hprrl0aaa03200700t <header>[#0aaa 03200700]	Valid only for SC5000
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>OPERATOR DISARMED	
44.	User Disarmed	6500 SIA <sup>1</sup>	hprrl0aaa0320070ut <header>[#0aaa 0320070u]	Valid only for SC5000
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>DISARMED: user u	
45.	User Duress	6500 SIA <sup>1</sup>	hprrl0aaa0320080ut <header>[#0aaa 0320080u]	Valid only for SC5000
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>DURESS: user u	
		6500 SIA <sup>1</sup>	hprrl0aaa03200900t <header>[#0aaa 03200900]	
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa OPERATOR CANCEL	
		6500 SIA <sup>1</sup>	hprrl0aaa0320090ut <header>[#0aaa 0320090u]	
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>CANCEL: user u	

1 - Refer to Table Explanation of Automation Output Items (within Message Body only).

2 - Refer to Table Explanation of Printer Output Items.

**Table 121: SafeCom Messages - Intercepted Control Panel Signals**

#	Event	Device/ Mode	Display
1.	3-1 Unexpanded	6500 SIA <sup>1</sup>	hprrlaaaa0220e0t <header>[#aaaa 0220e0]
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>(aaaa) e XXXXXXXX
2.	3-1 Expanded, 4- 2, BFSK, or Ademco 4-2 Express	6500 SIA <sup>1</sup>	hprrlaaaa0220ezt <header>[#aaaa 0220ez]
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>(aaaa) ez XXXXXXXX
3.	FBI SuperFast	6500 SIA <sup>1</sup>	hprrlaaaa0321ezzet <header>[#aaaa 0321ezze]
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>(aaaa) ee zzz >>>>>>>>>> aaa>XXXXXXXXXX
4.	Ademco 4-9 High Speed	6500 SIA <sup>1</sup>	hprrlaaaa0620eeeeeeeet0t <header>[#aaaa 0620eeeeeeeet0]
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>(aaaa) eeee eeee t
5.	Ademco Contact ID	6500 SIA <sup>1</sup>	hprrlaaaa072018qeeeggccc0t <header>[#aaaa 072018qeeeggccc0]
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>(aaaa) qeee gg czzz >>>>>>>>> aaa>qeeeTTTTTTXXXXXXX
6.	SIA DCS	6500 SIA <sup>1</sup>	hprrlaaaa0f20ffeeeezzzzz00000000000000000t <header>[#aaaa 0f20ffeeeezzzzz00000000000000000]
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>(aaaa) feezzz
7.	Modem II - PID 0x50	6500 SIA <sup>1</sup>	hprrlaaaa03231ezzt <header>[#aaaa 03231ezz]
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>(aaaa) ezz >>>>>>>>> aaa>XXXXXXXXXX
8.	Modem II - PID 0x72, Unexpanded, without Status Report	6500 SIA <sup>1</sup>	hprrlaaaa0322ez00t <header>[#aaaa 0322ez00]
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>(aaaa) e z00 >>>>>>>>> aaa>XXXXXXXXXX
9.	Modem II - PID 0x72, Unexpanded, with Status Report	6500 SIA <sup>1</sup>	hprrlaaaa0322ez00t <header>[#aaaa 0322ez00]
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>(aaaa) e z00 >>>>>>>>> aaa>STATUS:XXXXXXXXXX
10.	Modem II - PID 0x72, Expanded, without Status Report	6500 SIA <sup>1</sup>	hprrlaaaa0322ezzzt <header>[#aaaa 0322ezxx]
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>(aaaa) e zzz >>>>>>>>> aaa>XXXXXXXXXX
11.	Modem II - PID 0x72, Unexpanded, without Status Report	6500 SIA <sup>1</sup>	hprrlaaaa0322ez00t <header>[#aaaa 0322ez00]
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>(aaaa) e z00 >>>>>>>>> aaa>XXXXXXXXXX
12.	Modem II - PID 0x72, Unexpanded, with Status Report	6500 SIA <sup>1</sup>	hprrlaaaa0322ez00t <header>[#aaaa 0322ez00]
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>(aaaa) e z00 >>>>>>>>> aaa>STATUS:XXXXXXXXXX

**Table 121: SafeCom Messages - Intercepted Control Panel Signals**

#	Event	Device/ Mode	Display
13.	Modem II - PID 0x72, Expanded, without Status Report	6500 SIA <sup>1</sup>	hprrlaaaa0322ezzt <header>[#aaaa 0322ezxx]
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>(aaaa) e zzz >>>>>>>>>>>>> aaa>XXXXXXXXXX
14.	Modem III - PID 0x72, Expanded, with Status Report	6500 SIA <sup>1</sup>	hprrlaaaa0322ezzt <header>[#aaaa 0322ezzz]
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>(aaaa) e zxx >>>>>>>>>>>> aaa>STATUS:XXXXXXXXXX
15.	Modem II - PID 0xBB	6500 SIA <sup>1, 3</sup>	hprrlaaaa0621aaeezzz000t <header>[#aaaa 0621aaeezzz000]
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>(aaaa) aa ee zzz >>>>>>>>>>> aaa>XXXXXXXXXX
16.	Modem IIe/IIIfa2	6500 SIA <sup>1, 3</sup>	hprrlaaaa0621aaeezzz000t <header>[#aaaa 0621aaeezzz000]
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>(aaaa) aa ee zzz >>>>>>>>>>> aaa>XXXXXXXXXX
17.	Modem IIe/IIIfa2 with 4-Digit Zone	6500 SIA <sup>1, 3</sup>	hprrlaaaa0622aaeezzz00t <header>[#aaaa 0622aaeezzz00]
		Printer <sup>2</sup>	dd/dd tt:tt Sxx aaa>(aaaa) aa ee zzzz >>>>>>>>>>> aaa>XXXXXXXXXX
1 -	Refer to Table	Explanation of Automation Output Items (within Message Body only).	
2 -	Refer to Table	Explanation of Printer Output Items.	
3 -	Refer to Table	Supported Event Codes.	

**Table 122: Explanation of Automation Output Items (within Message Body only)**

Character	Meaning
aaa	Radio account number (in hex), range: 001 to 9C4.
i	Input number, range: 1 to 8.
z	Zone number, range: 1 to 8.
u	User number, range: 1 to 8.
aaaa	Control panel account number.
e ee eee eeee	Event code.
eeeeeeee	Event codes for Zone 1 thru 8 (Ademco 4-9 High Speed only).
t	Type code.
z zz zzz zzzz zzzzz	Zone (or contact) code.
gg	Group number.
ff	Function code.
aa	Area code.
q	Event qualifier (1: new event or opening, 3: restoral or closing, 6: previous message) (Ademco Contact ID only).
ccc	Hex contact or user code.

**Table 123: Explanation of Printer Output Items**

Character	Meaning
dd/dd	Month and day (MM/DD).
tt:tt	Time of message receipt (HH:MM).
S	SafeCom
xx	Line card number, range: 01 to 08.
n	Radio channel number, range: 1 to 8.
aaa	Radio account number (in hex), range: 001 to 9C4.
>	If exists, the signal is in high priority.
e	Error code (for dialer error signals only), range: 0 to 6.
i	Input number, range: 1 to 8.
z	Zone number, range: 1 to 8.
u	User number, range: 1 to 8.
(aaaa)	Control panel account number.

**Table 124: Explanation of Printer Output Items (continued)**

Character	Meaning
e ee eee	Event code.
eeee eeee	Event codes for Zone 1 thru 8 (Ademco 4-9 High Speed only).
t	Type code.
z zz zzz	Zone (or contact) code.
gg	Group number.
f	Function code.
aa	Area code.
XXXXXXXX	Translation text embedded (only when valid digital XLAT is selected for the radio account).
TTTTTTTT	Event type can be NEW, RESTORE, or PRIOR (Ademco Contact ID only).
q	Event qualifier (1: new event or opening, 3: restoral or closing, 6: previous message) (Ademco Contact ID only).

**Modem Ile Format**

DD/MM HH:MM:SS NNN &gt; (DDDD) AA EE ZZZ

Modem Ile messages are reported as AA EE ZZZ where AA is the area code, EE is the event code from Table , and ZZZ is the zone or user code. For example: 01 EF 009 = area 1, alarm zone 9.

**Table 125: Supported Event Codes**

Code	Meaning	Code	Meaning
FE	Listen in.	D4	Walk test point.
FD	Fail to call RAM.	D3	Extend close time by user ZZZ.
FC	Access granted.	D2	Cancel by user ZZZ.
FB	Duress user ZZZ.	D1	Status = open.
FA	User ZZZ alarm 7.	D0	Open by user ZZZ.
F9	User ZZZ alarm 9.	CF	Force close by user ZZZ.
F8	Point ZZZ bypass.	CE	Status = closed.
F7	Point ZZZ forced bypass.	CD	Close by user ZZZ.
F6	Status = alarm ZZZ.	CC	Test report.
F5	Status = trouble ZZZ.	CB	Log at threshold.
F4	Fire alarm ZZZ.	CA	Log overflow.
F3	Fire trouble ZZZ.	C9	Parameter change.
F2	Missing fire ZZZ.	C8	User code tamper by user ZZZ.
F1	Fire restore ZZZ.	C7	User code for user ZZZ added or changed.
F0	Fire trouble restore ZZZ.	C6	Sked ZZZ execute.
EF	Alarm ZZZ.	C5	Sked ZZZ changed.
EE	Trouble ZZZ.	C4	Date changed by user ZZZ.
ED	Restore ZZZ.	C3	Time changed by user ZZZ.
EC	Missing alarm ZZZ.	C2	User level set by user ZZZ.
EB	Missing trouble ZZZ.	C1	Valid programmer access by SDI device ZZZ.
EA	Point ZZZ open.	C0	Invalid programmer access by SDI device ZZZ.
E9	Point ZZZ close.	BF	Valid RAM access on phone ZZZ.
E8	Extra point ZZZ.	BE	Invalid RAM access on phone ZZZ.
E7	Point bus trouble.	BD	Comm fail phone ZZZ.
E6	All points tested.	BC	Comm restore phone ZZZ.
E5	Restoral from alarm.	BB	Phone line ZZZ fail.
E4	Fire cancel.	BA	Phone line ZZZ restore.
E3	User code added.	B9	SDI device ZZZ trouble.
E2	Service start.	B8	SDI device ZZZ restore.
E1	Service end.	B7	Panel AC fail.
E0	Sensor ZZZ reset.	B6	Panel AC restore.
DF	Relay ZZZ set.	B5	Panel battery missing.
DE	Relay ZZZ reset.	B4	Panel battery low.
DD	Panel was forced armed.	B3	Panel battery restore.
DC	Create status report.	B2	Panel watchdog activated.
DB	Fire walk start by user ZZZ.	B1	Supervision (non-fire) ZZZ.
DA	Fire walk end.	B0	Remote reset.
D9	Walk test start by user ZZZ.	AF	ROM checksum failure.
D8	Walk test end.	AE	Memory failure.
D7	Fail to open.	AD	Reboot
D6	Fail to close.	AC	Parameter checksum failure.
D5	Area watch by user ZZZ.	AB	Force perimeter instant by user ZZZ.
A6	Perimeter delayed by user ZZZ.	77	Status RF trans low battery point ZZZ.

**Table 125: Supported Event Codes**

Code	Meaning	Code	Meaning
A5	Passcode for user ZZZ deleted.	76	Status RF trans tamper alarm point ZZZ.
A4	Point bus restore.	75	Status RF trans tamper trouble point ZZZ.
A2	Transmitter point ZZZ battery low.	74	Sensor Trouble point ZZZ.
A1	Transmitter point ZZZ battery restore.	73	Sensor Trouble Restoral point ZZZ.
A0	Transmitter point ZZZ tamper restore.	72	Status fire missing point ZZZ.
9F	RF receiver trouble by SDI device ZZZ.	71	Status missing alarm point ZZZ.
9A	Extra RF point ZZZ.	70	Status missing trouble point ZZZ.
99	RF receiver restore by SDI device ZZZ.	6F	Status door forced point ZZZ.
98	RF interference by SDI device ZZZ.	6E	Door locked point ZZZ.
95	Transmitter point ZZZ tamper alarm.	6D	Missing fire supervision point ZZZ.
94	Transmitter point ZZZ tamper trouble.	6C	Missing supervision point ZZZ.
92	Equipment restoral by SDI device ZZZ.	6B	Status missing fire supervision point ZZZ.
91	Card assigned by user ZZZ.	6A	Status missing supervision point ZZZ.
90	Card deleted by user ZZZ.	69	Status door left open point ZZZ.
8F	Door cycled point ZZZ.	68	Failed to execute point ZZZ.
8E	Door unlocked point ZZZ.	5F	Analog service point ZZZ.
8D	Door locked point ZZZ.	5E	Analog restoral point ZZZ.
8C	No entry point ZZZ.	5D	Status analog service point ZZZ.
8B	Door left open point ZZZ.	5C	Test Failed path ZZZ.
8A	Door request point ZZZ.	5B	External device ZZZ.
89	Network failure path ZZZ.	5A	Custom Function ZZZ Executed.
88	Network restoral path ZZZ.	59	Low Temperature point ZZZ.
87	Network condition path ZZZ.	58	Low Temperature Restoral point ZZZ.
86	Equipment fail by SDI device ZZZ.	56	Unverified Event point ZZZ.
85	Status supervision point ZZZ.	55	Printer Status by SDI device ZZZ.
84	Fire Supervision Restoral point ZZZ.	54	Abort by user ZZZ.
83	Fire supervision point ZZZ.	53	Service Request.
82	Fire Supervision Trouble point ZZZ.	52	Output ZZZ State.
81	Fire Supervision Trouble Restoral point ZZZ.	51	Output ZZZ State Restoral.
7F	Status fire supervision point ZZZ.	50	Bypass Restoral point ZZZ.
7E	Extra account path ZZZ.	4F	Alarm Silenced point ZZZ.
7D	Low signal strength path ZZZ.	4E	Alarm-Panel Substitution path ZZZ.
7C	RF receiver tamper by SDI device ZZZ.		

## Appendix J: Acknowledgement from Automation Software



If a response other than a valid ACK or NAK is received, the receiver will transmit the last message again. It will continue to send the same message until a valid NAK or ACK is received.

### 1. Automation software to receiver, ACK.

The ACK from automation to receiver structure:

D6500 mode:

<0x06>

1 byte length and value is 0x06

**SIA mode:**

<LF><CRC><LEN><TAB><sequence#><receiver#><line>[]<CR>

<b>LF</b>	Standard line feed character.
<b>CRC</b>	Cyclical Redundancy Check number. (Calculated the same as in SIA DC-07)
<b>LEN</b>	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
<b>TAB</b>	09 hex
<b>Sequence#</b>	The message sequence number of the message which to be acknowledged.
<b>Receiver#</b>	The Receiver/Gateway number of the message to be acknowledged.
<b>Line#(Line/Group #)</b>	The line/group number of the message to be acknowledged.
<b>CR</b>	SIA trailer char, hex 0D

### 2. Automation software to receiver, NAK.



A NAK response from automation software will force the receiver to transmit the last message again. If 3 sequential NAKs are received for the same message, then the receiver will skip that message and move to the next one.

The NAK from automation to receiver structure:

D6500 mode:

<0x15>

1 byte length and value is 0x15

**SIA mode:**

<LF><CRC><LEN><TAB><0000><receiver#><00>[]<CR>

<b>LF</b>	Standard line feed character.
<b>CRC</b>	Cyclical Redundancy Check number. (Calculated the same as in SIA DC-07)
<b>LEN</b>	Two-digit length identifier that indicates how many characters directly follow it (the trailing <CR> character is not counted).
<b>TAB</b>	09 hex
<b>0000</b>	The message sequence number, fixed 0000 for NAK.
<b>Receiver#</b>	The Receiver/Gateway that receives the NAK message, valid digits are: 01-99.
<b>00</b>	The line number, fixed 00 for NAK.
<b>CR</b>	SIA trailer char, hex 0D



## Appendix K: Cyclic Redundancy Check (CRC) Calculation

This CRC calculation section is referenced from the SIA DC-07 Computer Interface Standard. The calculations for CRCs to the Bosch receivers are performed in the same manner.

CRCs are based on treating bit strings as representations of polynomials with coefficients of 0 and 1 only. An n-bit message is regarded as the coefficient list for a polynomial with n terms, ranging from  $x^{n-1}$  (high order bit) to  $x^0$  (low order bit).

For example, 110001 has 6 bits and thus represents a six term polynomial with coefficients 1, 1, 0, 0, 0, and 1:  $x^5 + x^4 + x^0$ .

When the polynomial code method is employed, the sender and receiver must agree upon a generator polynomial in advance. Both the high order and low order bits of the generator must be 1. The basic idea is that the polynomial represented by the check summed message is divided by the generator. If there is a remainder, then there has been a transmission error.

A 16 bit generator polynomial which has been widely implemented in data transfer protocols (such as XMODEM CRC) is:

$$X^{16} + X^{15} + X^2 + 1$$

This polynomial is called CRC-16. It catches all single and double errors, all errors with an odd number of bits, all burst errors of 16 bits or less, 99.997% (1/32768 chance of failure) of 17 bit burst errors, and 99.998% of 18 bit and longer burst errors (1/65536 chance of failure).

Polynomial arithmetic is done modulo 2, according to the rules of algebraic field theory, and therefore should be performed with simple exclusive-ORs. Floating point is not required.

### Calculation Routines

Two calculation routines are shown below, which each yield the same results. The second method of CRC calculation greatly speeds CRC processing, but does require a 512 byte table.

#### Calculation Method 1

The following C Language program illustrates CRC calculation. It can be compiled as shown with many compilers to demonstrate the CRC process.

```
/* THESE INCLUDES FOR MICROSOFT C 5.1 */
#include <stdio.h>
#include <stdlib.h>

/* FORWARDS */
unsigned int calcCRC(unsigned CRC, int ch);

void main(void)
{
    unsigned int CRC;      /* 16 BIT CRC RESULT */
    int count, ch;
    char *ptr, str[1024];
```

```

CRC = 0;
count = 0;
printf("Input string for CRC calculation (<CR> to end): ");
ptr = gets(str);
while (ch = *ptr++)
{
    CRC = calcCRC(CRC, ch); /* CALL CRC FUNCTION BELOW */
    printf("\nChar %c [%2.2x] CRC is %4.4x, %2.2x count",
        (ch > 32) ? ch : '.', ch, CRC, ++count);
}
unsigned int calcCRC(unsigned CRC, int ch)
{
int i;
unsigned char temp;

temp = (unsigned char)ch; /* TREAT LOCALLY AS UNSIGNED */
for (i = 0; i < 8; i++) /* DO 8 BITS */
{
    temp ^= CRC & 1; /* PROCESS LSB */
    CRC >>= 1; /* SHIFT RIGHT */
    if (temp & 1)
        CRC ^= 0xA001; /* IF LSB SET, ADD FEEDBACK */
    temp >>= 1; /* GO TO NEXT BIT */
}
return CRC;
}

```

## Calculation Method 2

Alternatively, the routine calcCRC could be replaced by the following, faster routine:

```

void calcCRC2(unsigned int CRC, int ch)
{
static unsigned int crcTable[] = {
/* DEFINE THE FIRST ORDER POLINOMIAL TABLE */
0x0000,0xc0c1,0xc181,0x0140,0xc301,0x03c0,0x0280,0xc241,
0xc601,0x06c0,0x0780,0xc741,0x0500,0xc5c1,0xc481,0x0440,
0xcc01,0x0cc0,0x0d80,0xcd41,0x0f00,0xcf1,0xce81,0x0e40,
0xa00,0xcac1,0xcb81,0xb40,0xc901,0x09c0,0x0880,0xc841,
0xd801,0x18c0,0x1980,0xd941,0x1b00,0xdb1,0xda81,0x1a40,
0xe00,0xdec1,0xdf81,0xf40,0xdd01,0x1dc0,0x1c80,0xdc41,
0x1400,0xd4c1,0xd581,0x1540,0xd701,0x17c0,0x1680,0xd641,
0xd201,0x12c0,0x1380,0xd341,0x1100,0xd1c1,0xd081,0x1040,
0xf001,0x30c0,0x3180,0xf141,0x3300,0xf3c1,0xf281,0x3240,
0x3600,0xf6c1,0xf781,0x3740,0xf501,0x35c0,0x3480,0xf441,
0x3c00,0xfc1,0xfd81,0x3d40,0xff01,0x3fc0,0x3e80,0xfe41,
0xfa01,0x3ac0,0x3b80,0xfb41,0x3900,0xf9c1,0xf881,0x3840,
0x2800,0xe8c1,0xe981,0x2940,0xbe01,0x2bc0,0x2a80,0xea41,
0xee01,0x2ec0,0x2f80,0xef41,0x2d00,0xedc1,0xec81,0x2c40,
0xe401,0x24c0,0x2580,0xe541,0x2700,0xe7c1,0xe681,0x2640,

```

```
0x2200,0xe2c1,0xe381,0x2340,0xe101,0x21c0,0x2080,0xe041,  
0xa001,0x60c0,0x6180,0xa141,0x6300,0xa3c1,0xa281,0x6240,  
0x6600,0xa6c1,0xa781,0x6740,0xa501,0x65c0,0x6480,0xa441,  
0x6c00,0xac1,0xad81,0x6d40,0xaf01,0x6fc0,0x6e80,0xae41,  
0xaa01,0x6ac0,0x6b80,0xab41,0x6900,0xa9c1,0xa881,0x6840,  
0x7800,0xb8c1,0xb981,0x7940,0xbb01,0x7bc0,0x7a80,0xba41,  
0xbe01,0x7ec0,0x7f80,0xbf41,0x7d00,0xbd1,0xbc81,0x7c40,  
0xb401,0x74c0,0x7580,0xb541,0x7700,0xb7c1,0xb681,0x7640,  
0x7200,0xb2c1,0xb381,0x7340,0xb101,0x71c0,0x7080,0xb041,  
0x5000,0x90c1,0x9181,0x5140,0x9301,0x53c0,0x5280,0x9241,  
0x9601,0x56c0,0x5780,0x9741,0x5500,0x95c1,0x9481,0x5440,  
0x9c01,0x5cc0,0x5d80,0x9d41,0x5f00,0x9fc1,0x9e81,0x5e40,  
0x5a00,0x9ac1,0x9b81,0x5b40,0x9901,0x59c0,0x5880,0x9841,  
0x8801,0x48c0,0x4980,0x8941,0x4b00,0x8bc1,0x8a81,0x4a40,  
0x4e00,0x8ec1,0x8f81,0x4f40,0x8d01,0x4dc0,0x4c80,0x8c41,  
0x4400,0x84c1,0x8581,0x4540,0x8701,0x47c0,0x4680,0x8641,  
0x8201,0x42c0,0x4380,0x8341,0x4100,0x81c1,0x8081,0x4040,  
};  
unsigned char temp;  
  
temp = (unsigned char)ch;  
return (CRC >> 8) ^ (crcTable[temp ^ (CRC & 0xff)]);
```



# Appendix L: Network Automation

## Overview

Network automation is a function of the receiver that allows the receiver to send the information from the receiver to the automation software using a network connection instead of a RS-232 serial connection to COM3 on the receivers.

## Automation Information

The Bosch receivers send events over the network using UDP/IP to the IP Address of the PC that the automation software is running on and the port # that the automation is listening for the receiver on. Each receiver should be sending to a unique port # on the automation PC. The automation will receive each packet and must cache the source IP address and source port # to be used for the ACK or NAK packet creation. The automation will extract the data portion of the UDP packet and process the data to create an ACK or NAK as it normally would.



The data portion of the IP packets is identical to the data that is sent over RS-232 serial to automation. Automation should process the data in the exact same manner as it would when received over serial.

The automation shall reply to the receiver with the proper ACK or NAK in the data portion of a UDP packet using the cached source IP Address and port # as the destination IP Address and port #.

Here is an example of this process:

- Link Test from receiver to automation example
  - Link Test packet is sent from receiver IP Address 192.168.1.10 Port # 7700 to automation on IP Address 192.168.1.200 Port #10000.
    - Source IP Address 192.168.1.10
    - Source Port # 7700
    - Destination IP Address 192.168.1.200
    - Destination Port # 10000
  - Automation accepts the packet, caches the source IP Address and Port #
  - Processes the data portion of the packet and generates the ACK/NAK for the data portion of the reply packet.
  - ACK/NAK reply packet is sent from automation IP Address 192.168.1.200 Port #10000 to receiver IP Address 192.168.1.10 Port #7700.
    - Source IP Address 192.168.1.200
    - Source Port 10000
    - Destination IP Address 192.168.1.10
    - Destination Port # 7700





**Bosch Security Systems B.V.**

Torenallee 49

5617 BA Eindhoven

Netherlands

**[www.boschsecurity.com](http://www.boschsecurity.com)**

© Bosch Security Systems B.V., 2023

**Building solutions for a better life.**

202306291746