

DECLARATION OF PERFORMANCE

No DoP0001

Unique identification code of the product-type:

RoLP LX Wall Base

Intended use/es:

Fire detection and fire alarm systems

Manufacturer:

Eaton Electrical Products Ltd, Llantarnam Park, Cwmbran, South Wales, NP44 3AW, United Kingdom

Authorised representative:

Not Applicable

System/s of AVCP:

System 1

Harmonised standard/s:

EN54-23:2010

Notified body/ies:

AFNOR Certification, 11 rue Francis de Pressensé, FR – 93571, La Plaine Saint-Denis, Cedex, France
(0333-CPR-075444)


Declared performance/s:

Essential Characteristics	Performance	Harmonized Technical Specification
		EN54-23:2010
Performance under fire conditions	Pass	4.3.1 to 4.3.7
Operational reliability	Pass	4.2.1 to 4.2.8
Durability Temperature Resistance	Pass	4.4.1.1 to 4.4.1.3
Durability Humidity Resistance	Pass	4.4.2.1 to 4.4.2.3
Durability Corrosion Resistance	Pass	4.4.4
Durability Shock and Vibration Resistance	Pass	4.4.3.1 to 4.4.3.4
Durability Electrical Stability	Pass	4.4.5

*The performance of the product identified above is in conformity with the set of declared performance/s.
 This declaration of performance is issued, in accordance with Regulations (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.*

Signed for an on behalf of the manufacturer by:

Name: Mr Philip Williams (Approvals Manager)

Signed: 

Place: Cwmbran

Date: 15th July 2019