



BOSCH

RPS Service Pack for FPD-7024 Fire Alarm Control Panel

FPD-7024



en

Release Notes

Table of contents

1	Introduction	4
1.1	Prerequisite	4
1.2	Requirements	4
2	Service pack RPS-FPD7024-SP1	5
2.1	Whats new	5
2.1.1	RPS programming for FPD-7024 without a dongle	5

1 Introduction

These release notes are for RPS users with version 6.08.200 installed and are related to an optional service pack release supporting the FPD-7024 Fire Alarm Control Panel.

1.1 Prerequisite

RPS version 6.08.200 must be installed in order to install this service pack.

1. Download RPS version. 6.08.200 file and install. Refer to RPS Help for detailed instructions in using RPS
 2. Download **RPS-FPD7024-SP1.exe** to a directory accessible to RPS.
 3. Launch the **RPS-FPD7024-SP1.exe** file and install.
- ✓ The installation wizard guides the user through the installation process.



1.2 Requirements

RPS version 6.08.200 is required. This release supports service pack: **RPS-FPD7024-SP1**.



Notice!

Future versions of RPS will not require the installation of service packs in order to use this capability.

2 **Service pack RPS-FPD7024-SP1**

Whats new

- *RPS programming for FPD-7024 without a dongle, page 5*

2.1 **Whats new**

This section examines the new features in this service pack release.

2.1.1 **RPS programming for FPD-7024 without a dongle**

In order to connect and program the control panel using RPS, a Bosch USB dongle is used. Installation of this service pack allows you to connect and program the FPD-7024 control panel without using the Bosch USB security dongle. This service pack does not affect the requirement of a security dongle for other Bosch control panels.



Bosch Security Systems B.V.

Torenallee 49

5617 BA Eindhoven

Netherlands

www.boschsecurity.com

© Bosch Security Systems B.V., 2019